



790 Buchanan Street
Amarillo, TX 79101

January 30, 2019

VIA ELECTRONIC FILING

Ms. Kimberly D. Bose, Secretary
Federal Energy Regulatory Commission
888 First Street, NE
Washington, DC 20426

Re: Public Service Company of Colorado
Southwestern Public Service Company
Xcel Energy Operating Companies Joint Open Access Transmission Tariff
Revisions to Wholesale Real Power Losses for Southwestern Public Service Company
Docket No. ER19-____-000

Dear Secretary Bose:

Pursuant to Section 205 of the Federal Power Act (“FPA”),¹ Part 35 of the regulations of the Federal Energy Regulatory Commission (“FERC” or “Commission”),² and Order No. 714,³ Public Service Company of Colorado (“PSCo”),⁴ on behalf of Southwestern Public Service Company (“SPS”), hereby submits eTariff records revising Sections 15.7 and 28.5 of the Xcel Energy Operating Companies Open Access Transmission Tariff (“Xcel Energy Tariff” or “Tariff”).⁵ The revisions update the stated real power loss percentages (“loss factors”) for service on the SPS system so they (i) are based on the most recent study of SPS system losses, and (ii) are consistent with the loss factors approved for and reflected in SPS’s retail rates in Texas and New Mexico.

SPS respectfully requests that the Commission accept the proposed tariff revisions for filing effective April 1, 2019, sixty (60) days after filing, without suspension.

¹ 16 U.S.C. § 824d.

² 18 C.F.R. § 35.13 (2018).

³ *Electronic Tariff Filings*, FERC Stats. & Regs. ¶ 31,276 (2008).

⁴ PSCo is the designated eTariff filing entity for the Xcel Energy OATT consistent with the requirements of Order No. 714. PSCo is a party to this filing solely as the eTariff filing entity.

⁵ Xcel Energy Operating Companies, FERC Electric Tariff, Third Revised Volume No. 1.

I. BACKGROUND

SPS is a New Mexico corporation and a wholly owned subsidiary of Xcel Energy Inc. (“Xcel Energy”). SPS is an operating utility engaged in, *inter alia*, the generation, purchase, transmission, distribution and sale of electricity to approximately 390,000 retail customers in portions of Texas and New Mexico. SPS also sells electric power and provides transmission service at wholesale to other utilities and electric cooperatives in Texas, New Mexico, Kansas, and Oklahoma.

SPS is a transmission-owning member of the Southwest Power Pool, Inc. (“SPP”), a FERC-approved Regional Transmission Organization (“RTO”). Transmission service over the SPS transmission system has been available under the SPP Open Access Transmission Tariff (“SPP Tariff”) since June 2000.

Xcel Energy Services Inc. (“XES”) is the centralized service company subsidiary of Xcel Energy and, as such, performs an array of administrative and general services on behalf of the Xcel Energy Operating Companies.⁶ Among other things, XES submits filings with and appears in proceedings before the Commission on behalf of SPS.

II. REASONS FOR THIS FILING

A. Updated Transmission and Distribution Loss Study.

The primary reason for this filing is to ensure that the transmission and distribution real power losses charged to SPS’s wholesale customers reflect the most recent analysis of the losses SPS experiences in providing such services and are consistent with the loss factors reflected in SPS’s retail rates in Texas and New Mexico. As discussed further by SPS Witness Mr. Wesley L. Berger, the existing Transmission and Distribution System – Primary Voltage real power loss factors set out in the Xcel Energy Tariff applicable to SPS were accepted effective May 1, 2016, Docket No. ER16-1030-000.⁷ The real power loss factors established in that docket were based on a loss study that analyzed data for the period from July 2012 through June 2013 (the “2013 Loss Study”).

The updated real power loss factors contained in this filing are based upon the most recent SPS loss study, completed in 2017 for the period of January 2016 through December 2016 (the “2016 Loss Study”). The 2016 Loss Study uses the same methodology as the 2013 Loss Study, with minor enhancements discussed by SPS Witness Mr. Duane J. Ripperger, and was accepted by the retail regulatory agencies with jurisdiction over SPS in 2018: the Public Utility Commission of Texas (“PUCT”) and the New Mexico Public Regulation Commission

⁶ The Xcel Energy Operating Companies are: SPS, PSCo, and Northern States Power Company, a Minnesota corporation, and Northern States Power Company, a Wisconsin corporation (collectively, the “NSP Companies”). The instant filing does not affect the rates for transmission service on the PSCo or NSP Companies’ systems.

⁷ *Public Service Company of Colorado*, Docket No. ER16-1030-000, delegated letter order (April 28, 2016).

(“NMPRC”).⁸ SPS then began to prepare this filing to similarly update the loss factors used in calculating wholesale rates.

As discussed more fully by Mr. Ripperger, the 2016 Loss Study quantifies, through engineering analysis and calculations, the physical power and energy losses that occurred on the SPS transmission and distribution system during the study period. The 2016 Loss Study reflects the impacts of changes to the SPS system since the 2013 Loss Study, including initiation of the SPP Integrated Marketplace, installation of new 345 kV transmission facilities, and increased wind and solar generation, including generation connected to the SPS distribution system.⁹ Implementing the updated loss factors in the Xcel Energy Tariff will provide for consistent allocations of costs between the three SPS rate jurisdictions: FERC wholesale, Texas retail, and New Mexico retail.

B. Summary of Current and Proposed Real Power Loss Factors.

The real power demand and energy loss factors for service on the SPS transmission system (“Transmission Loss Factors”) are stated as percentage values in Sections 15.7 and 28.5 of the Xcel Energy Tariff and incorporated into Attachment M, Appendix 1 of the SPP Tariff. The real power demand and energy loss factors for service on the SPS distribution system (“Distribution Loss Factors”), applicable to those SPS wholesale customers taking service at primary distribution voltage, are also stated in Sections 15.7 and 28.5 of the Xcel Energy Tariff. As discussed by Mr. Berger, the transmission loss factors total two transmission level loss factors described in the 2016 Loss Study into a composite transmission loss factor for the Xcel Energy Tariff and the SPP Tariff.¹⁰

As noted, the currently effective Transmission Loss Factors and Distribution Loss Factors accepted in Docket No. ER16-1030-000 were based on the 2013 Loss Study.¹¹ In this filing, SPS proposes to update the Transmission Loss Factors and Distribution Loss Factors with the values derived from the 2016 SPS Loss Study and accepted by the PUCT and NMPRC. The following table shows SPS’s currently effective and proposed loss demand and energy factors:

⁸ See *In the Matter of Southwestern Public Service Company’s Application for Revision of its Retail Electric Rates Pursuant to Advice Notice No. 272*, NMPRC Case No. 17-00255-UT, Final Order Adopting Recommended Decision (September 5, 2018); and *Application of Southwestern Public Service Company for Authority to Change Rates*, PUCT Docket No. 47527, Final Order (December 10, 2018).

⁹ Direct Testimony of Duane J. Ripperger, Exhibit No. SPS-0004 at PP. 15-17.

¹⁰ Direct Testimony of Wesley L. Berger (“Berger Direct Testimony”), Exhibit No. SPS-0001 at P. 10.

¹¹ See fn. 8. The 2013 Loss Study used the same methodology (with certain enhancements) that had been used by SPS in a 2009 Loss Study that supported SPS’s updated loss factors accepted effective December 1, 2012, pursuant to a Commission-approved uncontested settlement in Docket No. ER12-1682-000. See *Public Service Company of Colorado*, 142 FERC ¶ 61,099 (2013).

Table 1 – Current and Proposed Loss Factors

| | Demand Loss Factors | | Energy Loss Factors | |
|-----------------------------------|----------------------------|-----------------|----------------------------|-----------------|
| | <u>Current</u> | <u>Proposed</u> | <u>Current</u> | <u>Proposed</u> |
| Transmission | 3.107161% | 2.738606% | 2.881556% | 3.203203% |
| Distribution – Primary Voltage | 8.157751% | 8.846390% | 6.035731% | 6.327826% |

C. Impact of Proposed Tariff Revisions on Wholesale Customers.

The proposed updated Transmission and Distribution Loss Factors affect network transmission service customers in SPP Zone 11 who purchase transmission service under the SPP Tariff as well as wholesale production service customers who purchase power from SPS under wholesale requirements power sale agreements at the transmission and distribution level.¹² The Tariff revisions will affect the calculations of billing demands for both network transmission service under the SPP Tariff and wholesale production services provided by SPS. Specifically, the updated loss factors affect these wholesale power supply services because the loss factors are included in the calculation of how much energy each wholesale customer is purchasing under its power supply agreement.¹³ Therefore, although this filing is not amending these power supply agreements, the updated real power loss factors will affect the calculation of charges pursuant to the power supply agreements' existing terms.

Initially, SPS estimates the updated loss factors together will result in a net decrease in the overall annual costs to wholesale customers of approximately \$230,700, or approximately 0.07 percent.¹⁴ The overall charges to network transmission service customers under the SPP Tariff in Zone 11 (the SPS zone) will be reduced due to the reduction in the transmission Demand Loss Factor. The impact of the revised real power loss factors on wholesale production customers is a small annual cost increase. Exhibit No. SPS-0003 calculates the estimated impact by SPS wholesale customer using the revised loss factors applied to 2018 billings.¹⁵

¹² The affected wholesale transmission service customers in Zone 11 are: Golden Spread Electric Cooperative, Inc. (for itself and Tri-County Electric Cooperative, Inc.); Farmers' Electric Cooperative, Inc.; Lea County Electric Cooperative, Inc.; Central Valley Electric Cooperative, Inc.; Roosevelt County Electric Cooperative, Inc.; and West Texas Municipal Power Agency. All of these network transmission service customers also purchase power from SPS pursuant to Commission-approved cost-based wholesale requirements power supply sale agreements. Golden Spread purchases wholesale requirements power only for its Tri-County Electric Cooperative, Inc. member load.

¹³ For example, see the Replacement Power Sales Agreement between SPS and Central Valley Electric Cooperative dated January 15, 2010, SPS Electric Rate Schedule 114, Service Schedule A, Sections 3, 4, 5, and 6.

¹⁴ See Exhibit No. SPS-0003.

¹⁵ Berger Direct Testimony, Exhibit No. SPS-0001 at P. 14. The net impact to each wholesale customer is an estimated cost reduction, with the exception of Central Valley Electric Cooperative, Inc. ("Central Valley"). Central Valley is estimated to see a small total cost increase – approximately \$6800 compared to

Notably, the proposed Tariff revisions will not affect the collection of energy losses for transmission services under the SPP Tariff. Under Section II.(b) of Attachment M to the SPP OATT, energy losses are determined by the SPP regional system dispatch and included in the locational marginal prices charged to market participants, including SPS and network customers on the SPS system. The revised Energy loss factors affect only the allocation of SPS system energy costs between SPS wholesale production and retail customers.

D. Stakeholder Communications

In addition to being stated in the Xcel Energy Tariff, the SPS Transmission Demand loss factor is included in Attachment M (Loss Compensation Procedure), Appendix 1, to the SPP Tariff. SPS will work with SPP to file to modify Attachment M, Appendix 1 to the SPP Tariff to reflect the updated SPS transmission demand loss factors for purposes of calculating monthly billing determinants for the wholesale loads taking network service in the SPS rate zone (Zone 11).¹⁶ SPS discussed the need for this revision to Attachment M, Appendix 1 with SPP, and SPP has indicated it expects to submit companion changes to the SPP Tariff shortly after SPS submits this filing, to be effective on the same effective date approved by the Commission in this proceeding.

Prior to submitting this filing, on January 18, 2019, SPS also provided information to its wholesale transmission and production customers to notify them of the proposed changes to the SPS real power losses factors and the anticipated financial impact to each affected wholesale customer, and offered to hold individual meetings with each wholesale customer.¹⁷

E. The Tariff Revisions Should be Accepted for Filing

For the reasons stated above, SPS requests that the Commission accept the proposed changes to Sections 15.7 and 28.5 of the Xcel Energy Tariff for filing, to be subsequently incorporated into Attachment M, Appendix 1 of the SPP Tariff. The proposed revisions are further explained in the attached Testimonies and Exhibits of Mr. Wesley L. Berger and Mr. Duane J. Ripperger in support of the instant filing, including the 2016 Loss Study included as Exhibit No. SPS-0005 to Mr. Ripperger's testimony. As noted, the 2016 Loss Study uses the same basic methodology used in the 2013 Loss Study supporting SPS's currently effective real power loss factors in Sections 15.7 and 28.5, with certain refinements discussed by Mr. Ripperger.

total transmission service and production service billings of \$29.97 million – because of the high load factor at which Central Valley purchases energy from SPS. *Id.* at P. 15.

¹⁶ Berger Direct Testimony, Exhibit SPS-0001 at P. 6. Attachment M, Appendix 1 refers to a Delivery Loss Factor (“DLF”) and an Injection Loss Factor (“ILF”). The ILF equals the SPS Demand Loss factor stated in Section 15.7 and 28.5. The DLF is calculated as $1/(1-ILF)-1$. So an SPS transmission demand real power loss factor (ILF) of 2.738606% would result in an SPP DLF of 2.8115717%. *Id.* at PP. 12-13.

¹⁷ Berger Direct Testimony, Exhibit SPS-0001 at P. 15.

III. ADDITIONAL INFORMATION SUBMITTED IN SUPPORT OF FILING

A. Information Required by Section 35.13 of the Commission's Regulations, 18 C.F.R. § 35.13

1. Contents of Filing – Section 35.13(b)(1)

In addition to this transmittal letter, the filing consists of the following:

- Electronic marked and clean versions of Sections 15 and 28 of the Xcel Energy Tariff in eTariff format, including the revisions to Section 15.7 and 28.5;
- the testimony, exhibits and affidavit of Mr. Wesley L. Berger (Exhibit Nos. SPS-0001, SPS-0002, and SPS-0003); and
- the testimony, exhibit and affidavit of Mr. Duane J. Ripperger (Exhibit Nos. SPS-0004 and SPS-0005), including the 2016 Loss Study.

B. Requested Effective Date – Section 35.13(b)(2)

SPS respectfully requests that the Commission allow the proposed revised Tariff revisions to be effective April 1, 2019, sixty (60) days after filing, without suspension or condition for good cause shown. As noted, the transmission Demand Loss change will result in a small reduction in fixed charges to network transmission service customers (due to lower billing determinants after adjusting for transmission demand losses), and overall the proposed loss factors result in a net cost decrease to SPS wholesale customers of approximately \$230,700 annually.¹⁸ The revised real power loss factors reflect the most current SPS system loss study available, and will provide for consistent cost allocations between the three SPS rate jurisdictions (FERC wholesale, Texas retail and New Mexico retail).

If the Commission nonetheless believes a suspension is warranted, SPS respectfully asks that the Commission allow the proposed revised tariff provisions to become effective April 1, 2019, subject to refund, after only a nominal suspension. In *West Texas Utilities Co.*, the Commission explained that a minimal suspension period is justified in cases where no more than ten percent of the proposed increase appears to be excessive.¹⁹ The overall rate change proposed here is negligible (-0.072 percent), and no portion of the minimal change in charges is excessive.

SPS believes the materials submitted herewith comply with the Commission's filing requirements and will permit the Commission to review the proposed revisions and determine them to be just and reasonable. SPS respectfully requests waiver of any applicable filing or notice requirements under the Commission's Rules and Regulations as may be necessary to accept the proposed revisions to the Xcel Energy Tariff on the date requested.

¹⁸ See Exhibit No. SPS-0003.

¹⁹ *West Texas Utilities Co.*, 18 FERC ¶ 61,189, at 61,375 (1982).

1. The Names and Addresses of Persons to Whom a Copy of the Rate Change Has Been Posted – Section 35.13(b)(3)

An electronic notice of this filing will be served on the state commissions with jurisdiction over SPS. Electronic notice of this filing will also be provided to SPP and all network transmission service customers taking service under the SPP Tariff in the SPS rate zone (Zone 11), and on SPS's wholesale production service customers. A courtesy copy or notice will be served on the Commission's Director of the Division of Tariffs and Market Development (Central).

In addition, pursuant to 18 C.F.R. § 35.2(d), a copy of this filing will be available for public inspection at the offices of SPS in Amarillo, Texas. Finally, a copy of this filing will be posted at the Open Access Transmission Tariff link at the Xcel Energy Transmission website: (www.transmission.xcelenergy.com/Resources/Open-Access-Same-Time-Information-System-&-Open-Access-Transmission-Tariff).

2. Brief Description of Rate Change – Section 35.13(b)(4)

See Sections II and III above.

3. Statement of Reasons for Rate Change – Section 35.13(b)(5)

See Sections II and III above.

4. Requisite Agreement for Rate Change – Section 35.13(b)(6)

See Section II above.

5. Statement Showing Expenses or Costs Included in Cost-of-Service Statements – Section 35.13(b)(7)

None of the costs related to this filing have been alleged in any administrative or judicial proceeding to be illegal, duplicative, or unnecessary costs that are demonstrably the product of discriminatory practices.

C. Communications and Service

Please direct any communication or correspondence with respect to this filing to the following:²⁰

²⁰ SPS respectfully requests waiver of 18 C.F.R. Section 385.203(b)(3) of the Commission's regulations to permit the designation of more than two persons upon whom service is to be made in this proceeding.

Ms. Kimberly D. Bose

January 30, 2019

Page 8

Wesley Berger
Manager, Rate Cases
Regulatory Administration
Southwestern Public Service Company
790 Buchanan St., 7th Floor
Amarillo, TX 79101
Phone: (806) 378-2891
Email: wes.berger@xcelenergy.com

James P. Johnson
Assistant General Counsel
Xcel Energy Services Inc.
414 Nicollet Mall – 401 – 8
Minneapolis, MN 55401
(612) 215-4592 (phone)
Email: james.p.johnson@xcelenergy.com

Bernard Liu
Senior Transmission Tariff Consultant
Xcel Energy Services Inc.
414 Nicollet Mall – 401 – 8
Minneapolis, MN 55401
Phone: (612) 330-5728
Email: Bernard.Liu@xcelenergy.com

Mark C. Moeller
Manager, Transmission Business Relations
Xcel Energy Services Inc.
414 Nicollet Mall – 6
Minneapolis, MN 55401
Phone: (612) 330-6773
Email: mark.c.moeller@xcelenergy.com

IV. CONCLUSION

For the reasons stated above, SPS requests that the Commission accept the proposed revisions to Sections 15.7 and 28.5 of the Xcel Energy Tariff to update SPS's Transmission Loss Factors and the Distribution System - Primary Voltage Loss Factors effective April 1, 2019.

SPS appreciates the Commission's prompt attention to this matter. Please direct any questions regarding this filing to the undersigned at (806) 378-2891 or Ms. Tracee Holte at (612) 330-6206.

Respectfully submitted,

/s/ Wesley Berger

Wesley Berger
Manager, Rate Cases
Southwestern Public Service Company

Cc: State Commissions service list
SPS Transmission and Production customers
Southwest Power Pool, Inc.
Director, Division of Tariffs and Market Development (Central)

CERTIFICATE OF SERVICE

I, Elizabeth A. Walkup, hereby certify that I have this day electronically served a notice of the foregoing document via email on the Public Utility Commission of Texas, the New Mexico Public Regulation Commission, Southwest Power Pool, Inc., all SPS wholesale transmission customers within the SPS pricing zone taking service under the SPP OATT, and all SPS wholesale production customers.

Dated at Minneapolis, Minnesota this 30th day of January 2019.

/s/ Elizabeth A. Walkup
Elizabeth A. Walkup
Business Analyst
Xcel Energy Services Inc.
414 Nicollet Mall
Minneapolis, MN 55401
Tel: 612-330-6780
Elizabeth.A.Walkup@xcelenergy.com

Proposed Effective Date: 4/1/2019

Approved Effective Date:

15 Service Availability

- 15.1 General Conditions:** The Transmission Provider will provide Firm and Non-Firm Point-To-Point Transmission Service over, on or across its Transmission System to any Transmission Customer that has met the requirements of Section 16.
- 15.2 Determination of Available Transfer Capability:** A description of the Transmission Provider's specific methodology for assessing available transfer capability posted on the Transmission Provider's OASIS (Section 4) is contained in Attachment C of the Tariff. In the event sufficient transfer capability may not exist to accommodate a service request, the Transmission Provider will respond by performing a System Impact Study.
- 15.3 Initiating Service in the Absence of an Executed Service Agreement:** If the Transmission Provider and the Transmission Customer requesting Firm or Non-Firm Point-To-Point Transmission Service cannot agree on all the terms and conditions of the Point-To-Point Service Agreement, the Transmission Provider shall file with the Commission, within thirty (30) days after the date the Transmission Customer provides written notification directing the Transmission Provider to file, an unexecuted Point-To-Point Service Agreement containing terms and conditions deemed appropriate by the Transmission Provider for such requested Transmission Service. The Transmission Provider shall commence providing Transmission Service subject to the Transmission Customer agreeing to (i) compensate the Transmission Provider at whatever rate the Commission ultimately determines to be just and reasonable, and (ii) comply with the terms and conditions of the Tariff including posting appropriate security deposits in accordance with the terms of Section 17.3.
- 15.4 Obligation to Provide Transmission Service that Requires Expansion or Modification of the Transmission System, Redispatch or Conditional Curtailment:**
- (a) If the Transmission Provider determines that it cannot accommodate a Completed Application for Firm Point-To-Point Transmission Service because of insufficient capability on its Transmission System, the Transmission Provider will use due diligence to expand or modify its Transmission System to provide the requested Firm Transmission Service, consistent with its planning obligations in Attachment R, provided the Transmission Customer agrees to compensate the Transmission Provider for such costs pursuant to the terms of Section 27. The Transmission Provider will conform to Good Utility Practice and its planning obligations in Attachment R, in determining the need for new facilities and in the design and construction of such facilities. The obligation applies only to those facilities that the Transmission Provider has the right to expand or modify.
 - (b) If the Transmission Provider determines that it cannot accommodate a

Proposed Effective Date: 4/1/2019

Approved Effective Date:

Completed Application for Long-Term Firm Point-To-Point Transmission Service because of insufficient capability on its Transmission System, the Transmission Provider will use due diligence to provide redispatch from its own resources until (i) Network Upgrades are completed for the Transmission Customer, (ii) the Transmission Provider determines through a biennial reassessment that it can no longer reliably provide the redispatch, or (iii) the Transmission Customer terminates the service because of redispatch changes resulting from the reassessment. A Transmission Provider shall not unreasonably deny self-provided redispatch or redispatch arranged by the Transmission Customer from a third party resource.

- (c) If the Transmission Provider determines that it cannot accommodate a Completed Application for Long-Term Firm Point-To-Point Transmission Service because of insufficient capability on its Transmission System, the Transmission Provider will offer the Firm Transmission Service with the condition that the Transmission Provider may curtail the service prior to the curtailment of other Firm Transmission Service for a specified number of hours per year or during System Condition(s). If the Transmission Customer accepts the service, the Transmission Provider will use due diligence to provide the service until (i) Network Upgrades are completed for the Transmission Customer, (ii) the Transmission Provider determines through a biennial reassessment that it can no longer reliably provide such service, or (iii) the Transmission Customer terminates the service because the reassessment increased the number of hours per year of conditional curtailment or changed the System Conditions.

15.5 Deferral of Service: The Transmission Provider may defer providing service until it completes construction of new transmission facilities or upgrades needed to provide Firm Point-To-Point Transmission Service whenever the Transmission Provider determines that providing the requested service would, without such new facilities or upgrades, impair or degrade reliability to any existing firm services.

15.6 Other Transmission Service Schedules: Eligible Customers receiving transmission service under other agreements on file with the Commission may continue to receive transmission service under those agreements until such time as those agreements may be modified by the Commission.

Proposed Effective Date: 4/1/2019

Approved Effective Date:

15.7 Real Power Losses: Real Power Losses are associated with all transmission service. The Transmission Provider is not obligated to provide Real Power Losses. The Transmission Customer is responsible for replacing losses associated with all transmission service as calculated by the Transmission Provider. The applicable Real Power Losses are as follows:

For Service on the NSP Transmission System: 2.4%

For Service on the PSCo System:

| | <u>Demand</u> | <u>Energy</u> |
|--|---------------|---------------|
| Transmission System: | 2.20% | 1.70% |
| Distribution System – Primary Voltage: | 3.75% | 2.07% |

For Service on the SPS System:

| | <u>Demand</u> | <u>Energy</u> |
|--|-----------------|-------------------|
| Transmission System: | <u>2.738606</u> | <u>3.107161</u> % |
| | <u>3.203203</u> | <u>2.881556</u> % |
| Distribution System – Primary Voltage: | <u>8.846390</u> | <u>8.157751</u> % |
| | <u>6.327826</u> | <u>6.035731</u> % |

The loss factors for Direct Assignment Facilities shall be determined on a case by case basis.

28 Nature of Network Integration Transmission Service

- 28.1 Scope of Service:** Network Integration Transmission Service is a transmission service that allows Network Customers to efficiently and economically utilize their Network Resources (as well as other non-designated generation resources) to serve their Network Load located in the Transmission Provider's Control Area and any additional load that may be designated pursuant to Section 31.3 of the Tariff. The Network Customer taking Network Integration Transmission Service must obtain or provide Ancillary Services pursuant to Section 3.
- 28.2 Transmission Provider Responsibilities:** The Transmission Provider will plan, construct, operate and maintain its Transmission System in accordance with Good Utility Practice and its planning obligations in Attachment R in order to provide the Network Customer with Network Integration Transmission Service over the Transmission Provider's Transmission System. The Transmission Provider, on behalf of its Native Load Customers, shall be required to designate resources and loads in the same manner as any Network Customer under Part III of this Tariff. This information must be consistent with the information used by the Transmission Provider to calculate available transfer capability. The Transmission Provider shall include the Network Customer's Network Load in its Transmission System planning and shall, consistent with Good Utility Practice and Attachment R, endeavor to construct and place into service sufficient transfer capability to deliver the Network Customer's Network Resources to serve its Network Load on a basis comparable to the Transmission Provider's delivery of its own generating and purchased resources to its Native Load Customers.
- 28.3 Network Integration Transmission Service:** The Transmission Provider will provide firm transmission service over its Transmission System to the Network Customer for the delivery of capacity and energy from its designated Network Resources to service its Network Loads on a basis that is comparable to the Transmission Provider's use of the Transmission System to reliably serve its Native Load Customers.
- 28.4 Secondary Service:** The Network Customer may use the Transmission Provider's Transmission System to deliver energy to its Network Loads from resources that have not been designated as Network Resources. Such energy shall be transmitted, on an as-available basis, at no additional charge. Secondary service shall not require the filing of an Application for Network Integration Transmission Service under the Tariff. However, all other requirements of Part III of the Tariff (except for transmission rates) shall apply to secondary service. Deliveries from resources other than Network Resources will have a higher priority than any Non-Firm Point-To-Point Transmission Service under Part II of the Tariff.
- 28.5 Real Power Losses:** Real Power Losses are associated with all transmission service. The Transmission Provider is not obligated to provide Real Power

Losses. The Network Customer is responsible for replacing losses associated with all transmission service as calculated by the Transmission Provider. The applicable Real Power Losses are as follows:

For Service on the NSP Transmission System: 2.4%

For Service on the PSCo System:

| | <u>Demand</u> | <u>Energy</u> |
|--|---------------|---------------|
| Transmission System: | 2.20% | 1.70% |
| Distribution System – Primary Voltage: | 3.75% | 2.07% |

For Service on the SPS System:

| | <u>Demand</u> | <u>Energy</u> |
|--|------------------|-------------------|
| Transmission System: | <u>2.7386063</u> | <u>3.107161</u> % |
| | <u>3.2032032</u> | <u>3.881556</u> % |
| Distribution System – Primary Voltage: | <u>8.8463908</u> | <u>1.157751</u> % |
| | <u>6.3278266</u> | <u>0.035731</u> % |

The loss factors for Direct Assignment Facilities shall be determined on a case by case basis.

- 28.6 Restrictions on Use of Service:** The Network Customer shall not use Network Integration Transmission Service for (i) sales of capacity and energy to non-designated loads, or (ii) direct or indirect provision of transmission service by the Network Customer to third parties. All Network Customers taking Network Integration Transmission Service shall use Point-To-Point Transmission Service under Part II of the Tariff for any Third-Party Sale which requires use of the Transmission Provider's Transmission System. The Transmission Provider shall specify any appropriate charges and penalties and all related terms and conditions applicable in the event that a Network Customer uses Network Integration Transmission Service or secondary service pursuant to Section 28.4 to facilitate a wholesale sale that does not serve a Network Load.

Proposed Effective Date: 4/1/2019

Approved Effective Date:

15 Service Availability

- 15.1 General Conditions:** The Transmission Provider will provide Firm and Non-Firm Point-To-Point Transmission Service over, on or across its Transmission System to any Transmission Customer that has met the requirements of Section 16.
- 15.2 Determination of Available Transfer Capability:** A description of the Transmission Provider's specific methodology for assessing available transfer capability posted on the Transmission Provider's OASIS (Section 4) is contained in Attachment C of the Tariff. In the event sufficient transfer capability may not exist to accommodate a service request, the Transmission Provider will respond by performing a System Impact Study.
- 15.3 Initiating Service in the Absence of an Executed Service Agreement:** If the Transmission Provider and the Transmission Customer requesting Firm or Non-Firm Point-To-Point Transmission Service cannot agree on all the terms and conditions of the Point-To-Point Service Agreement, the Transmission Provider shall file with the Commission, within thirty (30) days after the date the Transmission Customer provides written notification directing the Transmission Provider to file, an unexecuted Point-To-Point Service Agreement containing terms and conditions deemed appropriate by the Transmission Provider for such requested Transmission Service. The Transmission Provider shall commence providing Transmission Service subject to the Transmission Customer agreeing to (i) compensate the Transmission Provider at whatever rate the Commission ultimately determines to be just and reasonable, and (ii) comply with the terms and conditions of the Tariff including posting appropriate security deposits in accordance with the terms of Section 17.3.
- 15.4 Obligation to Provide Transmission Service that Requires Expansion or Modification of the Transmission System, Redispatch or Conditional Curtailment:**
- (a) If the Transmission Provider determines that it cannot accommodate a Completed Application for Firm Point-To-Point Transmission Service because of insufficient capability on its Transmission System, the Transmission Provider will use due diligence to expand or modify its Transmission System to provide the requested Firm Transmission Service, consistent with its planning obligations in Attachment R, provided the Transmission Customer agrees to compensate the Transmission Provider for such costs pursuant to the terms of Section 27. The Transmission Provider will conform to Good Utility Practice and its planning obligations in Attachment R, in determining the need for new facilities and in the design and construction of such facilities. The obligation applies only to those facilities that the Transmission Provider has the right to expand or modify.
 - (b) If the Transmission Provider determines that it cannot accommodate a

Proposed Effective Date: 4/1/2019

Approved Effective Date:

Completed Application for Long-Term Firm Point-To-Point Transmission Service because of insufficient capability on its Transmission System, the Transmission Provider will use due diligence to provide redispatch from its own resources until (i) Network Upgrades are completed for the Transmission Customer, (ii) the Transmission Provider determines through a biennial reassessment that it can no longer reliably provide the redispatch, or (iii) the Transmission Customer terminates the service because of redispatch changes resulting from the reassessment. A Transmission Provider shall not unreasonably deny self-provided redispatch or redispatch arranged by the Transmission Customer from a third party resource.

- (c) If the Transmission Provider determines that it cannot accommodate a Completed Application for Long-Term Firm Point-To-Point Transmission Service because of insufficient capability on its Transmission System, the Transmission Provider will offer the Firm Transmission Service with the condition that the Transmission Provider may curtail the service prior to the curtailment of other Firm Transmission Service for a specified number of hours per year or during System Condition(s). If the Transmission Customer accepts the service, the Transmission Provider will use due diligence to provide the service until (i) Network Upgrades are completed for the Transmission Customer, (ii) the Transmission Provider determines through a biennial reassessment that it can no longer reliably provide such service, or (iii) the Transmission Customer terminates the service because the reassessment increased the number of hours per year of conditional curtailment or changed the System Conditions.

15.5 Deferral of Service: The Transmission Provider may defer providing service until it completes construction of new transmission facilities or upgrades needed to provide Firm Point-To-Point Transmission Service whenever the Transmission Provider determines that providing the requested service would, without such new facilities or upgrades, impair or degrade reliability to any existing firm services.

15.6 Other Transmission Service Schedules: Eligible Customers receiving transmission service under other agreements on file with the Commission may continue to receive transmission service under those agreements until such time as those agreements may be modified by the Commission.

Proposed Effective Date: 4/1/2019

Approved Effective Date:

15.7 Real Power Losses: Real Power Losses are associated with all transmission service. The Transmission Provider is not obligated to provide Real Power Losses. The Transmission Customer is responsible for replacing losses associated with all transmission service as calculated by the Transmission Provider. The applicable Real Power Losses are as follows:

For Service on the NSP Transmission System: 2.4%

For Service on the PSCo System:

| | <u>Demand</u> | <u>Energy</u> |
|--|---------------|---------------|
| Transmission System: | 2.20% | 1.70% |
| Distribution System – Primary Voltage: | 3.75% | 2.07% |

For Service on the SPS System:

| | <u>Demand</u> | <u>Energy</u> |
|--|---------------|---------------|
| Transmission System: | 2.738606% | 3.203203% |
| Distribution System – Primary Voltage: | 8.846390% | 6.327826% |

The loss factors for Direct Assignment Facilities shall be determined on a case by case basis.

Proposed Effective Date: 4/1/2019

Approved Effective Date:

28 Nature of Network Integration Transmission Service

- 28.1 Scope of Service:** Network Integration Transmission Service is a transmission service that allows Network Customers to efficiently and economically utilize their Network Resources (as well as other non-designated generation resources) to serve their Network Load located in the Transmission Provider's Control Area and any additional load that may be designated pursuant to Section 31.3 of the Tariff. The Network Customer taking Network Integration Transmission Service must obtain or provide Ancillary Services pursuant to Section 3.
- 28.2 Transmission Provider Responsibilities:** The Transmission Provider will plan, construct, operate and maintain its Transmission System in accordance with Good Utility Practice and its planning obligations in Attachment R in order to provide the Network Customer with Network Integration Transmission Service over the Transmission Provider's Transmission System. The Transmission Provider, on behalf of its Native Load Customers, shall be required to designate resources and loads in the same manner as any Network Customer under Part III of this Tariff. This information must be consistent with the information used by the Transmission Provider to calculate available transfer capability. The Transmission Provider shall include the Network Customer's Network Load in its Transmission System planning and shall, consistent with Good Utility Practice and Attachment R, endeavor to construct and place into service sufficient transfer capability to deliver the Network Customer's Network Resources to serve its Network Load on a basis comparable to the Transmission Provider's delivery of its own generating and purchased resources to its Native Load Customers.
- 28.3 Network Integration Transmission Service:** The Transmission Provider will provide firm transmission service over its Transmission System to the Network Customer for the delivery of capacity and energy from its designated Network Resources to service its Network Loads on a basis that is comparable to the Transmission Provider's use of the Transmission System to reliably serve its Native Load Customers.
- 28.4 Secondary Service:** The Network Customer may use the Transmission Provider's Transmission System to deliver energy to its Network Loads from resources that have not been designated as Network Resources. Such energy shall be transmitted, on an as-available basis, at no additional charge. Secondary service shall not require the filing of an Application for Network Integration Transmission Service under the Tariff. However, all other requirements of Part III of the Tariff (except for transmission rates) shall apply to secondary service. Deliveries from resources other than Network Resources will have a higher priority than any Non-Firm Point-To-Point Transmission Service under Part II of the Tariff.
- 28.5 Real Power Losses:** Real Power Losses are associated with all transmission service. The Transmission Provider is not obligated to provide Real Power

Proposed Effective Date: 4/1/2019

Approved Effective Date:

Losses. The Network Customer is responsible for replacing losses associated with all transmission service as calculated by the Transmission Provider. The applicable Real Power Losses are as follows:

For Service on the NSP Transmission System: 2.4%

For Service on the PSCo System:

| | <u>Demand</u> | <u>Energy</u> |
|--|---------------|---------------|
| Transmission System: | 2.20% | 1.70% |
| Distribution System – Primary Voltage: | 3.75% | 2.07% |

For Service on the SPS System:

| | <u>Demand</u> | <u>Energy</u> |
|--|---------------|---------------|
| Transmission System: | 2.738606% | 3.203203% |
| Distribution System – Primary Voltage: | 8.846390% | 6.327826% |

The loss factors for Direct Assignment Facilities shall be determined on a case by case basis.

- 28.6 Restrictions on Use of Service:** The Network Customer shall not use Network Integration Transmission Service for (i) sales of capacity and energy to non-designated loads, or (ii) direct or indirect provision of transmission service by the Network Customer to third parties. All Network Customers taking Network Integration Transmission Service shall use Point-To-Point Transmission Service under Part II of the Tariff for any Third-Party Sale which requires use of the Transmission Provider's Transmission System. The Transmission Provider shall specify any appropriate charges and penalties and all related terms and conditions applicable in the event that a Network Customer uses Network Integration Transmission Service or secondary service pursuant to Section 28.4 to facilitate a wholesale sale that does not serve a Network Load.

**UNITED STATES OF AMERICA
BEFORE THE
FEDERAL ENERGY REGULATORY COMMISSION**

Southwestern Public Service Company

)
)

Docket No. ER19-____-000

**DIRECT TESTIMONY
OF
WESLEY L. BERGER**

**ON BEHALF OF
SOUTHWESTERN PUBLIC SERVICE COMPANY**

JANUARY 30, 2019

DIRECT TESTIMONY OF WESLEY L. BERGER

TABLE OF CONTENTS

I. INTRODUCTION AND EXPERIENCE1

II. PURPOSE OF TESTIMONY3

III. OVERVIEW OF SPS’S FILING5

 A. Overview of SPS.....5

 B. SPS’s Filing and the Associated Testimony.....6

IV. CALCULATION OF PROPOSED LOSS FACTORS9

V. APPLICATION OF REAL POWER LOSS FACTORS TO CALCULATE
RATES APPLICABLE TO WHOLESALE SERVICES11

VI. COST IMPACT OF PROPOSED LOSS FACTORS14

VII. CONCLUSION16

**EXHIBITS TO
DIRECT TESTIMONY OF WESLEY L. BERGER**

| <u>Exhibit No.</u> | <u>Description</u> |
|---------------------------|---|
| SPS-0002 | Calculation of Proposed Loss Factors |
| SPS-0003 | Estimated Annual Cost Impact to Wholesale Customers |

Mr. Berger provides testimony in support of the filing by Southwestern Public Service Company (“SPS”) to revise SPS’s loss factors set forth in the Xcel Energy Open Access Transmission Tariff (“Xcel Energy Tariff”), the Southwest Power Pool, Inc. Open Access Transmission Tariff (“SPP Tariff”), and certain wholesale production requirements contracts. Mr. Berger provides an overview of SPS; introduces SPS’s other witness in this proceeding (Mr. Duane J. Ripperger); and explains and supports the changes to Sections 15.7 and 28.5 of the Xcel Energy Tariff proposed to be effective April 1, 2019. Mr. Berger also calculates the estimated cost impact of the revised loss factors on wholesale transmission service customers in the SPS rate zone (Zone 11) under the SPP Tariff and on customers currently receiving wholesale production service from SPS. Mr. Berger estimates that the overall impact to SPS wholesale customers of the proposed changes to the loss factors is a cost decrease of \$230,728 annually.

DIRECT TESTIMONY OF

WESLEY L. BERGER

I. INTRODUCTION AND EXPERIENCE

1 **Q. PLEASE STATE YOUR NAME AND BUSINESS ADDRESS.**

2 A. My name is Wesley L. Berger. My business address is 790 S. Buchanan St., Amarillo,
3 TX 79101.

4 **Q. BY WHOM ARE YOU EMPLOYED AND WHAT IS YOUR POSITION?**

5 A. I am employed by Southwestern Public Service Company (“SPS”), a New Mexico
6 corporation and wholly owned subsidiary of Xcel Energy Inc. (“Xcel Energy”), as
7 Manager, Rate Cases.

8 **Q. PLEASE DESCRIBE XCEL ENERGY.**

9 A. Xcel Energy is a public utility holding company with, among other subsidiaries, four
10 wholly owned, vertically integrated public utility operating company subsidiaries: SPS,
11 Northern States Power Company, a Minnesota corporation (“NSPM”), Northern States
12 Power Company, a Wisconsin corporation (“NSPW”), and Public Service Company of
13 Colorado (“PSCo”) (together, the “Xcel Energy Operating Companies”).

14 **Q. ON WHOSE BEHALF ARE YOU TESTIFYING?**

15 A. I am testifying on behalf of SPS.

16 **Q. PLEASE DESCRIBE YOUR EDUCATIONAL BACKGROUND.**

17 A. I graduated from New Mexico State University in 1993, receiving a Bachelor of Science
18 degree in Mathematics and a Bachelor of Arts degree in Economics. I received a Master

1 of Arts degree in Economics with specialization in public utility regulation from New
2 Mexico State University in 1995.

3 **Q. WHAT IS YOUR PROFESSIONAL EXPERIENCE?**

4 A. From June 1995 through April 1997, I worked as a Regulatory Compliance Coordinator
5 for SPS providing rate design and general regulatory compliance support. After SPS and
6 Public Service Company of Colorado merged to form New Century Energies in May
7 1997, I worked as a Pricing Analyst and later as a Pricing Specialist through July 2000. I
8 provided cost of service and rate design support for the retail and wholesale jurisdictions
9 of SPS. After the merger creating Xcel Energy in August 2000, I became a Contract
10 Administration Manager in the Wholesale Origination department, where I attended
11 wholesale market development meetings and regional tariff meetings, and I supported the
12 negotiation of wholesale power purchase and sale agreements. In August 2004, I became
13 an Originator, which meant that my duties focused more on negotiating purchase and sale
14 agreements. In 2005, I returned to Regulatory Administration to direct a retail rate case
15 filing in Texas. In May 2006, I assumed my current position as Manager, Rate Cases.

16 **Q. HAVE YOU ATTENDED OR TAKEN ANY SPECIAL COURSES OR SEMINARS**
17 **RELATING TO PUBLIC UTILITIES?**

18 A. Yes. In addition to my public utility regulation courses at New Mexico State University,
19 I have completed the advanced rate design course presented by the Edison Electric
20 Institute. I have also attended multiple seminars, including a Regulatory & Accounting
21 seminar presented by PricewaterhouseCoopers, a Utility Finance & Accounting seminar
22 presented by Financial Accounting Institute, and the Public Utility Conference sponsored
23 by New Mexico State University.

1 **Q. WHAT ARE YOUR DUTIES IN YOUR CURRENT POSITION?**

2 A. I oversee rate filings with the Federal Energy Regulatory Commission (“FERC” or
3 “Commission”) that impact SPS. I also provide input on SPS’s cost allocation and cost
4 of service issues for its retail jurisdictions in Texas and New Mexico. In addition, I
5 provide regulatory policy input on various issues impacting SPS.

6 **Q. HAVE YOU PREVIOUSLY SUBMITTED TESTIMONY BEFORE THE**
7 **FEDERAL ENERGY REGULATORY COMMISSION OR ANY OTHER**
8 **REGULATORY COMMISSION?**

9 A. Yes. I have filed written testimony with the Commission. Specifically, I have filed
10 testimony in Docket Nos. ER00-536, ER12-1682, ER16-1030, and ER19-675. I have
11 also testified before the Public Utility Commission of Texas (“PUCT”) and the New
12 Mexico Public Regulation Commission (“NMPRC”).

II. PURPOSE OF TESTIMONY

13 **Q. WHAT IS THE PURPOSE OF YOUR TESTIMONY IN THIS PROCEEDING?**

14 A. The purpose of my testimony is to support SPS’s proposal to update the real power
15 transmission and distribution line loss factors stated in Sections 15.7 and 28.5 of the Xcel
16 Energy Tariff applicable to SPS wholesale customers. In my testimony:

- I provide an overview of SPS;
- I provide an overview of the filing and introduce SPS's other witness, Mr. Duane J. Ripperger;
- I explain how the real power demand and energy loss factors proposed by SPS were derived from the 2016 Transmission and Distribution System Loss Evaluation Study (the "2016 Loss Study") discussed and supported by Mr. Ripperger and included as Exhibit No. SPS-0005;
- I explain how the demand and energy loss factors stated in the Xcel Energy Tariff are used in calculating bills to network transmission service and wholesale production customers; and
- I discuss the estimated cost impact of the proposed changes to the current loss factors on SPS's wholesale transmission and production customers.

Q. ARE YOU SPONSORING ANY EXHIBITS?

A. Yes. I am sponsoring the following exhibit, which is attached to my testimony:

| <u>Exhibit No.</u> | <u>Description</u> |
|--------------------|---|
| SPS-0002 | Calculation of Proposed Loss Factors |
| SPS-0003 | Estimated Annual Cost Impact to Wholesale Customers |

Submitted with this filing are the clean and marked tariff pages to Sections 15 and 28 of the Xcel Energy Tariff. I am sponsoring the proposed tariff revisions.

Q. WERE YOUR TESTIMONY AND EXHIBITS PREPARED BY YOU OR UNDER YOUR DIRECT SUPERVISION?

A. Yes.

III. OVERVIEW OF SPS'S FILING

A. Overview of SPS

1 Q. PLEASE DESCRIBE SPS.

2 A. Headquartered in Amarillo, Texas, SPS is a vertically integrated generation, transmission,
3 and distribution electric utility that serves approximately 390,000 retail and wholesale
4 customers in a 52,000 square-mile area of the Panhandle and the South Plains of Texas,
5 and eastern and southern New Mexico. SPS's service area extends approximately 400
6 miles from north to south and 200 miles from east to west. SPS also owns certain
7 transmission facilities in Kansas and Oklahoma. SPS provides regulated, cost-based
8 retail services subject to the jurisdiction of the PUCT and the NMPRC. SPS also
9 provides cost-based requirements wholesale service to cooperative and municipal power
10 customers, with rates determined under production formula rate templates that are part of
11 the individual wholesale power sales agreements.

12 SPS is a member of the SPP regional transmission organization ("RTO") and is
13 synchronously connected to the Eastern Interconnection grid. With limited exceptions,
14 all transmission services on the SPS system are provided under the SPP Tariff. SPS is
15 also connected to the Western Interconnection grid through three high-voltage direct-
16 current back-to-back converters. Although SPS operates adjacent to the Electric
17 Reliability Council of Texas ("ERCOT") grid, it has no direct interconnections with
18 ERCOT transmission owners.

19 Q. PLEASE DESCRIBE SPS'S SERVICE AREA.

20 A. The Texas retail jurisdiction is SPS's single largest regulatory jurisdiction. SPS also
21 serves retail customers in a large portion of eastern and southeastern New Mexico. SPS's

1 service territory in both Texas and New Mexico is primarily agricultural, with large areas
2 of oil and natural gas production. Additionally, wholesale power sales and transmission
3 services have historically been a significant business segment for SPS. SPS directly
4 serves six wholesale requirements power sales (production) customers, who in turn may
5 serve member customers, and provides wholesale Network Integration Transmission
6 Service (“NITS”) to various customers with loads on the SPS transmission system. The
7 SPS transmission system is included in Zone 11 of the SPP Tariff. In total, wholesale
8 production services currently account for approximately 22 percent of SPS’s total
9 production demand, and wholesale transmission services currently account for
10 approximately 36 percent of SPS’s total transmission network demand.

B. SPS’s Filing and the Associated Testimony

11 **Q. PLEASE SUMMARIZE THE CHANGES TO THE XCEL ENERGY TARIFF SPS**
12 **PROPOSES IN THIS FILING.**

13 A. SPS proposes to update its transmission and distribution real power loss factors stated in
14 Sections 15.7 and 28.5 of the Xcel Energy Tariff. Under the Xcel Energy Tariff and the
15 SPP Tariff, customers are responsible for replacing the real power losses associated with
16 transmission service. SPS has conducted a loss study to determine the amount of real
17 power losses on its system and, based on this analysis, has updated the real power loss
18 percentages for its transmission system and its distribution-primary voltage system.
19 Because transmission service over the SPS system is primarily provided under the SPP
20 Tariff, SPP will separately make a filing to update the SPS loss factors in Attachment M,
21 Appendix 1 of the SPP Tariff, to conform to the updated SPS loss factors in the Xcel

1 Energy Tariff, to be effective on the same effective date approved by the Commission in
2 this proceeding.

3 **Q. WHY IS SPS SEEKING TO UPDATE ITS TRANSMISSION AND**
4 **DISTRIBUTION PRIMARY REAL POWER LOSS FACTORS?**

5 A. The current transmission and distribution primary real power loss factors do not
6 accurately reflect the most recent study of the transmission and distribution losses SPS
7 experiences in providing service to its customers, including wholesale customers. SPS's
8 current transmission and distribution loss factors stated in the Xcel Energy Tariff were
9 accepted in Docket No. ER16-1030-000, using a loss study that included data from July
10 2012 through June 2013 (the "2013 Loss Study"). In 2017, SPS completed an updated
11 loss study based on data from January 2016 through December 2016 (the "2016 Loss
12 Study") and calculated new loss factors. The new loss factors were then filed with the
13 PUCT and the NMPRC. The updated loss factors were accepted by the NMPRC in its
14 final order in NMPRC Case No. 17-00255-UT, issued on September 5, 2018, and
15 accepted by the PUCT in its final order in PUCT Docket No. 47527, issued on December
16 10, 2018. SPS proposes to use the 2016 Loss Study as the basis for the updated real
17 power loss factors stated in the Xcel Energy Tariff applicable to SPS to ensure
18 comparability and consistency among all three jurisdictions (New Mexico, Texas, and
19 FERC).

20 **Q. WHY DOES SPS NEED TO FILE DISTRIBUTION LOSS FACTORS WITH THE**
21 **COMMISSION?**

22 A. SPS has transmission and wholesale production service customers who have delivery
23 points at primary distribution voltage. These real power demand and energy loss factors

need to be updated so that they are consistent with the primary distribution loss factors applied to SPS's retail customers.

Q. HOW DO THE PROPOSED LOSS FACTORS COMPARE TO THE CURRENT LINE LOSS FACTORS?

A. The proposed transmission loss factor for demand is slightly lower than the current transmission demand loss factor, while the proposed transmission loss factor for energy is slightly higher than the current transmission energy loss factor. SPS's proposed primary distribution loss factors are higher than the current distribution loss factors. A comparison of the current and proposed loss factors is shown in Table 1:

Table 1

| | Demand Loss Factors | | Energy Loss Factors | |
|-----------------------------------|----------------------------|-----------------|----------------------------|-----------------|
| | <u>Current</u> | <u>Proposed</u> | <u>Current</u> | <u>Proposed</u> |
| Transmission | 3.107161% | 2.738606% | 2.881556% | 3.203203% |
| Distribution - Primary Voltage | 8.157751% | 8.846390% | 6.035731% | 6.327826% |

Q. WHAT IS THE PROPOSED EFFECTIVE DATE FOR THE REVISED LOSS FACTORS?

A. SPS is requesting an effective date of April 1, 2019 for the revisions to Sections 15.7 and 28.5 of the Xcel Energy Tariff to reflect new demand and energy loss factors.

Q. PLEASE INTRODUCE THE OTHER WITNESS PROVIDING TESTIMONY IN SUPPORT OF SPS'S PROPOSED LOSS FACTORS.

A. SPS's filing is also supported by the Direct Testimony of Mr. Duane J. Ripperger, Manager, Regional Transmission Initiatives for XES, Exhibit Nos. SPS-0004 and SPS-0005 (the "Ripperger Testimony").

1 **Q. WHAT DOES MR. RIPPERGER ADDRESS IN HIS TESTIMONY?**

2 A. Mr. Ripperger discusses how a system loss study is performed, and the methodology used
3 by SPS for the 2016 Loss Study. Mr. Ripperger also discusses certain refinements to the
4 2016 Loss Study as compared to the 2013 Loss Study.

5 **Q. HAVE YOU QUANTIFIED THE IMPACT OF THE CHANGE PROPOSED IN**
6 **THE REVISED TEMPLATE ON SPS'S WHOLESALE DISTRIBUTION**
7 **SERVICE CUSTOMERS?**

8 A. Yes. In Exhibit No. SPS-0003, I present the annual customer impact of the new loss
9 factors. In Section V of my testimony, I discuss my calculations of the annual customer
10 impact presented in Exhibit No. SPS-0003.

IV. CALCULATION OF PROPOSED LOSS FACTORS

11 **Q. WHAT IS THE BASIS FOR THE REAL POWER LOSS FACTORS SPS**
12 **PROPOSES IN THIS PROCEEDING?**

13 A. SPS is using the 2016 Loss Study, its most recent system loss study, as presented by Mr.
14 Ripperger. As I mentioned, the loss factors resulting from this study have been accepted
15 by the PUCT and the NMPRC.

16 **Q. WHAT MODIFICATIONS DID YOU MAKE TO THE 2016 LOSS STUDY**
17 **RESULTS TO DERIVE THE PROPOSED WHOLESALE LOSS FACTORS?**

18 A. The primary distribution loss factors proposed by SPS come directly from Appendices O
19 and P to the 2016 Loss Study (attached as Exhibit No. SPS-0005 to Mr. Ripperger's
20 testimony).

21 I also used the loss factors from the 2016 Loss Study as the basis for SPS's
22 proposed transmission loss factors, but modified the loss factors to tailor them to

1 wholesale service. Specifically, I began with the Energy and Demand loss factors shown
2 in Appendices O and P to the 2016 Loss Study, and made one modification: I combined
3 the two transmission level loss factors described in the 2016 Loss Study into the
4 composite transmission loss factor for the Xcel Energy Tariff and the SPP Tariff.

5 **Q. PLEASE DESCRIBE YOUR MODIFICATION IN ORDER TO CREATE A**
6 **COMPOSITE CALCULATION.**

7 A. Both the Xcel Energy Tariff and the SPP Tariff employ a single loss factor for all
8 transmission voltage facilities. The 2016 Loss Study, however, contains two
9 transmission loss factors. Specifically, the 2016 Loss Study calculates a loss factor for
10 transmission facilities with a voltage of 115 kV or higher and a separate loss factor for
11 transmission facilities at a voltage level of 69 kV. Therefore, it was necessary for me to
12 calculate a composite transmission loss factor applicable to all transmission voltages to
13 be set out in the Xcel Energy Tariff and SPP Tariff. The current SPS transmission loss
14 factors accepted in Docket No. ER16-1030-000 were also calculated as composite
15 factors.

16 The modification I made to the Appendix O and P loss factor calculations was to
17 sum the losses for the two transmission service levels (levels 2 and 3) into a single total
18 transmission losses number. The total is shown on line 21 in the kW Loss by Level
19 column (column E) on page 1 and on line 21 in the kWh Loss by Level column (column
20 E) on page 2 of Exhibit No. SPS-0002. The remaining mathematical calculations on line
21 21 on both pages are identical to the original loss factor calculations done by Mr.
22 Ripperger and accepted by the PUCT and NMPRC.

1 **Q. IS IT NECESSARY TO MAKE A MODIFICATION TO THE 2016 LOSS STUDY**
2 **TO REMOVE GENERATOR STEP-UP TRANSFORMER LOSSES?**

3 A. No. As discussed in the 2016 Loss Study, SPS metered its generators at the high side of
4 the generator step-up transformers during the time period of the 2016 Loss Study.

5 **Q. WHAT ARE SPS' PROPOSED LOSS FACTORS AFTER THESE**
6 **CALCULATIONS?**

7 A. SPS proposes a transmission demand loss factor of 2.738606%, as shown on page 1, line
8 21 (column C) of Exhibit No. SPS-0002, and a transmission energy loss factor of
9 3.203203%, as shown on page 2, line 21 (column C) of Exhibit No. SPS-0002. SPS
10 proposes a distribution demand loss factor of 8.846390%, as shown on page 1, line 25
11 (column C) of Exhibit No. SPS-0002, and a distribution energy loss factor of 6.327826%,
12 as shown on page 2, line 25 (column C) of Exhibit No. SPS-0002. Table 1, on page 8
13 above, compares the currently effective wholesale transmission and distribution loss
14 factors with the proposed factors.

15 **V. APPLICATION OF REAL POWER LOSS FACTORS TO CALCULATE**
16 **RATES APPLICABLE TO WHOLESALE SERVICES**

17 **Q. WHAT CUSTOMERS ARE AFFECTED BY SPS'S PROPOSED CHANGE TO**
18 **ITS LOSS FACTORS?**

19 A. The network transmission service customers that purchase transmission service under the
20 SPP Tariff for loads on the SPS system (SPP Zone 11), and production service customers
21 who purchase power from SPS under wholesale requirements power sale agreements, are
22 both affected by SPS's proposal to update its real power loss values. The demand loss
23 change will affect the calculation of billing demands for both network and production
24 customers, and the energy loss change will affect charges to production customers.

Q. HOW DOES SPS APPLY THE LOSS FACTORS TO DETERMINE THE CHARGES APPLICABLE TO NETWORK TRANSMISSION CUSTOMERS?

A. The loss factors developed by Mr. Ripperger in the 2016 Loss Study are what are termed injection loss factors. However, these loss factors are typically applied to metered usage values of network transmission customers in calculating monthly network demands. Therefore, it is necessary to use what are termed delivery loss factors. Mr. Ripperger explains how the delivery loss factors in the 2016 Loss Study are calculated.

As shown on page 1, line 21 (column B) of Exhibit No. SPS-0002, the transmission demand delivery loss factor to be applied to metered usage is 1.028157. The metered usage is multiplied by the delivery loss factor to determine the monthly network demand. For example, if a customer has a metered demand of 600,000 kW, the monthly network demand for billing purposes is $600,000 * 1.028157 = 616,894$ kW. Similar delivery loss factors are shown in Exhibit No. SPS-0002 for the transmission energy, distribution demand, and distribution energy loss factors.

Alternatively, a delivery loss factor can be expressed as a percentage as is done in Attachment M, Appendix 1 to the SPP Tariff. This is calculated by the following equation: $\text{delivery loss factor} = [(1/(1 - \text{injection loss factor})) - 1] * 100$. Using the transmission demand injection loss factor in Exhibit No. SPS-0002 on page 1, line 21 (column C) of 2.738606%, we can calculate the delivery loss factor SPP will show in Attachment M as $[(1/(1 - .02738606)) - 1] * 100 = 2.815717\%$. The metered usage is added to the product of the metered usage and the delivery loss factor expressed as a percentage to determine monthly network demand. For example, if a customer has a

metered demand of 600,000 kW, the monthly network demand for billing purposes is
 $600,000 + (600,000 * 2.815717\%) = 616,894 \text{ kW}.$

Note that although the arithmetic calculations are performed differently, both methodologies result in the same billing demand.

Q. HOW DOES SPS APPLY THE LOSS FACTORS TO DETERMINE THE CHANGES APPLICABLE TO WHOLESALE PRODUCTION REQUIREMENTS SERVICE CUSTOMERS?

A. SPS applies the delivery loss factors calculated using the first method described above to the wholesale customers' metered monthly usage. For example, if a wholesale customer has a monthly demand of 100,000 kW and monthly energy usage of 50,000,000 kWh, SPS would calculate the monthly billing determinants using the delivery loss factors shown in line 21, Column B of pages 1 and 2 of SPS Exhibit 2. Specifically, billing demand equals $100,000 * 1.028157 = 102,816 \text{ kW}$ and billing energy equals $50,000,000 * 1.033092 = 51,654,600 \text{ kWh}.$

Q. WILL THE PROPOSED LOSS FACTOR CHANGES AFFECT ENERGY LOSSES BILLED TO NETWORK CUSTOMERS UNDER THE SPP TARIFF?

A. No. Under Attachment M to the SPP OATT, energy losses are determined by the SPP regional system dispatch and included in the locational marginal prices charged in the SPP Integrated Marketplace to market participants, including network transmission customers on the SPS system. The SPS Tariff loss factors do not affect these calculations.

1 **Q. IS IT NECESSARY TO UPDATE ANY SPS WHOLESALE PRODUCTION**
2 **SERVICE AGREEMENTS TO REFLECT THE REVISED LOSS FACTORS?**

3 A. No. The SPS production service agreements refer to the loss values as stated in the
4 applicable Tariff. As such, while the revised loss values will affect the calculation of
5 bills for SPS's production customers, Commission acceptance of the revised real power
6 loss factors will not require revisions to the underlying agreements.

VI. COST IMPACT OF THE PROPOSED LOSS FACTORS

7 **Q. HAVE YOU ESTIMATED THE COST IMPACT TO WHOLESALE**
8 **CUSTOMERS OF THE PROPOSED TARIFF CHANGES?**

9 A. Yes. I estimated the cost impact to individual network transmission service customers
10 and wholesale requirements customers on the SPS system by recalculating SPS bills to
11 wholesale customers for calendar year 2018 using the proposed loss factors in place of
12 the currently effective loss factors.

13 **Q. WHAT IS THE ESTIMATED COST IMPACT OF THE PROPOSED TARIFF**
14 **CHANGES TO SPS'S NETWORK TRANSMISSION SERVICE AND**
15 **WHOLESALE REQUIREMENTS CUSTOMERS?**

16 A. The overall cost impact to these customers of the changes to the current loss factors is
17 estimated to be a decrease of \$230,728 annually or approximately -0.072%. Exhibit No.
18 SPS-0003 shows the estimated transmission bill impact, production bill impact and net
19 impact for each wholesale customer. As noted, this estimate reflects billing data for the
20 twelve months from January 2018 through December 2018 and compares the amounts
21 billed using the current loss factors to the amounts that would have been billed had the
22 proposed loss factors been in effect.

Exhibit No. SPS-0003 shows that charges to network transmission service customers would be reduced as a result of the lower demand loss factor by approximately \$419,000 per year, while charges to wholesale production customers would increase by approximately \$188,000 per year. With one exception, all of SPS's wholesale customers are expected to see a slight net reduction. Central Valley Electric Cooperative is estimated to see a slight increase (\$6,833) because Central Valley Electric Cooperative has a relatively high load factor and the energy loss factor is increasing.

Q. HAS SPS CALCULATED THE COST IMPACT TO POINT-TO-POINT TRANSMISSION SERVICE CUSTOMERS?

A. No. Point-to-point service is provided only by SPP under the SPP Tariff. SPS does not have the information necessary to calculate the impact of the slight reduction of the transmission demand loss factor on SPP point-to-point transmission service customers. Further, similar to network transmission customers, point-to-point customers' energy charges will not be impacted by this change to the SPS transmission energy loss factor because energy losses are determined by the SPP regional system dispatch and included in the locational marginal prices charged in the SPP Integrated Marketplace.

Q. DID SPS SHARE THE PROPOSED LOSS FACTOR CHANGES AND THE ESTIMATED COST IMPACT WITH ITS WHOLESALE CUSTOMERS PRIOR TO SUBMITTING THIS FILING?

A. Yes. SPS provided the proposed loss factors and the estimated cost impact analysis to each of its wholesale customers on January 18, 2019, and offered to hold pre-filing conference calls with each of the customers to explain the calculations and why SPS was

1 making this filing. SPS answered a few questions, but none of the customers requested a
2 pre-filing meeting.

VII. CONCLUSION

3 **Q. PLEASE SUMMARIZE YOUR RECOMMENDATIONS.**

4 A. I recommend that the Commission approve SPS's proposed revisions to Sections 15.7
5 and 28.5 of the Xcel Energy Tariff to incorporate the new SPS loss factors discussed in
6 my testimony, effective on April 1, 2019. The Tariff changes are just and reasonable
7 because they incorporate information from SPS's most recent system loss study, and that
8 same loss study has recently been approved by the NMPRC and PUCT for retail
9 ratemaking purposes.

10 **Q. DOES THIS CONCLUDE YOUR PRE-FILED DIRECT TESTIMONY?**

11 A. Yes.


UNITED STATES OF AMERICA
BEFORE THE
FEDERAL ENERGY REGULATORY COMMISSION

Southwestern Public Service Company)
)

Docket No. ER19-____-000

AFFIDAVIT

Wesley L. Berger, being duly sworn, deposes and states: that the Direct Testimony of Wesley L. Berger was prepared by me or under my direct supervision, and that the statements contained therein are true and correct to the best of my knowledge and belief.



Wesley L. Berger
Wesley L. Berger

Subscribed and sworn before me this 29 day of January 2019.

Donna M. Anderson
[Name]

Notary Public

My commission expires: [date] 6/17/2020

Line No.

**SOUTHWESTERN PUBLIC SERVICE COMPANY
DEMAND LOSS FACTOR CALCULATION
12 MONTHS ENDING DECEMBER 2016**

Loss Factor Calculation

Total Generation Inputs = 6,003,000 Kw
System Peak Hr. 6,003,000 Kw

| | (A) | (B) | (C) | (D) | (E) | (F) | (G) |
|--|-----------------------------------|--|--------------------|----------------------------|---------------------|----------------------------|--------------------------------|
| | Loss Factor to Gross up to Gen | Loss factor to gross up 1 level 1/(1-loss %) | % loss by level | KW Flow into each level | KW Loss by Level | KW Demand by loss level | Loss Check Loss fac X sales |
| 12 Sales at the Generator 13 @ Generation | 1.000000 | 1.000000 | 0.000000% | 6,003,000 | 0 | 0 | 0 |
| 15 Sales @ 115, 230 & 345 KV 16 Level 2 | 1.023667 | 1.023667 | 2.311973% | 6,003,000 | 138,788 | 2,244,415 | 2,297,533 |
| 18 Sales @ 69 KV 19 Level 3 | 1.030961 | 1.007126 | 0.707520% | 3,619,798 | 25,611 | 1,090,485 | 1,124,247 |
| 21 Transmission Losses 22 Levels 2 and 3 combined | 1.028157 | 1.028157 | 2.738606% | 6,003,000 | 164,399 | 3,334,899 | |
| 25 Sales @ Primary (33kv - 2.4kv) 26 Level 4 | 1.131015 | 1.097049 | 8.846390% | 2,503,702 | 221,487 | 436,754 | 493,975 |
| 28 Secondary Sales @ the Transf. 29 Level 5 | 1.161769 | 1.027192 | 2.647180% | 1,845,461 | 48,853 | 640,746 | 744,399 |
| 31 Sales served by secondary lines 32 Level 6 | 1.166539 | 1.004106 | 0.408905% | 1,155,862 | 4,726 | 1,114,734 | 1,300,380 |
| 34 Total | | 1.078990 | 7.320754% | 5,966,598 | 439,465 | 5,527,133 | 5,960,535 |
| 36 Composite Factor Levels 5 and 6 | 1.164833 | 1.029901 | 2.903288% | 1,845,461 | 53,579 | 1,755,480 | |

Line No.

**SOUTHWESTERN PUBLIC SERVICE COMPANY
ENERGY LOSS FACTOR CALCULATION
12 MONTHS ENDING DECEMBER 2016**

Loss Factor Calculation

Total Generation Inputs = 31,758,276,076 kWh

| | (A) | (B) | (C) | (D) | (E) | (F) | (G) |
|--|-----------------------------------|--|--------------------|-----------------------------|-----------------------------|----------------------------|--------------------------------|
| | Loss Factor to Gross up to Gen | Loss factor to gross up 1 level 1/(1-loss %) | % loss by level | KWH Flow into each level | KWH Loss by Level | KWH Sales by loss level | Loss Check Loss fac X sales |
| Sales at the Generator @ Generation | 1.000000 | 1.000000 | 0.000000% | 31,758,276,076 | 0 | 8,295,082 | 8,295,082 |
| Sales @ 115, 230 & 345 KV Level 2 | 1.029633 | 1.029633 | 2.877997% | 31,749,980,994 | 913,763,470 | 13,821,244,766 | 14,230,809,712 |
| Sales @ 69 KV Level 3 | 1.035919 | 1.006105 | 0.606835% | 17,014,972,758 | 103,252,764 | 4,942,501,116 | 5,120,030,814 |
| Transmission Losses Levels 2 and 3 combined | 1.033092 | 1.033092 | 3.203203% | 31,749,980,994 | 1,017,016,234 | 18,763,745,882 | |
| Sales @ Primary (33kv - 2.4kv) Level 4 | 1.105898 | 1.067553 | 6.327826% | 11,969,218,878 | 757,391,388 | 3,704,794,414 | 4,097,124,733 |
| Secondary Sales @ the Transf. Level 5 | 1.125047 | 1.017315 | 1.702074% | 7,507,033,076 | 127,775,281 | 3,205,486,688 | 3,606,323,182 |
| Sales served by secondary lines Level 6 | 1.128389 | 1.002971 | 0.296182% | 4,173,771,108 | 12,361,948 | 4,161,409,160 | 4,695,688,321 |
| Total | | 1.064152 | 6.028491% | 31,758,276,076 | 1,914,544,850 | 29,843,731,226 | 31,758,271,843 |
| | | | | | Check using rounded factors | | -4,233 |
| Composite Factors 5 & 6 to Gen. | 1.126935 | 1.019023 | 1.866746% | 7,507,033,076 | 140,137,228 | 7,366,895,848 | |

Loss factor calculation for gross up to a target level equals the product of loss factors for each level up through the target level.

Page 1

| Line No. | Cost Impact Estimate Summary (Using Calendar Year 2018 data) | | | | | | Golden Spread | | Total | |
|-----------------------|--|---------------|--------------|---------------|--------------|---------------|----------------|---------------|----------------|--|
| | Central Valley | Farmers | Lea County | Roosevelt | WTMPA | (Tri-County) | Golden Spread* | | | |
| 1 | <u>Production Demand</u> | | | | | | | | | |
| 2 | Current | \$ 7,411,636 | \$ 3,870,853 | \$ 13,216,957 | \$ 1,516,124 | \$ 49,016,199 | \$ 5,483,249 | \$ - | \$ 80,515,020 | |
| 3 | Proposed | 7,370,042 | 3,852,157 | 13,150,440 | 1,507,465 | 48,859,356 | 5,462,471 | - | 80,201,932 | |
| 4 | Change | \$ (41,594) | \$ (18,697) | \$ (66,517) | \$ (8,660) | \$ (156,843) | \$ (20,778) | \$ - | \$ (313,088) | |
| 5 | | | | | | | | | | |
| 6 | <u>Production - Energy & Fuel</u> | | | | | | | | | |
| 7 | Current | \$ 15,289,781 | \$ 4,635,246 | \$ 21,730,993 | \$ 2,245,149 | \$ 74,689,469 | \$ 9,880,499 | \$ - | \$ 128,471,138 | |
| 8 | Proposed | 15,365,731 | 4,664,705 | 21,837,680 | 2,259,011 | 74,932,072 | 9,913,327 | - | 128,972,525 | |
| 9 | Change | \$ 75,950 | \$ 29,459 | \$ 106,687 | \$ 13,862 | \$ 242,603 | \$ 32,827 | \$ - | \$ 501,387 | |
| 10 | | | | | | | | | | |
| 11 | Total Production | \$ 34,356 | \$ 10,762 | \$ 40,169 | \$ 5,202 | \$ 85,760 | \$ 12,049 | \$ - | \$ 188,299 | |
| 12 | | | | | | | | | | |
| 13 | <u>Transmission</u> | | | | | | | | | |
| 14 | Current | \$ 7,263,150 | \$ 3,772,194 | \$ 12,045,284 | \$ 1,541,995 | \$ 32,393,247 | \$ 3,652,788 | \$ 52,124,076 | \$ 112,792,734 | |
| 15 | Proposed | 7,235,627 | 3,757,899 | 11,999,638 | 1,536,152 | 32,276,237 | 3,638,946 | 51,929,209 | 112,373,708 | |
| 16 | Change | \$ (27,524) | \$ (14,295) | \$ (45,645) | \$ (5,843) | \$ (117,010) | \$ (13,842) | \$ (194,868) | \$ (419,027) | |
| 17 | | | | | | | | | | |
| 18 | Total Transmission | \$ (27,524) | \$ (14,295) | \$ (45,645) | \$ (5,843) | \$ (117,010) | \$ (13,842) | \$ (194,868) | \$ (419,027) | |
| 19 | | | | | | | | | | |
| 20 | Total Change | \$ 6,833 | \$ (3,533) | \$ (5,476) | \$ (641) | \$ (31,250) | \$ (1,793) | \$ (194,868) | \$ (230,728) | |
| Total % Change | | | | | | | | | -0.072% | |

* Column represents Golden Spread loads where no wholesale power requirements are supplied by SPS. These loads incur only network transmission service and local distribution facilities charges.

**UNITED STATES OF AMERICA
BEFORE THE
FEDERAL ENERGY REGULATORY COMMISSION**

Southwestern Public Service Company

)
)

Docket No. ER19-____-000

**DIRECT TESTIMONY
OF
DUANE J. RIPPERGER**

**ON BEHALF OF
SOUTHWESTERN PUBLIC SERVICE COMPANY**

JANUARY 30, 2019

DIRECT TESTIMONY OF DUANE J. RIPPERGER

TABLE OF CONTENTS

I. INTRODUCTION AND EXPERIENCE1

II. PURPOSE OF TESTIMONY3

III. SPS’S 2016 LOSS STUDY3

IV. CALCULATION OF LOSS FACTORS18

V. CONCLUSION18

**EXHIBITS TO
DIRECT TESTIMONY OF DUANE J. RIPPERGER**

| <u>Exhibit No.</u> | <u>Description</u> |
|---------------------------|--|
| SPS-0005 | SPS's 2016 Transmission and Distribution System Loss Evaluation Study |

)

Summary of the Direct Testimony of Duane J. Ripperger

Mr. Ripperger discusses SPS’s 2016 Transmission and Distribution System Loss Evaluation Study (the “2016 Loss Study”) conducted for the period from January 1, 2016 through December 31, 2016 (“Study Period”) and completed in July 2017. The 2016 Loss Study is the basis for the updated wholesale loss factors proposed by SPS in this proceeding.

DIRECT TESTIMONY OF

DUANE J. RIPPERGER

I. INTRODUCTION AND EXPERIENCE

Q. PLEASE STATE YOUR NAME AND BUSINESS ADDRESS.

A. My name is Duane J. Ripperger. My business address is 790 S. Buchanan Street, Amarillo, Texas 79101.

Q. ON WHOSE BEHALF ARE YOU TESTIFYING IN THIS PROCEEDING?

A. I am filing testimony on behalf of Southwestern Public Service Company, a New Mexico corporation (“SPS”) and wholly-owned electric utility subsidiary of Xcel Energy Inc. (“Xcel Energy”).

Q. BY WHOM ARE YOU EMPLOYED AND IN WHAT POSITION?

A. I am employed by Xcel Energy Services Inc. (“XES”) as Manager, Regional Transmission Initiatives.

Q. PLEASE BRIEFLY DESCRIBE YOUR DUTIES AS MANAGER, REGIONAL TRANSMISSION INITIATIVES.

A. I am responsible for supporting the implementation of strategic transmission priorities. These priorities include the planning for large electric transmission projects, support of transmission-related regulatory activities, and the implementation of evolving technologies on the transmission grid.

Q. PLEASE DESCRIBE YOUR EDUCATIONAL BACKGROUND.

A. I earned a bachelor’s degree in Electrical Engineering from Iowa State University and a master’s degree in Engineering Management from the University of Colorado.

1 **Q. PLEASE DESCRIBE YOUR PROFESSIONAL EXPERIENCE.**

2 A. I have 34 years of experience in the electric utility industry obtained through various
3 engineering and management assignments. I have been employed by SPS or XES since
4 June 1984. I have held positions in distribution engineering, electrical operations,
5 transmission and distribution planning, asset management, and most currently in
6 transmission project planning and public policy.

7 **Q. DO YOU HOLD A PROFESSIONAL LICENSE?**

8 A. Yes. I am currently licensed as a Professional Engineer in the states of New Mexico,
9 Texas, and Colorado.

10 **Q. ARE YOU A MEMBER OF ANY PROFESSIONAL ORGANIZATIONS?**

11 A. Yes. I am a senior member of the Institute of Electrical and Electronics Engineers.

12 **Q. HAVE YOU TESTIFIED BEFORE ANY REGULATORY AUTHORITIES?**

13 A. Yes. I filed testimony with the Public Utility Commission of Texas (“PUCT”) on behalf
14 of SPS regarding: transmission capital additions in Docket No. 46877, SPS’s 2017
15 proceeding to adjust its Transmission Cost Recovery Factor; and the 2016 System Loss
16 Study and the 2017 Radial line study in Docket No. 47527, SPS’s 2017 Texas base rate
17 case. I have also filed testimony with the New Mexico Public Regulatory Commission
18 (“NMPRC”) on behalf of SPS regarding the 2016 System Loss Study and the 2017
19 Radial line study in Case No. 17-00255-UT, SPS’s 2017 New Mexico base rate case.
20 Additionally, I filed affidavit testimony with the Federal Energy Regulatory Commission
21 (“FERC”) regarding a filing by the Southwest Power Pool, Inc. (“SPP”) in FERC Docket
22 No. ER18-2358-000.

II. PURPOSE OF TESTIMONY

Q. WHAT IS THE SCOPE OF YOUR DIRECT TESTIMONY?

A. I will discuss the results of SPS's 2016 Transmission and Distribution System Loss Evaluation Study (the "2016 Loss Study") conducted for the period from January 1, 2016 through December 31, 2016 ("Study Period") and completed in July 2017. The 2016 Loss Study is the basis for the updated wholesale loss factors proposed by SPS in this proceeding. Exhibit No. SPS-0005 is a copy of the 2016 Loss Study, which consists of a narrative explanation of the study results and numerous detailed work papers.

Q. WAS YOUR DIRECT TESTIMONY PREPARED BY YOU OR UNDER YOUR DIRECT SUPERVISION?

A. Yes.

III. SPS'S 2016 LOSS STUDY

Q. WHAT IS A LOSS STUDY?

A. A loss study is an engineering evaluation of the transmission and distribution ("T&D") losses incurred on an electrical system for a specified period of time. The goal of such a study is to determine where the losses have occurred, that is, on what T&D elements (transmission lines and transformers, distribution lines and transformers, and Generator Step Up transformers) the losses occur and to then properly allocate the losses to each individual type of element of the system. The losses determined in an engineering evaluation should reasonably match losses derived from accounting records comparing energy deliveries and energy supplies into the T&D system. After the losses have been determined, loss factors representing the T&D losses on specific voltage levels of the system are developed for rate making purposes.

1 **Q. WHY DID SPS PREPARE THE 2016 LOSS STUDY?**

2 A. The previous SPS loss study had been completed utilizing data from July 1, 2012 through
3 June 30, 2013 (“2013 Loss Study”), and loss factors based on this study were
4 incorporated in the Xcel Energy Open Access Transmission Tariff (“Xcel Energy Tariff”)
5 in Docket No. ER16-1030-000 effective May 1, 2016. The SPS system has experienced
6 several significant changes since 2013, including implementation of the SPP Integrated
7 Marketplace, installation of new 345 kV transmission facilities by SPS, and increased
8 wind and solar generation. SPS concluded it would be appropriate to perform a new Loss
9 Study. Additionally, SPS committed to perform a new loss study that would cover a
10 study period ending no later than December 31, 2016 in both NMPRC Case No. 14-
11 00348-UT and in the Non-Unanimous Stipulation in PUCT Docket No. 42004.

12 **Q. HOW DOES THE 2016 LOSS STUDY COMPARE TO THE 2013 LOSS STUDY?**

13 A. During the Study Period, energy supplies (*i.e.*, “Resources”) and energy deliveries
14 (“Sales”)¹ were lower in absolute terms than in the 2013 Loss Study. As a percentage of
15 SPS’s total Resources, however, actual losses in the 2016 Loss Study were slightly higher
16 than in the 2013 Loss Study. The losses calculated in the 2016 Loss Study are 1,948,829
17 megawatt hours (“MWh”), which is only 1.79% more than the actual losses of 1,914,545
18 MWh, *i.e.*, calculated losses equal 101.79% of actual losses.

¹ The sum of energy SPS sold to customers and delivered to interconnections with other utilities at the points the energy left the SPS transmission and distribution system, collectively “Sales.” “Sales” thus include deliveries of power produced by suppliers other than SPS to transmission-only customers.

The following Table DJR-1 compares data and results from the 2013 and 2016 Loss Studies.

Table DJR-1
Comparison of 2013 and 2016 Loss Study Data²

| Subject | 2013 Loss Study | 2016 Loss Study |
|---|------------------------|------------------------|
| Total Resources | 32,964,320 MWh | 31,758,276 MWh |
| Total Sales | 31,142,401 MWh | 29,843,731 MWh |
| Actual Losses | 1,821,919 MWh | 1,914,545 MWh |
| Overall Loss Percentage | 5.53% | 6.03% |
| Calculated Losses | 1,836,997 MWh | 1,948,829 MWh |
| Calculated Losses as % of Actual Losses | 100.83% | 101.79% |
| Undeterminable Losses | -15,079 MWh | -34,284 MWh |
| Peak Load | 6,079 MW | 6,003 MW |

Q. DID YOU PARTICIPATE IN THE PREPARATION OF THE 2016 LOSS STUDY?

A. Yes. I participated in the preparation of the 2016 Loss Study and oversaw its completion. Several SPS and XES staff provided the necessary data updates required for the 2016 Loss Study.

²

Data presented are rounded, which may result in calculations not totaling properly. Loss study spreadsheets frequently display rounded data, but use the unrounded data in the calculations.

1 **Q. HAS SPS SUBMITTED THE 2016 LOSS STUDY TO ITS STATE REGULATORY**
2 **AGENCIES?**

3 A. Yes. As discussed in the Direct Testimony of Mr. Wesley L. Berger, SPS submitted the
4 2016 Loss Study to the PUCT and the NMPRC, and these commissions accepted the loss
5 factors derived from the 2016 Loss Study in orders issued in 2018. SPS proposes to
6 revise the wholesale real power loss percentages set out in the Xcel Energy Tariff to be
7 consistent with the 2016 Loss Study and the loss factors used to calculate retail rates to
8 provide consistency across SPS's three jurisdictions (FERC, Texas and New Mexico).

9 **Q. WHAT ARE ELECTRICAL "LINE LOSSES"?**

10 A. As electrical current flows from a generation source to customers' loads, it passes
11 through wires and transformers that have an inherent electrical resistance to the flow of
12 electricity. This electrical resistance causes some of the energy flowing in the system to
13 be converted to heat and is, thereby, "lost." Total losses are the difference between the
14 electrical energy put onto the T&D system and the electrical energy that was either sold
15 to customers or delivered to exit points on the utility's T&D system. For example, if a
16 utility generates 1,000 MWh and experiences overall losses of 6%, it will deliver only
17 940 of the 1,000 MWh generated. The 60 MWh difference between the amounts
18 generated and delivered to customers are the T&D losses. Such losses are an inherent
19 characteristic of a properly functioning electrical system and are unavoidable.

20 **Q. IN YOUR EXAMPLE, WOULD EACH TYPE OF CUSTOMER CAUSE THE**
21 **UTILITY TO LOSE 6% OF THE ENERGY GENERATED?**

22 A. No, not generally, and not on SPS's system. In order for electricity to reach a typical
23 residential customer, it must flow from the generator through generation unit main

1 transformers, then through bulk transmission lines and related autotransformers, then
2 through transformers at a distribution substation, then through primary distribution lines,
3 then through a pole top transformer, then through a secondary distribution line from the
4 pole top transformer to a pole behind the residence, and finally through a service line
5 from the pole to the meter on the side of the house. At each step, losses are incurred to
6 serve the residential customer.

7 By contrast, to reach a wholesale or industrial customer taking service at 230
8 kilovolts (“kV”), the electricity has to flow through only the generation unit main
9 transformer, some bulk transmission lines, and a 345/230 kV autotransformer. None of
10 the losses incurred at distribution substations, primary distribution lines, distribution
11 transformers, secondary lines, and service lines are experienced in serving an industrial
12 customer taking service at transmission voltage. Thus, in general, customers taking
13 service at higher voltages cause fewer losses to be incurred than do customers taking
14 service at lower voltages.

15 On the SPS system, customers take service at multiple voltages ranging from 230
16 kV to 120 volts. For example, on the SPS system, a wholesale customer may take service
17 at transmission voltages from 230, 115, or 69 kV. Wholesale customers may also take
18 service at various distribution voltages from 34 to 2.4 kV. A wholesale customer taking
19 service at a transmission voltage should only be required to pay for the losses incurred as
20 the power moves from the generators through the transmission system (or through the
21 distribution system for wholesale loads served at distribution voltage).

1 **Q. DO UTILITIES IN GENERAL, AND SPS IN PARTICULAR, HAVE METERS**
2 **INSTALLED AT EACH STEP IN THE ELECTRICAL FLOW DESCRIBED**
3 **ABOVE SO THAT LOSSES AT EACH STEP CAN BE MEASURED?**

4 A. No. In general and on SPS's system, meters exist at generators, at locations where SPS's
5 transmission lines interconnect with transmission lines of other utilities, and at points of
6 delivery to customers. Thus, SPS can use meters to measure the total electrical energy
7 placed on its T&D system, whether from generators located within or outside its system,
8 and the total energy Sales. The difference between total Resources and total Sales is the
9 actual loss incurred.

10 Given that meters do not exist at each step at which losses are incurred, a loss
11 evaluation study is performed to quantify, through engineering analysis and calculations,
12 the power and energy losses that occurred at the different loss levels on the T&D system
13 during the study period. The calculated loss values for each loss level are used with the
14 undeterminable losses (discussed later) to assign the proper portion of actual losses to
15 Loss Level 2 through Loss Level 6 discussed below.

16 **Q. WHAT CIRCUIT ELEMENTS OF SPS'S ELECTRICAL SYSTEM WERE**
17 **ANALYZED IN THE 2016 LOSS STUDY?**

18 A. The circuit elements analyzed were: (1) the transmission lines, (2) the transmission
19 autotransformers, (3) the distribution substation transformers, (4) the distribution primary
20 feeder circuits, (5) the distribution line transformers, and (6) the distribution secondary
21 lines and service lines.

Q. YOU STATED THAT THE 2016 LOSS STUDY CALCULATES LOSSES AT SEVERAL LEVELS. PLEASE IDENTIFY THE LOSS LEVELS AND THE CIRCUIT ELEMENTS CONTAINED IN EACH LOSS LEVEL.

A. Loss Level 1 is the generator and generator step-up transformer and no losses are calculated at this level because the Backbone Transmission is considered the delivery point of the electricity from the generator. Loss Levels 2 through 6 and the circuit elements in each loss level are identified below.

Loss Level 2 – Backbone Transmission

- Bulk transmission lines (345 kV, 230 kV, and 115 kV); and
- Autotransformers (345/230 kV and 230/115 kV).

Loss Level 3 – Sub-Transmission

- 69 kV transmission lines; and
- Autotransformers (115/69 kV).

Loss Level 4 – Distribution Primary

- Transformers located at distribution substations; and
- Primary Distribution Lines (“feeders”) (34.5 kV – 2.4 kV).

Loss Level 5 – Distribution Secondary Transformers

- Transformers located on primary distribution lines.

Loss Level 6 – Distribution Secondary and Service Lines

- Secondary distribution lines running from Level 5 transformers to other poles or service points and service lines running to the customers’ premises.

The losses at Levels 5 and 6 are combined to create a “Distribution Secondary” classification.

1 **Q. YOU NOTED THAT THE 2016 LOSS STUDY COVERED A 12-MONTH**
2 **PERIOD. IS IT APPROPRIATE TO PERFORM A LOSS EVALUATION STUDY**
3 **OVER A PERIOD SHORTER THAN 12 MONTHS?**

4 A. In general, no. The loss evaluation study must correlate energy generated and purchased
5 for customers with Sales to those customers. SPS bills some customers every normal
6 business day of each month. Customers are usually billed once per month; however, the
7 billing period start and end dates do not always respect the calendar month boundary.
8 The billing period may cover part of a previous calendar month or may only cover part of
9 the current month, with no overlap into a previous month. When all Sales are totaled and
10 compared to that billing month's generation and power purchases, there will be a
11 difference, which may be a positive or a negative number. This difference does not
12 necessarily reflect the actual losses incurred on the T&D system during this billing
13 month. This precludes doing a loss evaluation study for a short period of time.

14 **Q. HOW DOES A LONGER TIME PERIOD AID IN PREPARING A LOSS STUDY?**

15 A. By using a longer time period, such as one year, the effects of the different customer
16 billing cycles are minimized. I would note that the previous 2009 and 2013 loss studies
17 used to update the SPS loss factors included in the Xcel Energy Tariff in 2012 (Docket
18 No. ER12-1682-000) and 2016 (Docket No. ER16-1030-000) also used historic one year
19 study periods.

1 **Q. DID THE 2016 LOSS STUDY CONSIDER LOSSES OF CUSTOMERS**
2 **OPERATING THEIR OWN TRANSMISSION AND/OR DISTRIBUTION**
3 **SYSTEMS?**

4 A. No. SPS evaluated losses up to the customers' meters but not beyond, because SPS does
5 not incur the losses that occur beyond the customers' meters.

6 **Q. PLEASE DESCRIBE THE METHODOLOGY USED TO DETERMINE THE**
7 **TRANSMISSION SYSTEM LOSSES.**

8 A. For peak demand losses, the 2016 summer peak was modeled with powerflow studies and
9 the losses per circuit element were tabulated and grouped by voltage category. Any loss
10 contribution due to no-load losses was also calculated. For energy losses, the Study
11 Period was divided into four time segments consisting of whole months, and average
12 loads were computed for each time segment. Powerflow studies determined the losses
13 for each circuit element for the average load during each of the four segments. The
14 average loss per circuit element was determined and multiplied by the hours in the load
15 segment to determine the energy losses. The months included in each load segment are
16 identified in Appendix A of Exhibit No. SPS-0005.

17 **Q. WHAT ARE "NO-LOAD LOSSES"?**

18 A. Whenever a transformer is energized, a relatively small loss occurs even during hours
19 when no load current is passing through the transformer. These losses are referred to as
20 "no-load losses." Since transformers are typically energized every hour of the year, no-
21 load losses must be calculated for each transformer in order to accurately estimate losses
22 incurred at each transformer location.

**Q. WHERE ARE TRANSMISSION LEVEL LOSSES DISCUSSED IN THE 2016
LOSS STUDY?**

A. The circuit elements (i.e., lines and transformers) of the transmission system are identified in Section 1.1 of Exhibit No. SPS-0005, and the process for calculating transmission level losses for each type of circuit element is discussed in Sections 4 through 5.

Appendix M of Exhibit No. SPS-0005 presents a summary of losses for each type of circuit element at both transmission and distribution levels.

Energy losses by level are stated in Appendix O of Exhibit No. SPS-0005 in the column labeled “kWh Loss by Level” and Levels 2 and 3 are the transmission voltage levels.

Losses for individual transmission circuit elements are tabulated in Appendices E, F, and G of Exhibit No. SPS-0005.

The summary results of the powerflow studies are in Appendix N of Exhibit No. SPS-0005.

**Q. PLEASE DESCRIBE THE METHODOLOGY USED TO DETERMINE THE
DISTRIBUTION SYSTEM LOSSES.**

A. Peak demand and energy losses were calculated for the elements in the distribution system and accumulated based on a typical representation of SPS’s distribution system. Losses were calculated for the distribution substation transformer, the primary feeders, the secondary system (including distribution transformers), and the service lines to the customers. The annual energy loss was determined by calculating annual energy loss per

1 distribution element and summing up the total energy loss. Similarly, demand losses
2 were determined on each component of the distribution system and aggregated.

3 **Q. WHERE ARE DISTRIBUTION LEVEL LOSSES DISCUSSED IN THE 2016**
4 **LOSS STUDY?**

5 A. The circuit elements (i.e., lines and transformers) of the distribution system are identified
6 in Section 1.1 of Exhibit No. SPS-0005, and the process for calculating losses for each
7 type of circuit element is discussed in Sections 6 through 10.

8 Appendix M of Exhibit No. SPS-0005 presents a summary of losses for each type
9 of circuit element at both transmission and distribution levels.

10 Energy losses by level are stated in Appendix O of Exhibit No. SPS-0005 in the
11 column labeled “kWh Loss by Level” and Levels 4, 5, and 6 are the distribution voltage
12 levels.

13 Losses for individual distribution circuit elements are tabulated in Appendices I,
14 J, K, and L of Exhibit No. SPS-0005.

15 **Q. WHAT ARE THE RESULTS OF THE 2016 LOSS STUDY?**

16 A. Total actual losses for the Study Period were 1,914,545 MWh, and the losses determined
17 through the 2016 Loss Study’s engineering analysis were 1,948,829 MWh. The
18 undetermined losses are the difference, -34,284 MWh, which is -1.79% of the actual
19 losses. See Appendix M of Exhibit No. SPS-0005, Line No. 44 for total actual losses,
20 Line No. 42 for total determined losses, and Line No. 43 for undeterminable losses.

1 **Q. CAN YOU DETERMINE THE REASON FOR THE -34,284 MWH DIFFERENCE**
2 **BETWEEN THE LOSSES CALCULATED IN THE 2016 LOSS STUDY AND THE**
3 **ACTUAL LOSSES INCURRED?**

4 A. No. Undeterminable losses are equal to the Total Actual Losses minus the Total
5 Determined Losses (calculated losses). The -34,284 MWh of undeterminable losses
6 cannot be assigned to any particular cause. A loss evaluation study is an engineering
7 analysis of line losses attributable to average electrical loadings of particular components
8 of the T&D system. There is always a difference between the actual and calculated
9 losses, which can be positive or negative, between the results of a computer analysis
10 using average loads and the actual line losses experienced. The small 1.79 percent
11 difference between the actual losses and calculated losses indicates the 2016 Loss Study
12 reasonably represents the losses on the SPS T&D systems.

13 **Q. ARE UNDETERMINABLE LOSSES TAKEN INTO ACCOUNT IN**
14 **DETERMINING LOSS FACTORS?**

15 A. Yes. The loss factors must be based on actual losses to ensure correct fuel factors. Thus,
16 the undeterminable losses, whether positive or negative, are assigned to the circuit
17 elements for which losses have been calculated in the study based on the ratio of each
18 circuit element's calculated loss to the total of all calculated losses. The results of this
19 assignment process appear in Appendix M of Exhibit No. SPS-0005 in the "Adjusted
20 Energy MWH" and "Factored KWH" columns. The totals for those columns tie to the
21 Total Losses on Line No. 66 of Appendix A of Exhibit No. SPS-0005.

Q. DID ANY OF THE DATA OR METHODS USED TO CALCULATE LOSSES IN THE APPENDICES OF THE 2016 LOSS STUDY CHANGE FROM THE DATA USED IN THE 2013 LOSS STUDY?

A. Yes, there are always changes in data from one study to the next. Changing the Study Period changes much of the data, e.g. generation amounts, power purchases, peak load, powerflow case results, Sales data, miles of T&D lines, customer meter counts, etc. The updated data are reflected in the appendices of the 2016 Loss Study.

The SPS T&D systems modelled in the 2016 Loss Study have experienced four major changes since the 2013 Loss Study.


- First, there was significantly more wind and solar generation connected to SPS's transmission system in 2016 than in 2013. The effect of this additional generation injecting power into the transmission system at different locations than in the past has a significant effect on losses.
- Second, a significant amount of wind and solar generation has been connected to the SPS distribution system since the 2013 Loss Study. This wind and solar generation delivers energy directly to the distribution system in contrast to the historical norm of nearly all the energy flowing through the transmission system into the SPS distribution system.
- Third, three new 345 kV lines that significantly strengthen the SPS connection to the rest of the SPP grid were placed in service in 2014. The installation of these transmission lines has allowed SPS and other wholesale load serving entities ("LSEs") on the SPS system to purchase significant amounts of low-cost energy from the SPP Integrated Marketplace and import that power into the SPS system. These imports could significantly change the flows on the SPS transmission system and therefore affect losses.
- Fourth, there have been changing patterns of power delivery on SPS's system. Recently, SPS has been transmitting more wholesale customer-procured power than in the past.

Q. DID ANY OF THE METHODOLOGIES USED TO CALCULATE LOSSES IN THE APPENDICES OF THE 2016 LOSS STUDY CHANGE FROM THE METHODOLOGIES USED IN THE 2013 LOSS STUDY?

A. Yes. While the majority of the fundamental methodologies did not change, the increase in generation connected to the SPS distribution system from 2013 to the present Study Period has required a change in study methodology to accurately account for losses.

In previous studies, nearly all the generation was connected to the transmission system and the generated energy flowed through the transmission system to the distribution system. This energy flow scenario is shown graphically in Figure DJR-1:


Figure DJR-1
Historical SPS Energy Flow



In Figure DJR-1, 100 MWh of energy flows through the transmission system to the distribution system, resulting in transmission losses in proportion to the 100 MWh flow of energy.

In the 2016 Loss Study, a significant amount of generation had been connected to the SPS distribution system, delivering energy directly to the distribution system. In this simplistic example, the energy delivered directly to the distribution system does not cause losses in the transmission system, resulting in lower transmission losses than in the scenario shown in Figure DJR-1. This new energy flow scenario is shown graphically in Figure DJR-2 (next page):

Figure DJR-2
2016 Loss Study Energy Flows



In Figure DJR-2, only 95 MWh of energy flows through the transmission system to the distribution system, while 5 MWh of energy is generated and delivered directly to the distribution system. This scenario results in transmission losses from only 95 MWh of energy flow instead of 100 MWh as in the first scenario.

In the 2016 Loss Study, the significant increase in generation connected directly to the distribution system necessitated a change in the study methodology to account for this change in the energy flows. The Loss Study now includes data in Appendix B of Exhibit No. SPS-0005 that summarizes the energy and demand delivered directly to the distribution system. Updates were made to the spreadsheets in the Excel workbook to reflect this change in flows so that the resulting loss calculations are accurate. The methodology used in the 2016 Loss Study shows the generation connected to the distribution system flowing into the distribution system at the low voltage side of the distribution substation transformer.

1 **Q. WAS THERE ANY CHANGE IN THE TREATMENT OF WHOLESALE**
2 **TRANSACTIONS WITH ENTITIES OUTSIDE OF SPS'S SERVICE AREA?**

3 A. No. The same net metering approach was used in the 2016 Loss Study as was used in the
4 2013 Loss Study.

5 **IV. CALCULATION OF LOSS FACTORS**

6 **Q. WHAT ARE "LOSS FACTORS"?**

7 A. A loss factor is simply a number, which when multiplied by a given amount of Sales,
8 yields the amount of energy that must be generated to produce the Sales amount. If, for
9 example, losses at a specific service level are 10%, then 100 MWh have to be generated
10 to yield 90 MWh of Sales. Thus, the loss factor at that level is 1.1111 (90 MWh sold x
11 1.1111 loss factor = 100 MWh generated).

12 **Q. DOES THE 2016 LOSS STUDY CONTAIN CALCULATED LOSS FACTORS?**

13 A. Yes. The Energy Loss Factor and the Demand Loss Factor for each SPS loss level are
14 shown in Appendices O and P of Exhibit No. SPS-0005. Loss factor derivation is
15 discussed in Section 12.0 of Exhibit No. SPS-0005. These loss factors were calculated
16 using the same methodology as in previous loss studies.

17 In his Direct Testimony, Mr. Berger discusses the necessary adjustments to the
18 results of the 2016 Loss Study he made to arrive at the real power loss factors (stated on a
19 loss percentage basis) SPS is proposing in this filing to include in the Xcel Energy Tariff.

20 **V. CONCLUSION**

21 **Q. DOES THIS CONCLUDE YOUR PRE-FILED DIRECT TESTIMONY?**

22 A. Yes.

**UNITED STATES OF AMERICA
BEFORE THE
FEDERAL ENERGY REGULATORY COMMISSION**


Southwestern Public Service Company


)
)

Docket No. ER19-____-000


AFFIDAVIT

Duane J. Ripperger, being duly sworn, deposes and states: that the Direct Testimony of Duane J. Ripperger was prepared by me or under my direct supervision, and that the statements contained therein are true and correct to the best of my knowledge and belief.




Duane J. Ripperger

Subscribed and sworn before me this 29th day of January 2019.


Donna M. Anderson
Notary Public
My commission expires: 6/17/2020

Southwestern Public Service Company

2016 Loss Evaluation Study

January – December 2016

**SPS Transmission Planning
Xcel Energy Services, Inc.**

July 2017

Southwestern Public Service Company
Loss Evaluation Study for 2016 Study Period

TABLE OF CONTENTS

| | |
|---|----|
| 1.0 OVERVIEW | 1 |
| 2.0 GENERATION STEP-UP TRANSFORMER LOSSES..... | 8 |
| 3.0 SYSTEM LOAD ANALYSIS | 8 |
| 4.0 TRANSMISSION LINE LOSSES | 10 |
| 5.0 AUTOTRANSFORMER DEMAND LOSSES | 12 |
| 6.0 DISTRIBUTION SUBSTATION TRANSFORMER LOSSES..... | 14 |
| 7.0 LOAD FACTOR DERIVATION | 17 |
| 8.0 DISTRIBUTION PRIMARY FEEDER LOSSES | 17 |
| 9.0 DISTRIBUTION LINE TRANSFORMER LOSSES..... | 19 |
| 10.0 DISTRIBUTION SECONDARY LOSSES..... | 21 |
| 11.0 SUMMARY OF TRANSMISSION LOSS STUDY..... | 23 |
| 12.0 LOSS FACTOR DERIVATION..... | 24 |

Southwestern Public Service Company
Loss Evaluation Study for 2016 Study Period

1.0 Overview

This report discusses an evaluation of transmission and distribution system losses for the 12 month period January – December 2016 (2016 Study Period). This evaluation was designed to be as introspective as technically possible and provide a significant level of confidence in determining the electrical losses on the Southwestern Public Service (SPS) transmission and distribution systems. This evaluation determines actual losses and then uses engineering principles to calculate both demand and energy losses at specific voltage levels.

SPS operates an electrical system consisting of 345 kV, 230 kV, 115 kV and 69 kV transmission lines and a distribution system with lines operating at 33 kV to 2.4 kV. The system spans a large 52,000 square mile area from the Oklahoma panhandle through the Texas panhandle and into eastern and southeastern New Mexico. SPS has generation on both 230 kV and 115 kV busses throughout this area. Since 2009 SPS and other power producers have installed significant wind and solar generation within the SPS boundary. Most of this generation is connected at transmission voltage levels and some at distribution primary voltage levels. The scope of this study was to determine the demand and energy losses for the following components:

Transmission System Components:

- Generation Unit Main Transformers
- Transmission Lines
- Autotransformers

Distribution System Components:

- Distribution Substation Transformers
- Distribution System, including Primary, Secondary and Service Lines
- Transformers

Southwestern Public Service Company
Loss Evaluation Study for 2016 Study Period

The losses related to these elements of the power system are frequently seen in accounting reports as "Unaccounted For Energy." The purpose of this study is to determine actual losses and then specifically assign losses by the components identified above for the 2016 Study Year.

The losses of customer-operated transformers, transmission systems and distribution systems are not considered in this study. Any losses occurring in auxiliary busses at power plants are not considered in this study.¹ Also, losses related to the generator step-up transformers are not included since net generation is recorded at the high voltage side of these transformers.

The analysis of losses requires consideration of both demand, or power, losses and energy losses. The demand losses are typically measured in megawatts (MW), kilowatts (kW), or watts. The energy losses are measured in megawatt-hours (MWh), kilowatt-hours (kWh), or watt-hours (Wh). Certain components of the energy losses are present even though there is very low electrical load passing through the device. An example of this is the magnetizing current and related losses of a transformer. After the transformer is energized, these losses will occur. Power flow through the transformer will increase the losses, but even in the absence of any power flow, the transformer will experience "no-load losses" simply because it is energized.

To provide a basis for the calculations in this study, data was gathered for the transmission and distribution systems. This data and associated calculations are shown in the Appendices of Attachment DJR-RD-2. All references in this document to a specific appendix are found in Attachment DJR-RD-2. Each Appendix corresponds to a section of the total loss calculation or provides data used in other appendices. Actual counts exist for the devices and miles of electric lines that cause losses at the transmission level. The calculation of losses at the transmission level involves very little engineering judgment. Actual counts of devices and line data exist for much of the

Southwestern Public Service Company Loss Evaluation Study for 2016 Study Period

distribution system as well. In some cases, however, data does not exist for the distribution system and engineering approximations or judgments must be and were made to determine losses at specific voltage levels. These approximations are noted in the discussion.

1.1 Loss Levels

The energy losses for each physical category (lines, transformers, etc.) are grouped by the six Loss Levels. These Loss Levels, which are shown in Appendix H, are:

- Loss Level 1 - Generation
- Loss Level 2 – Backbone Transmission
- Loss Level 3 – Sub - Transmission
- Loss Level 4 - Primary Distribution
- Loss Level 5 - Secondary Distribution Transformers
- Loss Level 6 - Secondary Distribution Lines

Losses are not calculated at Level 1. The other levels are composed of the following physical loss categories:

- Loss Level 2 – Backbone Transmission
 - 345 kV, 230 kV and 115 kV Transmission Lines
 - 345/230 kV, 230/115 kV Autotransformers
- Loss Level 3 – Sub - Transmission
 - 69 kV Lines
 - 115/69 kV Autotransformers
- Loss Level 4 - Primary Distribution
 - Distribution Substation Transformers
 - Distribution Primary Lines (33 kV to 2.4 kV lines)
- Loss Level 5 - Secondary Distribution Transformer
 - Distribution Line Transformers
- Loss Level 6 - Secondary Distribution Lines

¹ Auxiliary busses are distribution busses which provide internal power plant distribution service for internal power

Southwestern Public Service Company
Loss Evaluation Study for 2016 Study Period

Distribution Secondary and Service Lines

Transmission losses are those at Levels 2 and 3. Losses attributable to distribution facilities are those calculated for levels 4, 5 and 6. In setting loss factors for rate classes, the losses calculated at levels 5 and 6 are combined and a composite loss factor is determined.

The results of the 2016 Loss Evaluation Study are shown in Appendix M and the rate class loss factors derived from the study are in Appendix Q.

1.2 Determination of Actual Losses

Appendix A contains the determination of actual losses measured in MWh for the total transmission and distribution system based on 2016 Study Period operating data. The general definition of losses is the difference between the total resources and total deliveries. Specifically, the Total Resources, shown in Appendix A, are:

Net Generation (line 6) – metered output of SPS's generating plants

Net Metered SPP Interchange and WECC HVDC Interchange (lines 7 & 8) – metered physical flows at all interchange tie points with the Southwest Power Pool (SPP) and the Western Electric Coordinating Council (WECC). Wherever SPS's transmission system interconnects with transmission systems of other utilities in the SPP or WECC, meters exist and data are captured to determine the energy either flowing into or out of SPS's system. The net flows into or out of the SPS system at these boundaries account for any purchases made from, or sales made to, entities outside the SPS boundary. In addition, if third parties enter into a sale and purchase transaction and SPS's transmission system is used to deliver power, the net metered flows at SPS's boundaries will reflect the

plant equipment (i.e. water wells, internal plant equipment, plant controls, pumps, etc.).

Southwestern Public Service Company
Loss Evaluation Study for 2016 Study Period

use of the transmission system by recording the inflow and the corresponding outflow. This process of calculating the net flows into or out of SPS's system is referred to as "net metering."

Firm Purchased Power

BEA, LPP (line 11) – SPS purchases energy pursuant to the contracts with Borger Energy Associates and Lea Power Partners, LLC.

LPL Generation (line 12) – SPS has a full requirements sales contract with West Texas Municipal Power Agency (WTMPA), an entity established by the cities of Lubbock, Tulia, Brownfield, and Floydada. SPS also contracts with the City of Lubbock to purchase the output of three Lubbock generating plants that operate only when requested by SPS. This generation is located within the Lubbock Power & Light (LPL) network and no SPS loss is attributable to this power. Line 12 is the total Lubbock generation during the 2016 Study Period.

Others (line 13) – SPS purchases relatively small amounts of energy from a number of other entities located within its system boundary pursuant to firm contracts. The collective purchases under these contracts are reported on this line.

Renewable Energy Purchases (lines 14-21) – these are energy purchases from renewable sources that have firm network transmission service.

Other Generation inside the SPS Boundary

Golden Spread Electric Cooperative (GSEC) owns the Mustang Plant near Denver City, Texas, and Antelope and Elk Stations located near Abernathy, Texas. GSEC has also purchased the output of the Panhandle Wind Ranch. Lines 23-27 show the GSEC resource outputs

Southwestern Public Service Company
Loss Evaluation Study for 2016 Study Period

for the 2016 Study Period. Since the GSEC generation is within SPS's boundary, its generation must be included in total area resources to prevent an under-statement of resources due to the net metering process described above.

Lea County Electric Cooperative (LCEC) Generation

This is renewable and fossil generation output that is connected to LCEC's 115 kV transmission line from SPS Hobbs Plant to SPS Denver City Substation. This is shown on lines 29-31.

Farmer's Electric Cooperative (FEC) Generation

This renewable generation is connected to FEC's transmission system and the value reported is the excess generation above FEC's load that flows back onto the SPS transmission system. This is shown on lines 33-34.

Export Renewables

The output of these renewable generators is scheduled or purchased by other companies outside of the SPS boundary. These energy values are shown on lines 36-42,

SPS Non-Firm Purchased Power

Lines 44-50 represent the output of various generators that are being purchased by SPS and flow onto the SPS transmission system.

Market Renewables

Lines 52-56 represent generators located within SPS's boundary sending power over SPS's transmission lines into the SPP Energy Market. Like GSEC's generation, this generation must be included in SPS's total

Southwestern Public Service Company Loss Evaluation Study for 2016 Study Period

resources to prevent an under-statement of resources due to the net metering process described above.

The sum of these resources is the “Total Resources” (line 58) available on SPS’s system for serving customer load within its system boundary.

Total Deliveries (line 64) consists of all retail sales, all full requirements wholesale sales within the system boundary, and all deliveries to Golden Spread load points within the system boundary.

Total Losses (line 66) are the actual losses experienced during the 2016 Study Period. Total Losses are calculated by subtracting the Total Deliveries on line 64 from the Total Resources on line 58. This value of Total Losses is the value that will be used to generate the loss factors by voltage level.

SPS’s Total System Loss percentage during the 2016 Study Period is shown on line 67. This value is derived by dividing Total Losses (line 66) by Total Resources (line 58).

The “Net Output to Lines by Load Segment” data (lines 77-89) are simply the sums of monthly values for “Net Output to Lines” (line 74) for the months contained in each segment. The determination of segments is discussed in Section 3.1 and the Net Output to Lines by Load Segment data are used in determining transmission line losses in Section 4.3.

1.3 Distribution Connected Generation Sources

Appendix B contains a list of distribution-connected resources that deliver power directly onto the SPS distribution system at the primary level. These resource values

Southwestern Public Service Company Loss Evaluation Study for 2016 Study Period

are used in the calculation of losses on the distribution system, specifically in Appendix J – Distribution Primary Loss.

2.0 Generation Step-Up Transformer Losses

Losses attributable to these transformers are included in station power and are not part of this study.

3.0 System Load Analysis

To determine the transmission line and autotransformer losses, it is necessary to perform powerflow studies at different system load levels throughout the year. The system loading levels must be determined before these studies can be done. For the period under study, the system loads are obtained from the operations center. The load represented in these studies is a composite of SPS retail load, GSEC and other wholesale loads within the SPS system boundary.

Any other sale or purchase of energy that either started in or was received into the SPS boundary, and including any through transactions from the east to west or west to east across the SPS system between the eastern and western grids are included when the powerflow models are developed to capture any transmission losses due to those transactions.

SPS's daily minimum and maximum load are summed to produce a daily average load. Then the corresponding values for tie line flows are obtained and summed for the same hour. This produces a daily minimum and daily maximum load to be analyzed. The results of this procedure are shown in Appendix D – System Load Data 6, Daily Maximum/Minimum Loads graph.

3.1 Segment Derivation

Southwestern Public Service Company Loss Evaluation Study for 2016 Study Period

The daily maximum and minimum loads are still too detailed for the powerflow analysis, since there are 366 minimum and 366 maximum values for each load (2016 is a leap year). The next step is to produce a daily average load graph. The Average Value Analysis graph is shown in Appendix D – System Load Data 6. The average load is graphed for the study period. Then an average study value is fit to the graph. The goal of this fit is to minimize the sum of the errors between the average load values to be used in the study and the actual daily average load. Once this has been determined, the year can be broken into load segments which will be modeled in the powerflow program using the values of average load determined here. The load segments will typically be a spring period, summer period, and a fall/winter period. It is required that the segment boundary fall on whole calendar months because the all the data is based on a calendar month. For the 2016 Study Period, the best fit to model the loads for the 12 months was a four segment model. The sum of the errors in the 2016 Study Period is 0.28%. See Appendix D - System Load Data, line 8. The segment values used in this analysis were:

| | |
|---------------------------------|---------|
| Segment 1: January - February | 3380 MW |
| Segment 2: March - May | 3323 MW |
| Segment 3: June - August | 4432 MW |
| Segment 4: September - December | 3387 MW |

The average loads per segment, number of days in each segment and other values used in the analysis are shown on the chart in Appendix D - System Load Data.

3.2 Powerflow Loss Calculations

Once the segment loads have been determined, the powerflow analysis can be performed. The average segment load values determined above are used for the loads in the powerflow studies. Powerflow cases are run on each of the load segments under study. The generation patterns are varied between the segments to better represent

Southwestern Public Service Company Loss Evaluation Study for 2016 Study Period

the mix of generators actually on-line at that time of the year. There is also a peak powerflow case prepared to analyze the system losses at the hour of the system peak.

The powerflow program used to perform studies is Power Technologies Inc.'s PSS/E program. Once the powerflows have been completed, the losses are summarized for the SPS system. The loss values for each transmission element and voltage class are tabulated for the peak hour case and for each segment period. The summary tabulations are shown in Appendix N. These losses represent the loss for that element for the segment load used. These values are then used to determine the transmission line and transformer losses.

Excluded from the loss tabulation are transmission systems that are not owned by SPS, but reside inside SPS's boundary and modelled in SPS's powerflow program. These systems are Lea County Electric, Lubbock Power and Light, and Tri-County Electric Cooperative.

4.0 Transmission Line Losses

The losses on transmission lines consist of several parts. Demand and energy losses on the transmission system consist of corona losses, insulator losses, and losses due to power flow through the transmission lines. These losses are tabulated by transmission voltage level in Appendix E.

4.1 Transmission Line Corona and Insulator Losses

Transmission systems have losses due to corona and insulator leakage. Corona loss occurs when the voltage gradient near the conductor surface exceeds the breakdown strength of the surrounding air. Insulator leakage is the small current that flows across the surface of the insulators attached to the electric conductor. The Transmission Line Reference Book published by Electric Power Research Institute contains information on determining the representative losses associated with corona and insulator leakage.

Southwestern Public Service Company Loss Evaluation Study for 2016 Study Period

Using that reference, losses per mile for each transmission voltage level were determined and entered in the “kW Loss/mile” column. Transmission line mileage was taken from FERC Form 1 data. The demand loss due to corona and insulator leakage (Appendix E, “Demand Losses” column) is calculated by multiplying the kW loss per mile for a specific voltage level times the miles of transmission operating at that voltage and then dividing that product by 1,000 to yield a MW loss result. The energy loss is simply the demand loss times the number of hours per year. For 345 kV transmission lines, for example, the corona and insulator demand loss of 2.121 MW in Appendix E is the rounded value of this equation: $(2.343 \text{ kW loss/mile} \times 905.42 \text{ miles}) \div 1,000$. The annual energy loss (18,634 MWH) for these same elements is the product of 2.121 MW (the unrounded value from the previous equation) $\times 8,784 \text{ hours/year}$.

4.2 Transmission Line Demand Losses

The losses calculated for transmission lines are shown in Appendix E, labeled Transmission Line Demand Loss. The peak demand losses were determined by tabulating the megawatt losses per transmission line as shown in the 2016 Study Period peak powerflow study in Appendix N. These losses are tabulated by voltage class.

4.3 Transmission Line Energy Losses

The energy loss for the transmission lines at each voltage level is determined by using the losses developed in the powerflows for each load segment. The segment loads are listed in Appendix E along with the net output of power to the transmission system during the segment. This value was determined in Appendix A and labeled “Net Output to Lines By Load Segment.” The Net Output to Lines by Load Segment is the amount of generated and purchased energy put onto the transmission system to serve load. The determination of the energy losses for transmission lines of a specific voltage in a specific segment is calculated using the following equations.

**Southwestern Public Service Company
Loss Evaluation Study for 2016 Study Period**

$$\text{Segment Loss Factor} = \frac{\text{Segment Loss for Transmission Element, MW}}{\text{Segment Load, MW}} \quad (4.3.1)$$

$$\text{Segment Losses} = \text{Segment Loss Factor} \times \text{Segment Output to Lines, MWH} \quad (4.3.2)$$

Thus, the powerflows provide a determination of the energy loss as a single value for each segment. Dividing the segment loss by the segment load produces a per MW energy loss factor. Multiplying this per MW energy loss factor by the Segment Output to Lines produces the energy loss for that element in that load segment. The energy loss values for the year are simply the sum of the energy loss values for each element in each load segment and appear in Appendix E on lines 37-43 under the column heading “Total Segment Losses, MWH.”

5.0 Autotransformer Demand Losses

SPS’s transmission system autotransformers reduce voltage from one transmission voltage to a lower transmission voltage. The high side and low side autotransformer voltages are typically written as “345/230,” “230/115” and “115/69.” See, e.g., Appendix G, column heading “Voltage”, lines 2, 11 and 41. Each autotransformer in SPS’s transmission system is identified in Appendix G. The load losses related to autotransformers can be separated into demand and energy components.

The demand component was determined in two steps. The first step was to determine the total demand loss for each voltage level of autotransformers from the summer peak powerflow study, summarized in Appendix N. This provided the MW loss due to loading at the peak time of the year. These losses are shown for each of three voltage classes of autotransformers at lines 3, 5 and 7 of Appendix F.

The second component of the autotransformer demand loss was provided by summing the individual transformer no-load demand losses for the different voltage classes of

Southwestern Public Service Company Loss Evaluation Study for 2016 Study Period

individual transformers in Appendix G in the three columns under column heading “Demand Losses, KW.” This component represents the demand loss incurred by simply energizing the transformer, as described below.

5.1 Autotransformer Energy Losses

The energy losses related to autotransformers can also be separated into two parts. The first part is the energy loss associated with no-load operation. This is the energy loss due to the magnetizing currents that exist when a transformer is energized. These losses were determined by multiplying the no-load loss in Watts as shown under column heading “No Load Loss, Watts” in Appendix G by the number of hours in the 2016 Study Period because these autotransformers are assumed to be energized throughout the study period.

The energy losses related to loading were determined using the same methodology as for transmission lines. For each powerflow study, a tabulation of the autotransformer demand losses by voltage level was calculated. A segment loss factor for each segment was calculated by dividing the MW Loss by the Segment Load in Appendix F. The autotransformer energy losses for each segment were calculated by multiplying the segment loss factor by the Segment Output to the Lines for that segment. This produces the average energy losses for each voltage level for each segment. The data needed to make these calculations and the results are shown in Appendix F. The equations used to obtain the energy losses for the autotransformers are the same as Equations 4.3.1 and 4.3.2.

All losses discussed to this point are transmission level losses. The losses discussed in the following sections 6 through 10 are losses at the distribution level.

Southwestern Public Service Company
Loss Evaluation Study for 2016 Study Period

6.0 Distribution Substation Transformer Losses

Distribution substation transformers are those transformers that reduce the transmission voltage, e.g., 69 kV, to a distribution voltage, such as 33 kV, 22 kV or 12.5 kV. The data for each distribution substation transformer are in Appendix I. Manufacturers' data were used to determine losses. If manufacturers' data were not available for a specific transformer, data for a similar transformer manufactured by another company were used.

Column 9 has a code for verification of data. The codes used in this field mean:

- R - ratings were verified from manufacturer's data
- L - loss values were verified from manufacturer's data
- E - loss values are an estimate

There are many transformers on SPS's system that are either owned by a specific customer or have metering or other arrangements to reflect the billing on the high side of the transformer, *i.e.*, before losses are incurred. These transformers are excluded from the loss calculations in Appendix I, and excluded from Appendix I's list of transformers, because SPS does not incur the losses associated with these transformers (the losses are borne by the customer leasing the transformer). In some situations, only a portion of a transformer's capacity is leased, and thus, only a portion of the losses associated with that transformer should be excluded. These transformers are identified by the letter "E" in column 10 of Appendix I, and the percentage of losses to be excluded is stated in column 15. The letter "I" in column 10 means that all of the transformer's losses are included in the loss calculations.

6.1 Distribution Substation Transformer Demand Losses

The demand losses associated with these transformers have two components. The first component is the magnetizing current losses that are present anytime the transformer is energized. The second component is the full load loss value for the transformer. Manufacturers' test report data was used to determine the no-load loss

Southwestern Public Service Company
Loss Evaluation Study for 2016 Study Period

and the loss when the distribution transformers were loaded to their nominal MVA ratings (Appendix I, column 4). Loading of transformers at their nominal MVA rating is referred to in Appendix I as “full load” but this label does not mean that the transformers have no additional capacity. The maximum MVA loading for each transformer is listed in Appendix I, column 5. As evidenced by the differences between the values in columns 4 and 5 of Appendix I, many transformers can handle loads in excess of their nominal “full load.” The no-load losses and nominal “full load” losses for each transformer are tabulated in Appendix I, columns 6 and 7, and totaled for the entire system near the bottom of Columns 6, 7, and 8 on line 302.

It was assumed for the purposes of this study that the distribution transformers were operating at “full load” (their nominal MVA ratings) at the time of the system peak. This assumption was reasonable, conservative, and necessary. The transmission and distribution system is designed to handle the system’s peak load and have additional capacity available in case peak load is greater than forecasted. And, of course, system load has grown since most of these transformers were originally sized and installed. Thus, at the time of system peak, it is likely that many transformers operated somewhere between their nominal and maximum MVA ratings. Thus, basing losses upon only the nominal MVA loading, as SPS has done, is conservative. Using this assumption was necessary since manufacturers typically provide test data only for losses at the nominal MVA rating.

6.2 Distribution Substation Transformer Energy Losses

The energy loss has two components. The first is the no-load loss, which occurs during every hour of the Study Period. Referring to Appendix I, this value was calculated by multiplying the no-load losses derived from manufacturers’ test data, column 6, by the number of hours in the Study Period, which results in the energy loss during the Study Period, as shown in column 12.

Southwestern Public Service Company Loss Evaluation Study for 2016 Study Period

The full load loss required the determination of the load characteristic of the load being served by a particular transformer. The load factor assigned to each transformer is shown in Appendix I, column 11.

The load factor for a study period is defined as:

$$\text{Load Factor} = \frac{\text{Total Study Period Energy Delivered}}{\text{Max. Demand} \times \text{Hours in Study Period}} \quad (6.2.1)$$

For the purpose of determining the study period energy losses, the following equation was used:

$$\text{Losses} = \text{Full Load Loss} \times \text{Hours in Period} \times \text{Load Factor} \quad (6.2.2)$$

The results of this calculation are shown in Appendix I, column 13.

The “Sum of demands adjusted for Primary Generation” is the estimated load at primary and shown on line 305. The 47.291 MW adjustment shown on line 304 is the coincident wind and solar primary generation from Attachment B at system peak hour and it thus reduces the total flow on the primary feeders. This generation connected to the primary voltage level may all flow into the primary voltage level and never get transformed to the transmission voltage level.

6.3 Calculation of Load at Each Feeder Voltage Level

The load at each feeder voltage level is calculated at lines 312-319 of Appendix I. The loading on 33 kV feeders, for example, is calculated by determining the ratio of the nominal MVA of transformers connected to 33 kV feeders (153.30 MVA on line 314) to the adjusted nominal MVA of all distribution substation transformers (3,026.08 on line 314) and then multiplying that ratio by total loading on all distribution feeders (line 305). Thus, for 33 kV feeders, the calculated loading is: $(153.30/3,026.08) \times 2,206.35 \text{ MW} =$

Southwestern Public Service Company Loss Evaluation Study for 2016 Study Period

111.77 MW. This value appears at line 315, column 2 of Appendix I. From this value, the load on transformers with no feeders (line 316) is subtracted to yield the load on 33 kV feeders, which appears on line 319. Line 317 shows data on total numbers of feeders at each voltage level and line 318 shows the number of feeders after excluding the portions of transformers that are shared with customers.

7.0 Load Factor Derivation

The load factor used to calculate the study period full-load energy losses reflected in Appendix I, column 11, provides a representative load factor for substation loads. However, the load factor is not a pure load factor, such as might be found for a rate class. Rather it represents the composite mix of customer load which occurs on the power system. This load factor is calculated in Appendix H.

The data used in Appendix H comes from rate analysis of each customer class on SPS's system for the Study Period. Using this data, monthly demand peaks and monthly energy deliveries, a composite load is developed which represents the desired substation class load. With the summed energy and demands, a load factor can be calculated. The annual load factor for primary distribution, Loss Level 4 is shown in Appendix H, line 78 under table column heading "Total Loss Level 4."

8.0 Distribution Primary Feeder Losses

The primary distribution system (Level 4 in the loss study) includes the distribution lines (feeders) that transport power from the distribution substation to the distribution line transformers near each customer. The losses associated with these primary distribution feeders are calculated on Appendix J. At the top of Appendix J, the distribution loads and energy are summarized for the Study Period. They are broken into loss levels and they represent the demand and energy for each level of the distribution system. These values shown are derived from Appendix H and they will be

Southwestern Public Service Company Loss Evaluation Study for 2016 Study Period

used throughout the distribution loss calculations. On lines 2 and 9, the demand and energy values are offset by the distribution connected generation, obtained from Appendix B.

Losses are calculated for 552.10 feeders operating at 6 nominal voltage levels (33 kV, 22 kV, 13.2 kV, 12.5 kV, 4.16 kV and 2.4 kV). There are 573 feeders connected to the transformers (Appendix I, line 317), but some feeders are connected to transformers whose capacity is shared with customers. Thus, the number of feeders at each voltage level has been reduced in proportion to the nominal MVA of substation transformers at each voltage level leased by customers. The percentage of each transformer's capacity leased to a customer is shown in column 15 of Appendix I. This process produces fractional feeders that are used to calculate primary distribution feeder losses.

8.1 Distribution Primary Feeder Demand Losses

The number of feeders and load at each distribution voltage level are derived from lines 318 and 319, respectively, of Appendix I.

The Feeder Current, in amps, is:

$$\text{Feeder Current} = \frac{\text{Feeder Load}}{(\sqrt{3}) \times \text{Feeder Voltage}} \quad (8.1.1)$$

The Feeder Loss, in watts, for a given voltage level is:

$$\text{Feeder Loss} = 3 \times (\text{Feeder Current})^2 \times \text{Resistance} \times \text{Average Length} \quad (8.1.2)$$

The length of each feeder varies considerably as do the wire sizes (conductors) used in the construction, which affects resistance. The distribution system database consists of 552 feeders ranging in length from zero to 48.6 miles and many different wire sizes and materials. The typical conductor size was determined by summing the feeder lengths

Southwestern Public Service Company Loss Evaluation Study for 2016 Study Period

by voltage and by conductor type and size, selecting the most common conductor based on length and conductor material and size. The results of this investigation appear under the column heading "Typical Conductor" in Appendix J.

The average feeder length was determined by sorting the feeders by voltage and dividing the sum of the lengths by the number of feeders in each voltage range. A feeder was counted if the length was greater than 0.05 miles. There were 552 feeders that fit this criterion. The results of this investigation appear under the column heading "Avg. Feeder Length, Miles" in Appendix J.

The total loss for a given voltage level is obtained by multiplying the loss determined above by the number of feeders in the given voltage level.

8.2 Distribution Primary Energy Losses

These losses were calculated by multiplying the demand energy loss for the entire load served via primary distribution line by the hours in the study year and by the loss factor for the entire distribution load. The load factor is determined in Appendix J from the Total Primary Demand and the Total Energy. Note that the Total Primary Demand and Energy have been offset by the distribution primary connected generation from Appendix B. The Loss Factor is determined by the following equation:²

$$\text{Loss Factor} = (0.3 \times \text{Load Factor}) + (0.7 \times (\text{Load Factor})^2) \quad (8.2.1)$$

Thus, the losses over the year are determined by the following equation:

$$\text{Loss} = \text{Demand Loss} \times 8784 \text{ hours} \times \text{Loss Factor} \quad (8.2.2)$$

9.0 Distribution Line Transformer Losses

² Westinghouse Electric Corporation, Distribution Systems, 1965, page 28.

Southwestern Public Service Company Loss Evaluation Study for 2016 Study Period

Appendix K contains the loss calculations for distribution line transformers, which corresponds to Loss Level 5. The number of meters and transformers are actual counts derived from SPS's records. The meters per transformer data is derived by dividing the adjusted meter count by the number of transformers, e.g., 331,812 single phase meters/97,184 transformers equals 3.41427 meters/transformer.

In calculating losses, it is necessary to distinguish between single phase transformers, which serve primarily residential customers, and three phase transformers, which serve primarily commercial customers. The "Adjusted Meters" column on Appendix K performs this function by assigning the single phase commercial meters to the "Residential" category, i.e., Residential Adjusted Meters equals actual residential meters (301,809) plus the difference between all commercial meters and three phase commercial meters (30,003).

It was assumed that one residential customer took service directly from each distribution line transformer and that all other residential customers were served from secondary distribution lines. Secondary lines are the lines that typically run from a pole top transformer to another pole that has no transformer. From that second pole, a service line runs to the customer's premises. Losses on secondary lines and drops are addressed in Appendix L. For three phase commercial customers, the number of transformers essentially equals the number of meters, and thus, each such customer is assumed to be served directly from the transformer.

9.1 Distribution Line Transformer Demand Losses

Based on consultation with distribution system engineers, typical transformer sizes were chosen as 25 KVA (residential) and 100 KVA (commercial). The transformer loss data at no load and "full load" for each size are listed in Appendix K at lines 26 and 27. The average load per customer is developed by taking the demand served and dividing by the number of customers. Then the loss per transformer is developed by taking the load per customer and calculating the losses proportionally to the load served by the

Southwestern Public Service Company
Loss Evaluation Study for 2016 Study Period

transformer and its full load rating. The total demand loss is determined by multiplying the number of transformers by each no-load and full load loss component. The no-load and loaded losses are shown at Appendix K, lines 35 and 37, and totaled at lines 39 and 41.

9.2 Distribution Line Transformer Energy Losses

These losses were calculated by using the demand energy loss for the distribution line transformers and multiplying by the loss factor of the load served through the distribution transformers and by the number of hours in the Study Period. The load factor is determined from data in Appendix K using the Total Secondary Distribution Transformer Demand and the Total Secondary Distribution Transformer Energy. The Loss Factor is determined from equation 8.2.1. Thus, the losses over the year are determined by the following equation.

$$\text{Loss} = \text{Demand Loss} \times 8784 \text{ hours} \times \text{Loss Factor} \quad (9.2.1)$$

10.0 Distribution Secondary Losses

The distribution secondary losses are determined in Appendix L. To determine the secondary losses, it was estimated that the secondary conductor was 1/0 MCM ACSR conductor and that there was 60 feet of conductor serving each residential meter not served directly from the transformer. The resistance of this secondary was 0.0127 ohms. The typical residential load and current and the commercial load and current were determined in Appendix K. There is no consideration of commercial load on secondary lines, as these customers are usually served directly from transformers.

10.1 Distribution Secondary Demand Losses

There was assumed to be 2 meters per 60 foot of secondary line. The loss, in watts, on the secondary was determined by the following equation:

**Southwestern Public Service Company
Loss Evaluation Study for 2016 Study Period**

$$\text{Loss} = (2 \times I^2 \times R) \quad (10.1.1)$$

Multiplying by the number of meters (Appendix K) produces the total loss for the distribution secondary.

10.2 Distribution Service Line Demand Losses

It was estimated that residential service line consisted of 65 feet of #2 Triplex and commercial service line consisted of 30 feet of #1/0 Quadraplex service wire. The resistances for these service lines are 0.02028 ohms and 0.00636 ohms, respectively. The current for each type of customer is calculated and the losses are calculated by the following equations:

$$\text{Loss} = 2 \times I^2 \times R, \text{ for residential customers and} \quad (10.2.1)$$

$$\text{Loss} = 3 \times I^2 \times R, \text{ for commercial customers} \quad (10.2.2)$$

The total loss for each group was determined by multiplying the loss per meter by the number of meters, which are found on Appendix K.

10.3 Distribution Secondary and Service Lines Energy Losses

These losses were calculated by adding the demand loss of both the Secondary and Services and multiplying by the number of hours in the test year and also multiplying by the loss factor of the load that is served by Secondary and Services. The load factor is determined from data in Appendix L using the Total Secondary Distribution Transformer Demand and Total Secondary Distribution Lines demand and their associated energy. The Loss Factor is determined from equation 8.2.1. Thus, the losses over the year are determined by the following equation.

$$\text{Loss} = \text{Demand Loss} \times 8784 \text{ hours} \times \text{Loss Factor} \quad (10.3.1)$$

Southwestern Public Service Company
Loss Evaluation Study for 2016 Study Period

The results of this calculation are shown in Appendix L.

11.0 Summary of Transmission Loss Study

Appendix M contains the results of all of the calculations discussed previously. The power system elements for which losses are determined are:

- Transmission Lines
- Autotransformers
- Distribution Substation Transformers
- Distribution Primary Lines
- Distribution Line Transformers
- Distribution Secondary and Service Lines

Line 42 shows the total of the loss values obtained by the study, labeled as “Total Determined Losses” or calculated losses. Line 44, labeled “Total Losses,” is the actual energy losses determined in Section 1.2 of this report. The difference between the results of this study and the actual losses is shown on line 43 as “Undeterminable Losses”. Typically, the results from a loss study will be within a few percent, plus or minus, of the actual losses. For the 2016 Study Period, the Total Determined Losses are over estimated by 1.79% of actual losses. ***It should be noted that nowhere in this study is the actual loss value used to force the loss study to produce a final answer equal to the actual loss value.***

The results of this study are used to determine loss factors for the different rate classes. To do this, the calculated losses must be adjusted to total to the actual losses, and thus, the Undeterminable Losses (Appendix M, line 43) have to be allocated to Loss Levels 2 through 6. Each category of energy losses is allocated a portion of the Undeterminable Losses equal to the ratio of that category’s calculated losses to Total Determined Losses in MWh. For example, the “Adjusted Energy MWh” value for Transmission Lines – 345 kV (line 14), which is 80,473 MWh, is determined by: 81,914

Southwestern Public Service Company
Loss Evaluation Study for 2016 Study Period

MWh (line 14 determined energy loss) x (1,914,545 MWH Total Losses /1,948,829 MWH Total Determined Losses).

The values in Appendix M under the column headings “Demand Total Loss, KW” and “Energy Total Loss, kWh” are used in the development of the rate class loss factors.

12.0 Loss Factor Derivation

Appendices O and P contain the derivation of the rate class loss factors from summary data derived in various sections of the report. The rate class loss factors are determined for the loss levels shown in Appendix O and P.

The method to determine the loss factors is based on starting with the total resource input to the system at Generation Level, Level 1. This value is the starting point for the worksheet. Using Appendix O as an example, from this value, the deliveries for that level and the losses for that level are subtracted, leaving the ‘Net KWH into each Loss Level’. This calculation is done for each loss level, with the result that all losses and deliveries have been subtracted from the Total Resources, with a result of zero. This means that all deliveries and losses have been assigned to a loss level and there is no error. Loss factors are calculated at each level as the subtraction progresses to the right through the loss levels. The calculation is shown in the appendices along with the loss factors by rate classification.

The process of calculating the Demand Loss Factor in Appendix O is the same as described for the energy factor calculation. However, rather than redistributing the energy “Undeterminable Losses” among the different loss levels, the Demand MW from line 42 Appendix M is used.

Southwestern Public Service Company
Loss Evaluation Study for 2016 Study Period

Appendix Q contains the Demand and Energy Loss Factors by rate class in summarized form, without their respective derivations. The composite loss factors are shown for rate classes in loss levels 5 and 6.

APPENDIX A
DERIVATION OF ACTUAL LOSSES
January - December 2016
(MWh)

| Line No. | Jan 2016 | Feb 2016 | Mar 2016 | Apr 2016 | May 2016 | Jun 2016 | Jul 2016 | Aug 2016 | Sept 2016 | Oct 2016 | Nov 2016 | Dec 2016 | TOTAL PERIOD |
|----------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|--------------|-------------|-------------|-------------|-----------------|
| 1 | | | | | | | | | | | | | |
| 2 | | | | | | | | | | | | | |
| 3 | | | | | | | | | | | | | |
| 4 | | | | | | | | | | | | | |
| 5 | | | | | | | | | | | | | |
| 6 | | | | | | | | | | | | | |
| 7 | | | | | | | | | | | | | |
| 8 | | | | | | | | | | | | | |
| 9 | | | | | | | | | | | | | |
| 10 | | | | | | | | | | | | | |
| 11 | | | | | | | | | | | | | |
| 12 | | | | | | | | | | | | | |
| 13 | | | | | | | | | | | | | |
| 14 | | | | | | | | | | | | | |
| 15 | | | | | | | | | | | | | |
| 16 | | | | | | | | | | | | | |
| 17 | | | | | | | | | | | | | |
| 18 | | | | | | | | | | | | | |
| 19 | | | | | | | | | | | | | |
| 20 | | | | | | | | | | | | | |
| 21 | | | | | | | | | | | | | |
| 22 | | | | | | | | | | | | | |
| 23 | | | | | | | | | | | | | |
| 24 | | | | | | | | | | | | | |
| 25 | | | | | | | | | | | | | |
| 26 | | | | | | | | | | | | | |
| 27 | | | | | | | | | | | | | |
| 28 | | | | | | | | | | | | | |
| 29 | | | | | | | | | | | | | |
| 30 | | | | | | | | | | | | | |
| 31 | | | | | | | | | | | | | |
| 32 | | | | | | | | | | | | | |
| 33 | | | | | | | | | | | | | |
| 34 | | | | | | | | | | | | | |
| 35 | | | | | | | | | | | | | |
| 36 | | | | | | | | | | | | | |
| 37 | | | | | | | | | | | | | |
| 38 | | | | | | | | | | | | | |
| 39 | | | | | | | | | | | | | |
| 40 | | | | | | | | | | | | | |
| 41 | | | | | | | | | | | | | |
| 42 | | | | | | | | | | | | | |
| 43 | | | | | | | | | | | | | |
| 44 | | | | | | | | | | | | | |
| 45 | | | | | | | | | | | | | |
| 46 | | | | | | | | | | | | | |
| 47 | | | | | | | | | | | | | |
| 48 | | | | | | | | | | | | | |
| 49 | | | | | | | | | | | | | |
| 50 | | | | | | | | | | | | | |
| 51 | | | | | | | | | | | | | |
| 52 | | | | | | | | | | | | | |
| 53 | | | | | | | | | | | | | |
| 54 | | | | | | | | | | | | | |
| 55 | | | | | | | | | | | | | |
| 56 | | | | | | | | | | | | | |
| 57 | | | | | | | | | | | | | |
| 58 | | | | | | | | | | | | | |
| 59 | | | | | | | | | | | | | |
| 60 | | | | | | | | | | | | | |
| 61 | | | | | | | | | | | | | |
| 62 | | | | | | | | | | | | | |
| 63 | | | | | | | | | | | | | |
| 64 | | | | | | | | | | | | | |
| 65 | | | | | | | | | | | | | |
| 66 | | | | | | | | | | | | | |
| 67 | | | | | | | | | | | | | |
| 68 | | | | | | | | | | | | | |
| 69 | | | | | | | | | | | | | |
| 70 | | | | | | | | | | | | | |
| 71 | | | | | | | | | | | | | |
| 72 | | | | | | | | | | | | | |
| 73 | | | | | | | | | | | | | |
| 74 | | | | | | | | | | | | | |
| 75 | | | | | | | | | | | | | |
| 76 | | | | | | | | | | | | | |
| 77 | | | | | | | | | | | | | |
| 78 | | | | | | | | | | | | | |
| 79 | | | | | | | | | | | | | |
| 80 | | | | | | | | | | | | | |
| 81 | | | | | | | | | | | | | |
| 82 | | | | | | | | | | | | | |
| 83 | | | | | | | | | | | | | |
| 84 | | | | | | | | | | | | | |
| 85 | | | | | | | | | | | | | |
| 86 | | | | | | | | | | | | | |
| 87 | | | | | | | | | | | | | |
| 88 | | | | | | | | | | | | | |
| 89 | | | | | | | | | | | | | |

Appendix B
Distribution Resources

| Line No. | | Jan 2016 | Feb 2016 | Mar 2016 | Apr 2016 | May 2016 | Jun 2016 | Jul 2016 | Aug 2016 | Sept 2016 | Oct 2016 | Nov 2016 | Dec 2016 | TOTAL PERIOD | MW Output at Peak |
|----------|--|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|--------------|-------------|-------------|-------------|-----------------|-------------------------|
| 1 | | | | | | | | | | | | | | | |
| 2 | | | | | | | | | | | | | | | |
| 3 | SPS Distribution Connected Resources at Level 4 - Distribution Primary | | | | | | | | | | | | | | |
| 4 | | | | | | | | | | | | | | | |
| 5 | Aeolus Wind | 8 | 3 | 5 | 5 | 4 | 10 | 6 | 4 | 4 | 4 | 6 | 7 | 67 | 0.00 No data |
| 6 | Sun Edison Dist Solar | 6,935 | 8,788 | 10,911 | 11,577 | 11,126 | 11,694 | 12,016 | 9,154 | 8,453 | 8,215 | 5,199 | 4,744 | 108,812 | 39.67 |
| 7 | Subtotal Dist Wind - Pringle | 2,902 | 4,433 | 3,788 | 2,971 | 2,872 | 2,375 | 2,531 | 1,429 | 934 | 895 | 1,864 | 2,424 | 29,418 | -0.09 |
| 8 | West Texas A&M University | 1 | 1 | 1 | 1 | 1 | 1 | 0 | 0 | 0 | 0 | 1 | 1 | 8 | -0.02 |
| 9 | Suzlon 8 Wind | 634 | 1,489 | 1,800 | 1,628 | 1,265 | 1,107 | 1,595 | 1,205 | 1,106 | 1,718 | 1,381 | 1,731 | 16,659 | 0.79 |
| 10 | High Plains Wind Farm (Exelon) | 2,066 | 2,822 | 2,980 | 2,673 | 2,668 | 1,851 | 2,567 | 1,620 | 2,048 | 2,984 | 2,413 | 2,979 | 29,671 | -0.03 |
| 11 | JD Wind (unit 1) (Exelon) | 1,600 | 768 | 651 | 949 | 1,128 | 622 | 572 | 389 | 367 | 752 | 294 | 22 | 8,114 | 0.22 |
| 12 | JD Wind (unit 2) (Exelon) | 1,706 | 1,264 | 1,333 | 1,275 | 1,017 | 597 | 776 | 829 | 1,064 | 1,292 | 836 | 485 | 12,474 | 0.22 |
| 13 | JD Wind (unit 3) (Exelon) | 1,269 | 623 | 736 | 905 | 1,263 | 1,018 | 722 | 426 | 393 | 320 | 361 | 176 | 8,212 | 0.26 |
| 14 | JD Wind (unit 5) (Exelon) | 1,696 | 2,956 | 2,780 | 2,273 | 2,383 | 1,849 | 2,313 | 1,590 | 2,248 | 2,466 | 1,360 | 1,948 | 25,862 | 0.03 |
| 15 | JD Wind (unit 6) (Exelon) | 2,216 | 2,975 | 3,100 | 2,692 | 2,222 | 2,054 | 2,563 | 1,809 | 2,599 | 2,768 | 1,747 | 2,514 | 29,259 | -0.01 |
| 16 | JD Wind (unit 7) (Exelon) | 2,210 | 3,148 | 3,059 | 2,798 | 2,645 | 1,859 | 2,351 | 1,598 | 2,362 | 2,967 | 2,661 | 2,947 | 30,605 | 0.54 |
| 17 | JD Wind (unit 8) (Exelon) | 2,154 | 3,215 | 3,041 | 2,718 | 2,433 | 1,698 | 2,298 | 1,623 | 2,218 | 2,977 | 2,621 | 2,908 | 29,904 | 0.38 |
| 18 | JD Wind (unit 9) (Exelon) | 2,136 | 3,154 | 2,904 | 2,213 | 2,245 | 1,775 | 1,932 | 1,636 | 2,197 | 2,957 | 2,565 | 2,831 | 28,545 | 0.32 |
| 19 | JD Wind (unit 10) (Exelon) | 2,126 | 2,897 | 3,002 | 2,483 | 2,128 | 1,386 | 2,134 | 1,443 | 2,035 | 2,751 | 2,569 | 2,748 | 27,702 | -0.10 |
| 20 | JD Wind (unit 11) (Exelon) | 2,228 | 2,993 | 2,744 | 2,300 | 2,044 | 1,443 | 2,113 | 1,494 | 2,006 | 2,840 | 2,512 | 2,876 | 27,593 | 0.43 |
| 21 | Meslands CC Wind | 15 | 7 | 7 | 8 | 6 | 10 | 9 | 9 | 22 | 17 | 7 | 11 | 128 | 0.00 No data |
| 22 | Llano Estacado (Texico) | 115 | 42 | 52 | 61 | 52 | 66 | 50 | 76 | 60 | 40 | 81 | 71 | 764 | 0.00 No data |
| 23 | Ralls Wind Farm | 1838 | 1954 | 2538 | 1675 | 1668 | 1855 | 2004 | 1575 | 1929 | 2695 | 2804 | 2,954 | 25,489 | 4.68 |
| 24 | | | | | | | | | | | | | | 439,286 | 47.29 MWH |
| 25 | | | | | | | | | | | | | | | |

Appendix C
Generator Step-up Transformer Energy Losses

Appendix C

Not used in this loss evaluation study

Exhibit No. SPS-0005_2016 Loss Study-FINAL.xlsx App. D - System Load Data

App. D - System Load Data

| A | B | C | D | E | F | G | H | I | J | K | L | M |
|-------|-------|-----|------|-------------|---------------------|---------------|---------------|----------------|---------------|--------------|---------------|----------------|
| Seq # | Month | Day | Year | Hr @ Min | Min Sys Net Load | TOTAL EDDY | TOTAL BLKW | TOTAL LAMAR | TOTAL SWPP | TOTAL LPL | TOTAL WIND | TOTAL SOLAR |
| 10 | | | | | | | | | | | | |
| 11 | | | | | | | | | | | | |
| 12 | | | | | | | | | | | | |
| 13 | Jan | 1 | 2016 | 17 | 3244 | 0 | 0 | 0 | -252 | 199 | 299 | 1 |
| 14 | Jan | 2 | 2016 | 16 | 3130 | 0 | 0 | 0 | -558 | 186 | 41 | 4 |
| 15 | Jan | 3 | 2016 | 17 | 3006 | 0 | 0 | 0 | -327 | 164 | 34 | 15 |
| 16 | Jan | 4 | 2016 | 1 | 3235 | 34 | 0 | 0 | -342 | 185 | 129 | 3 |
| 17 | Jan | 5 | 2016 | 3 | 3360 | 0 | 0 | 0 | -198 | 163 | 1101 | 3 |
| 18 | Jan | 6 | 2016 | 3 | 3323 | 0 | 0 | 0 | -2 | 150 | 1396 | 3 |
| 19 | Jan | 7 | 2016 | 3 | 3240 | 0 | 0 | 0 | -103 | 144 | 1243 | 3 |
| 20 | Jan | 8 | 2016 | 4 | 3240 | 0 | 0 | 0 | -708 | 138 | 374 | 3 |
| 21 | Jan | 9 | 2016 | 3 | 3422 | 0 | 0 | 0 | -718 | 178 | 464 | 3 |
| 22 | Jan | 10 | 2016 | 4 | 3469 | 0 | 0 | 0 | -331 | 194 | 355 | 3 |
| 23 | Jan | 11 | 2016 | 16 | 3340 | 0 | 0 | 0 | -612 | 189 | 39 | 24 |
| 24 | Jan | 12 | 2016 | 17 | 3263 | 0 | 0 | 0 | -441 | 177 | 116 | 17 |
| 25 | Jan | 13 | 2016 | 17 | 3224 | 0 | 0 | 0 | -594 | 175 | 45 | 18 |
| 26 | Jan | 14 | 2016 | 16 | 3210 | 0 | 0 | 0 | -580 | 164 | 629 | 19 |
| 27 | Jan | 15 | 2016 | 3 | 3231 | 0 | 0 | 0 | -571 | 178 | 672 | 0 |
| 28 | Jan | 16 | 2016 | 2 | 3205 | 0 | 0 | 0 | -131 | 173 | 618 | 0 |
| 29 | Jan | 17 | 2016 | 16 | 3294 | 0 | 0 | 0 | -367 | 179 | 360 | 28 |
| 30 | Jan | 18 | 2016 | 17 | 3388 | 0 | 0 | 0 | -187 | 189 | 996 | 18 |
| 31 | Jan | 19 | 2016 | 3 | 3266 | 0 | 0 | 0 | -168 | 160 | 1147 | 0 |
| 32 | Jan | 20 | 2016 | 16 | 3235 | 0 | 0 | 0 | 41 | 174 | 1143 | 28 |
| 33 | Jan | 21 | 2016 | 3 | 3181 | 0 | 0 | 0 | 349 | 142 | 1368 | 0 |
| 34 | Jan | 22 | 2016 | 17 | 3207 | 0 | 0 | 0 | -327 | 173 | 25 | 22 |
| 35 | Jan | 23 | 2016 | 16 | 3122 | 0 | 0 | 0 | -473 | 176 | 689 | 30 |
| 36 | Jan | 24 | 2016 | 17 | 3066 | 0 | 0 | 0 | 320 | 169 | 1570 | 22 |
| 37 | Jan | 25 | 2016 | 2 | 3058 | 0 | 0 | 0 | 214 | 156 | 1371 | 0 |
| 38 | Jan | 26 | 2016 | 3 | 3191 | 0 | 0 | 0 | -514 | 153 | 358 | 0 |
| 39 | Jan | 27 | 2016 | 17 | 3216 | 0 | 0 | 0 | -611 | 153 | 139 | 24 |
| 40 | Jan | 28 | 2016 | 0 | 3143 | 0 | 0 | 0 | 394 | 170 | 1436 | 0 |
| 41 | Jan | 29 | 2016 | 18 | 3113 | 0 | 0 | 0 | -315 | 174 | 918 | 3 |
| 42 | Jan | 30 | 2016 | 0 | 2997 | 0 | 0 | 0 | 436 | 149 | 1567 | 0 |
| 43 | Jan | 31 | 2016 | 3 | 2913 | 0 | 0 | 0 | 147 | 135 | 1257 | 0 |

App. D - System Load Data

| A | B | C | D | E | F | G | H | I | J | K | L | M |
|-------|-------|-----|------|------|---------------------|---------------|---------------|----------------|---------------|--------------|---------------|----------------|
| Seq # | Month | Day | Year | Hr @ | Min Sys Net Load | TOTAL EDDY | TOTAL BLKW | TOTAL LAMAR | TOTAL SWPP | TOTAL LPL | TOTAL WIND | TOTAL SOLAR |
| 10 | | | | | | | | | | | | |
| 11 | | | | | | | | | | | | |
| 12 | | | | | | | | | | | | |
| 44 | Feb | 1 | 2016 | 2 | 2980 | 0 | 0 | 0 | -190 | 156 | 664 | 0 |
| 45 | Feb | 2 | 2016 | 2 | 3272 | 0 | 0 | 0 | 244 | 175 | 1659 | 7 |
| 46 | Feb | 3 | 2016 | 16 | 3334 | 0 | 0 | 0 | -458 | 216 | 290 | 21 |
| 47 | Feb | 4 | 2016 | 17 | 3240 | 0 | 0 | 0 | -349 | 161 | 148 | 27 |
| 48 | Feb | 5 | 2016 | 3 | 3329 | 0 | 0 | 0 | 233 | 165 | 1282 | 0 |
| 49 | Feb | 6 | 2016 | 17 | 3040 | 0 | 0 | 0 | -368 | 154 | 414 | 27 |
| 50 | Feb | 7 | 2016 | 18 | 3069 | 0 | 0 | 0 | 9 | 152 | 921 | 2 |
| 51 | Feb | 8 | 2016 | 2 | 3157 | 0 | 0 | 0 | 148 | 151 | 1162 | 0 |
| 52 | Feb | 9 | 2016 | 17 | 3163 | 0 | 0 | 0 | -38 | 190 | 474 | 33 |
| 53 | Feb | 10 | 2016 | 0 | 3090 | 0 | 0 | 0 | 170 | 156 | 748 | 0 |
| 54 | Feb | 11 | 2016 | 2 | 3016 | 0 | 0 | 0 | 482 | 148 | 1151 | 0 |
| 55 | Feb | 12 | 2016 | 2 | 3067 | 0 | 0 | 0 | -423 | 159 | 393 | 0 |
| 56 | Feb | 13 | 2016 | 0 | 3049 | 0 | 0 | 0 | -114 | 146 | 1191 | 0 |
| 57 | Feb | 14 | 2016 | 17 | 2975 | 0 | 0 | 50 | -263 | 167 | 251 | 34 |
| 58 | Feb | 15 | 2016 | 1 | 3020 | 0 | 0 | 0 | -414 | 159 | 373 | 0 |
| 59 | Feb | 16 | 2016 | 2 | 3053 | 0 | 0 | 0 | 0 | 146 | 1269 | 0 |
| 60 | Feb | 17 | 2016 | 0 | 3080 | 0 | 0 | 0 | 142 | 154 | 1457 | 0 |
| 61 | Feb | 18 | 2016 | 3 | 2944 | 0 | 0 | 0 | 132 | 135 | 1460 | 0 |
| 62 | Feb | 19 | 2016 | 4 | 2882 | 0 | 0 | 0 | 37 | 125 | 1253 | 0 |
| 63 | Feb | 20 | 2016 | 5 | 2869 | 0 | 0 | 0 | -66 | 132 | 1071 | 0 |
| 64 | Feb | 21 | 2016 | 3 | 2837 | 0 | 0 | 0 | -667 | 129 | 533 | 0 |
| 65 | Feb | 22 | 2016 | 3 | 2971 | 0 | 0 | 0 | -751 | 119 | 490 | 0 |
| 66 | Feb | 23 | 2016 | 2 | 3119 | 0 | 0 | 0 | -987 | 144 | 115 | 0 |
| 67 | Feb | 24 | 2016 | 18 | 3153 | 0 | 0 | 0 | -14 | 165 | 869 | 15 |
| 68 | Feb | 25 | 2016 | 2 | 3180 | 0 | 0 | 0 | -208 | 147 | 1071 | 0 |
| 69 | Feb | 26 | 2016 | 18 | 3122 | 0 | 0 | 0 | -769 | 180 | 45 | 14 |
| 70 | Feb | 27 | 2016 | 0 | 2995 | 0 | 0 | -26 | 595 | 144 | 1407 | 0 |
| 71 | Feb | 28 | 2016 | 4 | 2906 | 0 | 0 | -50 | 420 | 135 | 1167 | 0 |
| 72 | Feb | 29 | 2016 | 2 | 2914 | 0 | 0 | 0 | 583 | 140 | 1320 | 0 |

App. D - System Load Data

| A | B | C | D | E | F | G | H | I | J | K | L | M |
|-------|-------|-----|------|-------------|---------------------|---------------|---------------|----------------|---------------|--------------|---------------|----------------|
| Seq # | Month | Day | Year | Hr @ Min | Min Sys Net Load | TOTAL EDDY | TOTAL BLKW | TOTAL LAMAR | TOTAL SWPP | TOTAL LPL | TOTAL WIND | TOTAL SOLAR |
| 10 | | | | | | | | | | | | |
| 11 | Mar | 1 | 2016 | 3 | 2893 | 0 | 0 | -24 | 67 | 127 | 1164 | 0 |
| 12 | Mar | 2 | 2016 | 0 | 3046 | 0 | 0 | 0 | -91 | 150 | 680 | 0 |
| 13 | Mar | 3 | 2016 | 2 | 2956 | 0 | 0 | -50 | 227 | 136 | 1068 | 0 |
| 14 | Mar | 4 | 2016 | 3 | 3057 | 0 | 0 | 0 | 462 | 138 | 1480 | 0 |
| 15 | Mar | 5 | 2016 | 3 | 2983 | 0 | 0 | 0 | -229 | 138 | 767 | 0 |
| 16 | Mar | 6 | 2016 | 4 | 2936 | 0 | 0 | -114 | 257 | 124 | 1314 | 0 |
| 17 | Mar | 7 | 2016 | 3 | 2887 | 0 | 0 | -49 | -51 | 131 | 1155 | 0 |
| 18 | Mar | 8 | 2016 | 4 | 2954 | 0 | 0 | 0 | -336 | 135 | 591 | 0 |
| 19 | Mar | 9 | 2016 | 2 | 2959 | 0 | 0 | 0 | -222 | 135 | 374 | 0 |
| 20 | Mar | 10 | 2016 | 3 | 3025 | 0 | 0 | 0 | -300 | 143 | 230 | 0 |
| 21 | Mar | 11 | 2016 | 3 | 3076 | 0 | 0 | 0 | -154 | 140 | 668 | 0 |
| 22 | Mar | 12 | 2016 | 0 | 3032 | 0 | 0 | -63 | 34 | 139 | 1067 | 0 |
| 23 | Mar | 13 | 2016 | 4 | 2933 | 0 | 0 | 0 | -254 | 122 | 572 | 0 |
| 24 | Mar | 14 | 2016 | 4 | 2884 | 0 | 0 | 0 | -79 | 128 | 982 | 0 |
| 25 | Mar | 15 | 2016 | 4 | 2942 | 0 | 0 | 0 | -275 | 122 | 762 | 0 |
| 26 | Mar | 16 | 2016 | 3 | 3001 | 0 | 0 | 0 | -437 | 84 | 551 | 0 |
| 27 | Mar | 17 | 2016 | 4 | 3057 | 0 | 0 | 0 | -617 | 129 | 269 | 0 |
| 28 | Mar | 18 | 2016 | 4 | 3070 | 0 | 0 | 0 | 260 | 130 | 1381 | 0 |
| 29 | Mar | 19 | 2016 | 19 | 3187 | 0 | 0 | 0 | -839 | 158 | 352 | 17 |
| 30 | Mar | 20 | 2016 | 18 | 3109 | 0 | 0 | 0 | -79 | 165 | 293 | 32 |
| 31 | Mar | 21 | 2016 | 3 | 3137 | 0 | 0 | 0 | 228 | 143 | 1423 | 0 |
| 32 | Mar | 22 | 2016 | 3 | 3055 | 0 | 0 | -124 | 503 | 133 | 1422 | 0 |
| 33 | Mar | 23 | 2016 | 4 | 3017 | 0 | 0 | -37 | 86 | 129 | 1322 | 0 |
| 34 | Mar | 24 | 2016 | 2 | 3167 | 0 | 0 | 0 | 8 | 150 | 1228 | 0 |
| 35 | Mar | 25 | 2016 | 3 | 3204 | 0 | 0 | 0 | 259 | 146 | 1375 | 0 |
| 36 | Mar | 26 | 2016 | 3 | 3097 | 0 | 0 | 0 | 227 | 134 | 1087 | 0 |
| 37 | Mar | 27 | 2016 | 17 | 3070 | 0 | 0 | 81 | 42 | 151 | 41 | 34 |
| 38 | Mar | 28 | 2016 | 2 | 3079 | 0 | 0 | 0 | 73 | 139 | 1448 | 0 |
| 39 | Mar | 29 | 2016 | 4 | 3049 | 0 | 0 | -100 | 97 | 124 | 1282 | 0 |
| 40 | Mar | 30 | 2016 | 4 | 3078 | 0 | 0 | -86 | 51 | 134 | 1162 | 0 |
| 41 | Mar | 31 | 2016 | 3 | 3138 | 0 | 0 | -50 | 136 | 133 | 1235 | 0 |

App. D - System Load Data

| A | B | C | D | E | F | G | H | I | J | K | L | M |
|-------|-------|-----|------|------|---------------------|---------------|---------------|----------------|---------------|--------------|---------------|----------------|
| Seq # | Month | Day | Year | Hr @ | Min Sys Net Load | TOTAL EDDY | TOTAL BLKW | TOTAL LAMAR | TOTAL SWPP | TOTAL LPL | TOTAL WIND | TOTAL SOLAR |
| 10 | | | | | | | | | | | | |
| 11 | | | | | | | | | | | | |
| 12 | | | | | | | | | | | | |
| 104 | Apr | 1 | 2016 | 4 | 3202.00 | 0 | 0 | 0 | -513 | 136 | 593 | 0 |
| 105 | Apr | 2 | 2016 | 0 | 3274.00 | 0 | 0 | 0 | -188 | 152 | 1091 | 0 |
| 106 | Apr | 3 | 2016 | 4 | 3186.00 | 0 | 0 | -89 | 112 | 135 | 1419 | 0 |
| 107 | Apr | 4 | 2016 | 3 | 3016.00 | 0 | 0 | 0 | -158 | 125 | 424 | 0 |
| 108 | Apr | 5 | 2016 | 4 | 3080.00 | 0 | 0 | -26 | 291 | 129 | 1416 | 0 |
| 109 | Apr | 6 | 2016 | 4 | 3100.00 | 0 | 0 | 0 | -20 | 131 | 1301 | 0 |
| 110 | Apr | 7 | 2016 | 4 | 3133.00 | 0 | 0 | 0 | 385 | 127 | 1228 | 0 |
| 111 | Apr | 8 | 2016 | 4 | 3151.00 | 0 | 0 | 0 | -18 | 131 | 698 | 0 |
| 112 | Apr | 9 | 2016 | 4 | 3155.00 | 0 | 0 | 0 | -32 | 128 | 1047 | 0 |
| 113 | Apr | 10 | 2016 | 5 | 3118.00 | 0 | 0 | -101 | 36 | 120 | 1372 | 0 |
| 114 | Apr | 11 | 2016 | 4 | 3039.00 | 0 | 0 | -26 | -92 | 131 | 945 | 0 |
| 115 | Apr | 12 | 2016 | 4 | 3199.00 | 0 | 0 | 0 | -619 | 135 | 53 | 0 |
| 116 | Apr | 13 | 2016 | 4 | 3216.00 | 0 | 0 | 0 | -299 | 141 | 573 | 0 |
| 117 | Apr | 14 | 2016 | 4 | 3076.00 | 0 | 0 | -26 | 190 | 132 | 1283 | 0 |
| 118 | Apr | 15 | 2016 | 4 | 3033.00 | 0 | 0 | -50 | 212 | 126 | 1331 | 0 |
| 119 | Apr | 16 | 2016 | 5 | 2971.00 | 0 | 0 | 0 | 419 | 131 | 1273 | 0 |
| 120 | Apr | 17 | 2016 | 5 | 2941.00 | 0 | 0 | 0 | 757 | 123 | 1254 | 0 |
| 121 | Apr | 18 | 2016 | 3 | 2981.00 | 0 | 0 | 0 | 411 | 132 | 1223 | 0 |
| 122 | Apr | 19 | 2016 | 3 | 3033.00 | 0 | 0 | 0 | -232 | 135 | 247 | 0 |
| 123 | Apr | 20 | 2016 | 4 | 2972.00 | 0 | 0 | 0 | -275 | 132 | 73 | 0 |
| 124 | Apr | 21 | 2016 | 4 | 2940.00 | 0 | 0 | 0 | -453 | 134 | 265 | 0 |
| 125 | Apr | 22 | 2016 | 4 | 2957.00 | 39 | 0 | 0 | -79 | 134 | 368 | 0 |
| 126 | Apr | 23 | 2016 | 5 | 2982.00 | 42 | 0 | -50 | 278 | 131 | 1578 | 0 |
| 127 | Apr | 24 | 2016 | 5 | 2971.00 | 41 | 0 | -50 | 145 | 130 | 1318 | 0 |
| 128 | Apr | 25 | 2016 | 4 | 2932.00 | 0 | 0 | 0 | 238 | 135 | 886 | 0 |
| 129 | Apr | 26 | 2016 | 5 | 3064.00 | 0 | 0 | 0 | 85 | 138 | 1125 | 0 |
| 130 | Apr | 27 | 2016 | 4 | 3023.00 | 0 | 0 | 0 | 219 | 126 | 1211 | 0 |
| 131 | Apr | 28 | 2016 | 4 | 3051.00 | 0 | 0 | 0 | -307 | 130 | 728 | 0 |
| 132 | Apr | 29 | 2016 | 4 | 3076.00 | 0 | 0 | 0 | -49 | 145 | 947 | 0 |
| 133 | Apr | 30 | 2016 | 4 | 3018.00 | 0 | 0 | 0 | -217 | 131 | 322 | 0 |

App. D - System Load Data

| A | B | C | D | E | F | G | H | I | J | K | L | M |
|-------|-------|-----|------|------|---------------------|---------------|---------------|----------------|---------------|--------------|---------------|----------------|
| Seq # | Month | Day | Year | Hr @ | Min Sys Net Load | TOTAL EDDY | TOTAL BLKW | TOTAL LAMAR | TOTAL SWPP | TOTAL LPL | TOTAL WIND | TOTAL SOLAR |
| 10 | | | | | | | | | | | | |
| 11 | | | | | | | | | | | | |
| 12 | | | | | | | | | | | | |
| 134 | May | 1 | 2016 | 4 | 2988.00 | 0 | 0 | 0 | 539 | 118 | 1524 | 0 |
| 135 | May | 2 | 2016 | 3 | 3046.00 | 0 | 0 | 0 | -321 | 139 | 247 | 0 |
| 136 | May | 3 | 2016 | 3 | 2992.00 | 0 | 0 | 0 | 294 | 132 | 797 | 0 |
| 137 | May | 4 | 2016 | 3 | 2947.00 | 0 | 0 | 0 | -426 | 133 | 160 | 0 |
| 138 | May | 5 | 2016 | 5 | 2986.00 | 0 | 0 | 0 | 216 | 132 | 560 | 0 |
| 139 | May | 6 | 2016 | 5 | 3080.00 | 0 | 0 | 0 | 534 | 136 | 1562 | 0 |
| 140 | May | 7 | 2016 | 5 | 3130.00 | 0 | 0 | 0 | 249 | 137 | 1347 | 0 |
| 141 | May | 8 | 2016 | 6 | 3079.00 | 0 | 0 | 0 | -55 | 140 | 470 | 0 |
| 142 | May | 9 | 2016 | 4 | 3043.00 | 0 | 0 | 0 | -262 | 141 | 948 | 0 |
| 143 | May | 10 | 2016 | 5 | 3122.00 | 0 | 0 | 0 | -109 | 143 | 419 | 0 |
| 144 | May | 11 | 2016 | 5 | 3236.00 | 0 | 0 | 0 | 105 | 140 | 1114 | 0 |
| 145 | May | 12 | 2016 | 4 | 3187.00 | 0 | 0 | 0 | -384 | 143 | 654 | 0 |
| 146 | May | 13 | 2016 | 5 | 3226.00 | 0 | 0 | -52 | 298 | 143 | 1373 | 0 |
| 147 | May | 14 | 2016 | 5 | 3159.00 | 0 | 0 | -110 | -225 | 143 | 1218 | 0 |
| 148 | May | 15 | 2016 | 5 | 2980.00 | 0 | 0 | 0 | -198 | 126 | 458 | 0 |
| 149 | May | 16 | 2016 | 4 | 2979.00 | 0 | 0 | 0 | -127 | 134 | 923 | 0 |
| 150 | May | 17 | 2016 | 4 | 3010.00 | 0 | 0 | 0 | 277 | 140 | 1391 | 0 |
| 151 | May | 18 | 2016 | 4 | 2937.00 | 0 | 0 | 0 | -312 | 135 | 429 | 0 |
| 152 | May | 19 | 2016 | 4 | 2877.00 | 0 | 0 | 0 | -292 | 134 | 195 | 0 |
| 153 | May | 20 | 2016 | 4 | 2817.00 | 0 | 0 | 0 | 225 | 132 | 1380 | 0 |
| 154 | May | 21 | 2016 | 5 | 2867.00 | 0 | 0 | -100 | 117 | 140 | 1436 | 0 |
| 155 | May | 22 | 2016 | 8 | 2877.00 | 0 | 0 | -118 | 230 | 150 | 1134 | 7 |
| 156 | May | 23 | 2016 | 5 | 2860.00 | 0 | 0 | 0 | 326 | 156 | 1123 | 0 |
| 157 | May | 24 | 2016 | 5 | 3055.00 | 0 | 0 | 0 | 276 | 166 | 1448 | 0 |
| 158 | May | 25 | 2016 | 5 | 3058.00 | 0 | 0 | 0 | -94 | 158 | 1121 | 0 |
| 159 | May | 26 | 2016 | 5 | 3145.00 | 0 | 0 | 0 | 301 | 167 | 1450 | 0 |
| 160 | May | 27 | 2016 | 5 | 3101.00 | 0 | 0 | 0 | -507 | 145 | 544 | 0 |
| 161 | May | 28 | 2016 | 6 | 3077.00 | 0 | 0 | 0 | -517 | 139 | 451 | 0 |
| 162 | May | 29 | 2016 | 5 | 3079.00 | 0 | 0 | 0 | -154 | 140 | 990 | 0 |
| 163 | May | 30 | 2016 | 5 | 2875.00 | 0 | 0 | 0 | -304 | 126 | 481 | 2 |
| 164 | May | 31 | 2016 | 5 | 2939.00 | 0 | 0 | -26 | -234 | 147 | 956 | 2 |

App. D - System Load Data

| A | B | C | D | E | F | G | H | I | J | K | L | M |
|-------|-------|-----|------|------|---------------------|---------------|---------------|----------------|---------------|--------------|---------------|----------------|
| Seq # | Month | Day | Year | Hr @ | Min Sys Net Load | TOTAL EDDY | TOTAL BLKW | TOTAL LAMAR | TOTAL SWPP | TOTAL LPL | TOTAL WIND | TOTAL SOLAR |
| 10 | | | | | | | | | | | | |
| 11 | | | | | | | | | | | | |
| 12 | | | | | | | | | | | | |
| 153 | Jun | 1 | 2016 | 5 | 2881.00 | 0 | 0 | 0 | -409 | 141 | 124 | 0 |
| 154 | Jun | 2 | 2016 | 5 | 2804.00 | 0 | 0 | 0 | -481 | 135 | 181 | 0 |
| 155 | Jun | 3 | 2016 | 4 | 2860.00 | 0 | 0 | 0 | -569 | 139 | 26 | 0 |
| 156 | Jun | 4 | 2016 | 5 | 2904.00 | 0 | 0 | 0 | -444 | 142 | 335 | 0 |
| 157 | Jun | 5 | 2016 | 8 | 2858.00 | 0 | 0 | 0 | -655 | 141 | 38 | 15 |
| 158 | Jun | 6 | 2016 | 5 | 2954.00 | 0 | 0 | 0 | -232 | 149 | 593 | 0 |
| 159 | Jun | 7 | 2016 | 5 | 3085.00 | 52 | 0 | 0 | -144 | 156 | 614 | 8 |
| 160 | Jun | 8 | 2016 | 5 | 3122.00 | 50 | 0 | 0 | 348 | 153 | 1100 | 0 |
| 161 | Jun | 9 | 2016 | 5 | 3246.00 | 50 | 0 | 0 | 538 | 160 | 1329 | 0 |
| 162 | Jun | 10 | 2016 | 5 | 3146.00 | 50 | 0 | 0 | 41 | 165 | 792 | 0 |
| 163 | Jun | 11 | 2016 | 7 | 3323.00 | 50 | 0 | 0 | -226 | 167 | 1071 | 0 |
| 164 | Jun | 12 | 2016 | 8 | 3145.00 | 0 | 0 | 0 | 267 | 155 | 908 | 7 |
| 165 | Jun | 13 | 2016 | 5 | 3360.00 | 0 | 0 | 0 | 237 | 186 | 905 | 1 |
| 166 | Jun | 14 | 2016 | 5 | 3342.00 | 40 | 0 | 0 | -765 | 154 | 297 | 1 |
| 167 | Jun | 15 | 2016 | 5 | 3500.00 | 40 | 0 | 0 | -38 | 208 | 1348 | 1 |
| 168 | Jun | 16 | 2016 | 5 | 3370.00 | 40 | 0 | 0 | 314 | 168 | 1526 | 1 |
| 169 | Jun | 17 | 2016 | 6 | 3634.00 | 40 | 0 | 0 | -183 | 206 | 1351 | 1 |
| 170 | Jun | 18 | 2016 | 8 | 3643.00 | 39 | 0 | 0 | -164 | 206 | 748 | 12 |
| 171 | Jun | 19 | 2016 | 8 | 3622.00 | 40 | 0 | 0 | -394 | 190 | 267 | 6 |
| 172 | Jun | 20 | 2016 | 5 | 3583.00 | 40 | 0 | 0 | -334 | 181 | 1075 | 1 |
| 173 | Jun | 21 | 2016 | 5 | 3661.00 | 40 | 0 | 0 | -234 | 178 | 1254 | 1 |
| 174 | Jun | 22 | 2016 | 5 | 3805.00 | 40 | 0 | 0 | 177 | 182 | 1625 | 1 |
| 175 | Jun | 23 | 2016 | 6 | 3872.00 | 40 | 0 | 0 | -398 | 200 | 471 | 1 |
| 176 | Jun | 24 | 2016 | 5 | 3865.00 | 40 | 0 | 0 | -227 | 190 | 727 | 1 |
| 177 | Jun | 25 | 2016 | 7 | 3833.00 | 40 | 0 | -92 | -297 | 156 | 1245 | 1 |
| 178 | Jun | 26 | 2016 | 8 | 3719.00 | 0 | 0 | 0 | -351 | 185 | 151 | 11 |
| 179 | Jun | 27 | 2016 | 5 | 3615.00 | 0 | 0 | 0 | -247 | 176 | 339 | 1 |
| 180 | Jun | 28 | 2016 | 5 | 3748.00 | 0 | 0 | 0 | -332 | 175 | 415 | 0 |
| 181 | Jun | 29 | 2016 | 5 | 3806.00 | 0 | 0 | 0 | -20 | 170 | 906 | 0 |
| 182 | Jun | 30 | 2016 | 5 | 3854.00 | 40 | 0 | 0 | -764 | 190 | 462 | 0 |

App. D - System Load Data

| A | B | C | D | E | F | G | H | I | J | K | L | M |
|-------|-------|-----|------|------|---------------------|---------------|---------------|----------------|---------------|--------------|---------------|----------------|
| Seq # | Month | Day | Year | Hr @ | Min Sys Net Load | TOTAL EDDY | TOTAL BLKW | TOTAL LAMAR | TOTAL SWPP | TOTAL LPL | TOTAL WIND | TOTAL SOLAR |
| 10 | | | | | | | | | | | | |
| 11 | | | | | | | | | | | | |
| 12 | | | | | | | | | | | | |
| 183 | Jul | 1 | 2016 | 5 | 3789.00 | 40 | 0 | 0 | -304 | 182 | 708 | 0 |
| 184 | Jul | 2 | 2016 | 6 | 3834.00 | 40 | 0 | 0 | -688 | 176 | 989 | 0 |
| 185 | Jul | 3 | 2016 | 8 | 3738.00 | 40 | 0 | 0 | -169 | 186 | 373 | 15 |
| 186 | Jul | 4 | 2016 | 7 | 3701.00 | 40 | 0 | 0 | -479 | 167 | 286 | 0 |
| 187 | Jul | 5 | 2016 | 6 | 3934.00 | 40 | 0 | 0 | -627 | 220 | 641 | 0 |
| 188 | Jul | 6 | 2016 | 6 | 3997.00 | 40 | 0 | 0 | 91 | 194 | 1215 | 0 |
| 189 | Jul | 7 | 2016 | 5 | 4054.00 | 40 | 0 | 0 | -184 | 170 | 1562 | 0 |
| 190 | Jul | 8 | 2016 | 5 | 4220.00 | 40 | 0 | 0 | -589 | 206 | 1147 | 0 |
| 191 | Jul | 9 | 2016 | 8 | 3958.00 | 40 | 0 | 0 | 72 | 159 | 1035 | 6 |
| 192 | Jul | 10 | 2016 | 8 | 4091.00 | 40 | 0 | 0 | -50 | 175 | 1283 | 18 |
| 193 | Jul | 11 | 2016 | 5 | 4245.00 | 40 | 0 | 0 | -124 | 209 | 1421 | 0 |
| 194 | Jul | 12 | 2016 | 6 | 4309.00 | 40 | 0 | 0 | -659 | 221 | 800 | 0 |
| 195 | Jul | 13 | 2016 | 6 | 4366.00 | 40 | 0 | 0 | -83 | 228 | 1481 | 0 |
| 196 | Jul | 14 | 2016 | 6 | 4373.00 | 40 | 0 | 0 | -549 | 215 | 1117 | 0 |
| 197 | Jul | 15 | 2016 | 5 | 4061.00 | 40 | 0 | 0 | -547 | 178 | 314 | 0 |
| 198 | Jul | 16 | 2016 | 7 | 3881.00 | 40 | 0 | 0 | -443 | 172 | 564 | 0 |
| 199 | Jul | 17 | 2016 | 8 | 4035.00 | 49 | 0 | 0 | 178 | 186 | 1523 | 8 |
| 200 | Jul | 18 | 2016 | 5 | 4085.00 | 0 | 0 | 0 | -299 | 187 | 1324 | 0 |
| 201 | Jul | 19 | 2016 | 6 | 4168.00 | 0 | 0 | 0 | -189 | 195 | 984 | 0 |
| 202 | Jul | 20 | 2016 | 5 | 4226.00 | 40 | 0 | 0 | -70 | 198 | 1505 | 0 |
| 203 | Jul | 21 | 2016 | 6 | 4325.00 | 40 | 0 | 0 | -70 | 205 | 1504 | 0 |
| 204 | Jul | 22 | 2016 | 6 | 4299.00 | 40 | 0 | 0 | -53 | 202 | 1318 | 0 |
| 205 | Jul | 23 | 2016 | 8 | 4207.00 | 40 | -16 | 0 | 244 | 193 | 1332 | 25 |
| 206 | Jul | 24 | 2016 | 8 | 4172.00 | 40 | -17 | 0 | -119 | 191 | 762 | 23 |
| 207 | Jul | 25 | 2016 | 6 | 4223.00 | 40 | 13 | 0 | -926 | 212 | 79 | 0 |
| 208 | Jul | 26 | 2016 | 5 | 4209.00 | 40 | -16 | 0 | -1129 | 198 | 291 | 0 |
| 209 | Jul | 27 | 2016 | 5 | 4197.00 | 40 | -16 | 0 | -1172 | 145 | 401 | 0 |
| 210 | Jul | 28 | 2016 | 5 | 4100.00 | 40 | -16 | 74 | -1339 | 183 | 291 | 0 |
| 211 | Jul | 29 | 2016 | 5 | 4217.00 | 0 | -23 | 0 | -559 | 193 | 950 | 0 |
| 212 | Jul | 30 | 2016 | 8 | 4032.00 | 50 | -25 | 0 | -526 | 188 | 430 | 23 |
| 213 | Jul | 31 | 2016 | 8 | 4066.00 | 0 | -107 | 0 | -103 | 188 | 1204 | 27 |

App. D - System Load Data

| A | B | C | D | E | F | G | H | I | J | K | L | M |
|-------|-------|-----|------|------|---------------------|---------------|---------------|----------------|---------------|--------------|---------------|----------------|
| Seq # | Month | Day | Year | Hr @ | Min Sys Net Load | TOTAL EDDY | TOTAL BLKW | TOTAL LAMAR | TOTAL SWPP | TOTAL LPL | TOTAL WIND | TOTAL SOLAR |
| 10 | | | | | | | | | | | | |
| 11 | | | | | | | | | | | | |
| 12 | | | | | | | | | | | | |
| 226 | Aug | 1 | 2016 | 5 | 4145.00 | 0 | -21 | 0 | -146 | 202 | 1401 | 7 |
| 227 | Aug | 2 | 2016 | 5 | 4275.00 | 40 | -21 | 0 | -1099 | 208 | 550 | 7 |
| 228 | Aug | 3 | 2016 | 5 | 4098.00 | 45 | -91 | 0 | -1018 | 207 | 192 | 7 |
| 229 | Aug | 4 | 2016 | 5 | 4229.00 | 0 | -21 | 0 | -571 | 205 | 1258 | 0 |
| 230 | Aug | 5 | 2016 | 5 | 4220.00 | 0 | -21 | 0 | -564 | 208 | 218 | 0 |
| 231 | Aug | 6 | 2016 | 8 | 4165.00 | 0 | -16 | 0 | -588 | 200 | 251 | 21 |
| 232 | Aug | 7 | 2016 | 8 | 4106.00 | 0 | -20 | 0 | -771 | 191 | 355 | 21 |
| 233 | Aug | 8 | 2016 | 5 | 4096.00 | 0 | -21 | 0 | -956 | 205 | 617 | 0 |
| 234 | Aug | 9 | 2016 | 5 | 3994.00 | 40 | 14 | 0 | -746 | 189 | 739 | 0 |
| 235 | Aug | 10 | 2016 | 5 | 4030.00 | 40 | -94 | 0 | -151 | 194 | 1229 | 0 |
| 236 | Aug | 11 | 2016 | 5 | 4096.00 | 40 | -182 | 0 | -668 | 196 | 822 | 0 |
| 237 | Aug | 12 | 2016 | 5 | 3967.00 | 40 | -21 | 0 | -828 | 202 | 149 | 0 |
| 238 | Aug | 13 | 2016 | 6 | 3787.00 | 40 | -21 | 0 | -734 | 148 | 149 | 0 |
| 239 | Aug | 14 | 2016 | 8 | 3704.00 | 40 | -21 | 0 | -553 | 157 | 62 | 1 |
| 240 | Aug | 15 | 2016 | 5 | 3683.00 | 40 | 14 | 0 | -195 | 158 | 589 | 0 |
| 241 | Aug | 16 | 2016 | 5 | 3869.00 | 40 | 14 | 0 | -317 | 168 | 1188 | 0 |
| 242 | Aug | 17 | 2016 | 5 | 3911.00 | 40 | 14 | 0 | -543 | 165 | 815 | 0 |
| 243 | Aug | 18 | 2016 | 5 | 3999.00 | 40 | -21 | 0 | -696 | 185 | 668 | 0 |
| 244 | Aug | 19 | 2016 | 5 | 4024.00 | 40 | -16 | 0 | -900 | 182 | 316 | 0 |
| 245 | Aug | 20 | 2016 | 5 | 3867.00 | 0 | -20 | 0 | -532 | 180 | 1011 | 0 |
| 246 | Aug | 21 | 2016 | 8 | 3646.00 | 0 | 13 | 0 | -818 | 151 | 299 | 2 |
| 247 | Aug | 22 | 2016 | 5 | 3616.00 | 0 | 14 | 0 | -258 | 158 | 1097 | 0 |
| 248 | Aug | 23 | 2016 | 5 | 3850.00 | 40 | 14 | 0 | 65 | 175 | 1392 | 0 |
| 249 | Aug | 24 | 2016 | 5 | 3675.00 | 75 | -16 | 0 | -348 | 171 | 1095 | 0 |
| 250 | Aug | 25 | 2016 | 5 | 3552.00 | 75 | -20 | 0 | -646 | 168 | 110 | 0 |
| 251 | Aug | 26 | 2016 | 5 | 3426.00 | 0 | -21 | 0 | -219 | 158 | 250 | 0 |
| 252 | Aug | 27 | 2016 | 5 | 3393.00 | 0 | 15 | 0 | -114 | 155 | 1103 | 0 |
| 253 | Aug | 28 | 2016 | 6 | 3284.00 | 0 | 14 | 0 | -145 | 162 | 460 | 0 |
| 254 | Aug | 29 | 2016 | 5 | 3157.00 | 0 | 14 | 0 | -105 | 166 | 193 | 0 |
| 255 | Aug | 30 | 2016 | 5 | 3086.00 | 0 | -21 | 0 | -205 | 159 | 24 | 0 |
| 256 | Aug | 31 | 2016 | 5 | 2977.00 | 0 | -21 | 0 | -167 | 157 | 8 | 0 |

App. D - System Load Data

| A | B | C | D | E | F | G | H | I | J | K | L | M |
|-------|-------|-----|------|------|---------------------|---------------|---------------|----------------|---------------|--------------|---------------|----------------|
| Seq # | Month | Day | Year | Hr @ | Min Sys Net Load | TOTAL EDDY | TOTAL BLKW | TOTAL LAMAR | TOTAL SWPP | TOTAL LPL | TOTAL WIND | TOTAL SOLAR |
| 10 | | | | | | | | | | | | |
| 11 | | | | | | | | | | | | |
| 12 | | | | | | | | | | | | |
| 257 | Sep | 1 | 2016 | 4 | 2918.00 | 0 | -30 | 0 | -550 | 155 | 36 | 0 |
| 258 | Sep | 2 | 2016 | 4 | 2962.00 | 0 | 14 | 0 | -544 | 160 | 377 | 0 |
| 259 | Sep | 3 | 2016 | 5 | 3034.00 | 0 | 108 | 0 | -366 | 159 | 1027 | 0 |
| 260 | Sep | 4 | 2016 | 6 | 3028.00 | 0 | 114 | -50 | -118 | 165 | 1043 | 0 |
| 261 | Sep | 5 | 2016 | 5 | 3017.00 | 0 | 19 | -91 | -33 | 162 | 1251 | 0 |
| 262 | Sep | 6 | 2016 | 5 | 3036.00 | 0 | 161 | 0 | -147 | 173 | 1140 | 0 |
| 263 | Sep | 7 | 2016 | 5 | 3047.00 | 0 | -16 | -1 | 29 | 173 | 1000 | 0 |
| 264 | Sep | 8 | 2016 | 5 | 3078.00 | 0 | 14 | 0 | -516 | 179 | 860 | 0 |
| 265 | Sep | 9 | 2016 | 5 | 3062.00 | 0 | 64 | -49 | -667 | 175 | 651 | 0 |
| 266 | Sep | 10 | 2016 | 6 | 2921.00 | 0 | 161 | -124 | -671 | 161 | 878 | 0 |
| 267 | Sep | 11 | 2016 | 5 | 2838.00 | 0 | 155 | -129 | -232 | 139 | 1176 | 0 |
| 268 | Sep | 12 | 2016 | 4 | 2933.00 | 0 | 180 | -183 | -273 | 154 | 1298 | 0 |
| 269 | Sep | 13 | 2016 | 5 | 2979.00 | 0 | 29 | -106 | -639 | 162 | 443 | 0 |
| 270 | Sep | 14 | 2016 | 4 | 2952.00 | 0 | -16 | 0 | -544 | 163 | 149 | 0 |
| 271 | Sep | 15 | 2016 | 4 | 2980.00 | 0 | 180 | 0 | -516 | 160 | 973 | 0 |
| 272 | Sep | 16 | 2016 | 5 | 2776.00 | 0 | 27 | 0 | -461 | 130 | 595 | 0 |
| 273 | Sep | 17 | 2016 | 5 | 2840.00 | 0 | -16 | 0 | -433 | 150 | 152 | 0 |
| 274 | Sep | 18 | 2016 | 5 | 2825.00 | 0 | 170 | 0 | -431 | 147 | 1089 | 0 |
| 275 | Sep | 19 | 2016 | 5 | 2882.00 | 0 | 180 | -39 | -671 | 168 | 832 | 0 |
| 276 | Sep | 20 | 2016 | 5 | 2981.00 | 0 | -16 | -99 | -82 | 171 | 958 | 4 |
| 277 | Sep | 21 | 2016 | 5 | 3049.00 | 0 | 90 | -110 | -239 | 168 | 1072 | 4 |
| 278 | Sep | 22 | 2016 | 5 | 3008.00 | 0 | -16 | -69 | -181 | 168 | 963 | 0 |
| 279 | Sep | 23 | 2016 | 5 | 3000.00 | 0 | -16 | 0 | -105 | 162 | 1153 | 0 |
| 280 | Sep | 24 | 2016 | 6 | 3061.00 | 0 | -13 | 0 | -950 | 173 | 369 | 0 |
| 281 | Sep | 25 | 2016 | 5 | 2915.00 | 0 | -30 | 32 | -166 | 152 | 341 | 0 |
| 282 | Sep | 26 | 2016 | 4 | 2763.00 | 0 | -16 | 0 | -737 | 133 | 208 | 0 |
| 283 | Sep | 27 | 2016 | 4 | 2867.00 | 0 | -60 | 0 | -23 | 132 | 562 | 0 |
| 284 | Sep | 28 | 2016 | 5 | 2885.00 | 0 | -16 | 0 | -509 | 137 | 492 | 0 |
| 285 | Sep | 29 | 2016 | 5 | 2931.00 | 0 | -71 | 0 | -164 | 141 | 362 | 0 |
| 286 | Sep | 30 | 2016 | 5 | 2966.00 | 0 | -16 | 0 | -92 | 138 | 1051 | 0 |

App. D - System Load Data

| A | B | C | D | E | F | G | H | I | J | K | L | M |
|-------|-------|-----|------|------|---------------------|---------------|---------------|----------------|---------------|--------------|---------------|----------------|
| Seq # | Month | Day | Year | Hr @ | Min Sys Net Load | TOTAL EDDY | TOTAL BLKW | TOTAL LAMAR | TOTAL SWPP | TOTAL LPL | TOTAL WIND | TOTAL SOLAR |
| 10 | | | | | | | | | | | | |
| 11 | | | | | | | | | | | | |
| 12 | | | | | | | | | | | | |
| 287 | Oct | 1 | 2016 | 5 | 3004.00 | 0 | 14 | 0 | -56 | 143 | 1119 | 0 |
| 288 | Oct | 2 | 2016 | 6 | 2977.00 | 0 | 0 | 0 | -312 | 142 | 785 | 0 |
| 289 | Oct | 3 | 2016 | 5 | 3001.00 | 0 | 0 | 0 | 44 | 152 | 1298 | 0 |
| 290 | Oct | 4 | 2016 | 5 | 3086.00 | 0 | 0 | 0 | -234 | 156 | 1021 | 0 |
| 291 | Oct | 5 | 2016 | 4 | 2914.00 | 0 | 0 | 0 | -107 | 133 | 413 | 0 |
| 292 | Oct | 6 | 2016 | 4 | 3001.00 | 0 | 0 | 0 | -126 | 145 | 1207 | 0 |
| 293 | Oct | 7 | 2016 | 4 | 2946.00 | 0 | 0 | 0 | -14 | 133 | 1252 | 0 |
| 294 | Oct | 8 | 2016 | 4 | 2944.00 | 0 | 0 | 0 | 108 | 131 | 1018 | 0 |
| 295 | Oct | 9 | 2016 | 5 | 2896.00 | 0 | 0 | 0 | -317 | 131 | 249 | 0 |
| 296 | Oct | 10 | 2016 | 4 | 2827.00 | 0 | 0 | 0 | -179 | 135 | 1193 | 0 |
| 297 | Oct | 11 | 2016 | 4 | 2939.00 | 0 | 0 | 0 | -208 | 147 | 1244 | 0 |
| 298 | Oct | 12 | 2016 | 5 | 2998.00 | 0 | 0 | 0 | -526 | 153 | 900 | 0 |
| 299 | Oct | 13 | 2016 | 4 | 2882.00 | 0 | 0 | 0 | -670 | 133 | 105 | 0 |
| 300 | Oct | 14 | 2016 | 4 | 2900.00 | 0 | 0 | 0 | 272 | 135 | 1118 | 0 |
| 301 | Oct | 15 | 2016 | 5 | 2931.00 | 0 | 0 | 0 | 28 | 141 | 1385 | 0 |
| 302 | Oct | 16 | 2016 | 5 | 2865.00 | 0 | 0 | 0 | -250 | 142 | 1190 | 0 |
| 303 | Oct | 17 | 2016 | 5 | 2877.00 | 0 | 0 | 0 | -28 | 150 | 1518 | 0 |
| 304 | Oct | 18 | 2016 | 5 | 2909.00 | 40 | 0 | 0 | -20 | 144 | 1094 | 0 |
| 305 | Oct | 19 | 2016 | 4 | 2898.00 | 40 | 0 | 0 | 230 | 136 | 1131 | 0 |
| 306 | Oct | 20 | 2016 | 4 | 2919.00 | 40 | 0 | 0 | -3 | 134 | 879 | 0 |
| 307 | Oct | 21 | 2016 | 4 | 2944.00 | 40 | 0 | 0 | 225 | 133 | 1351 | 0 |
| 308 | Oct | 22 | 2016 | 4 | 2932.00 | 0 | 0 | 0 | 64 | 130 | 1478 | 0 |
| 309 | Oct | 23 | 2016 | 5 | 2891.00 | 0 | 0 | 0 | -127 | 128 | 1150 | 0 |
| 310 | Oct | 24 | 2016 | 4 | 2892.00 | 0 | 0 | 0 | -101 | 139 | 152 | 0 |
| 311 | Oct | 25 | 2016 | 4 | 3025.00 | 0 | 0 | 0 | 79 | 146 | 1263 | 0 |
| 312 | Oct | 26 | 2016 | 5 | 3004.00 | 0 | 0 | 0 | 545 | 134 | 910 | 0 |
| 313 | Oct | 27 | 2016 | 5 | 3019.00 | 0 | 0 | 0 | 418 | 143 | 832 | 0 |
| 314 | Oct | 28 | 2016 | 4 | 3025.00 | 0 | 0 | 0 | 69 | 143 | 1398 | 0 |
| 315 | Oct | 29 | 2016 | 5 | 3028.00 | 0 | 0 | 0 | 248 | 138 | 1516 | 0 |
| 316 | Oct | 30 | 2016 | 6 | 2974.00 | 0 | 0 | 0 | -148 | 135 | 656 | 0 |
| 317 | Oct | 31 | 2016 | 4 | 2941.00 | 0 | 0 | 0 | 35 | 138 | 1407 | 0 |

App. D - System Load Data

| A | B | C | D | E | F | G | H | I | J | K | L | M |
|-------|-------|-----|------|-------------|---------------------|---------------|---------------|----------------|---------------|--------------|---------------|----------------|
| Seq # | Month | Day | Year | Hr @ Min | Min Sys Net Load | TOTAL EDDY | TOTAL BLKW | TOTAL LAMAR | TOTAL SWPP | TOTAL LPL | TOTAL WIND | TOTAL SOLAR |
| 10 | | | | | | | | | | | | |
| 11 | | | | | | | | | | | | |
| 12 | | | | | | | | | | | | |
| 318 | Nov | 1 | 2016 | 4 | 2995.00 | 0 | 0 | 0 | -123 | 143 | 852 | 0 |
| 319 | Nov | 2 | 2016 | 4 | 3009.00 | 0 | 0 | 0 | -453 | 144 | 458 | 0 |
| 320 | Nov | 3 | 2016 | 3 | 2872.00 | 0 | 0 | 0 | -90 | 136 | 295 | 0 |
| 321 | Nov | 4 | 2016 | 5 | 2959.00 | 0 | 0 | 0 | -159 | 140 | 49 | 0 |
| 322 | Nov | 5 | 2016 | 5 | 2936.00 | 0 | 0 | 0 | -86 | 134 | 431 | 0 |
| 323 | Nov | 6 | 2016 | 4 | 2802.00 | 0 | 0 | 0 | -260 | 129 | 887 | 0 |
| 324 | Nov | 7 | 2016 | 3 | 2788.00 | 0 | 0 | 0 | 159 | 136 | 318 | 0 |
| 325 | Nov | 8 | 2016 | 3 | 2860.00 | 0 | 0 | 0 | 133 | 135 | 945 | 0 |
| 326 | Nov | 9 | 2016 | 3 | 2965.00 | 0 | 0 | 0 | -204 | 144 | 185 | 0 |
| 327 | Nov | 10 | 2016 | 4 | 3023.00 | 0 | 0 | 0 | -175 | 143 | 842 | 0 |
| 328 | Nov | 11 | 2016 | 3 | 2990.00 | 0 | 0 | 0 | -160 | 141 | 752 | 0 |
| 329 | Nov | 12 | 2016 | 3 | 3001.00 | 0 | 0 | 0 | -552 | 143 | 115 | 0 |
| 330 | Nov | 13 | 2016 | 0 | 2999.00 | 0 | 0 | 0 | -210 | 153 | 282 | 0 |
| 331 | Nov | 14 | 2016 | 3 | 2893.00 | 0 | 0 | 0 | -197 | 136 | 482 | 0 |
| 332 | Nov | 15 | 2016 | 3 | 2949.00 | 0 | 0 | 0 | -211 | 138 | 741 | 0 |
| 333 | Nov | 16 | 2016 | 4 | 2941.00 | 0 | 0 | 0 | 403 | 133 | 1225 | 0 |
| 334 | Nov | 17 | 2016 | 3 | 2926.00 | 0 | 0 | 0 | 278 | 135 | 1407 | 0 |
| 335 | Nov | 18 | 2016 | 3 | 3026.00 | 0 | 0 | 0 | -115 | 140 | 1021 | 0 |
| 336 | Nov | 19 | 2016 | 17 | 3249.00 | 0 | 0 | 0 | 350 | 177 | 1573 | 68 |
| 337 | Nov | 20 | 2016 | 0 | 3056.00 | 0 | 0 | 0 | 166 | 159 | 690 | 0 |
| 338 | Nov | 21 | 2016 | 2 | 2980.00 | 0 | 0 | 0 | 39 | 148 | 555 | 0 |
| 339 | Nov | 22 | 2016 | 3 | 3040.00 | 0 | 0 | 0 | 159 | 140 | 1422 | 0 |
| 340 | Nov | 23 | 2016 | 3 | 3162.00 | 0 | 0 | 0 | -13 | 151 | 1108 | 0 |
| 341 | Nov | 25 | 2016 | 17 | 3023.00 | 0 | 0 | 0 | 43 | 146 | 1231 | 35 |
| 342 | Nov | 25 | 2016 | 3 | 3071.00 | 0 | 0 | 0 | -351 | 124 | 673 | 0 |
| 343 | Nov | 26 | 2016 | 4 | 3138.00 | 0 | 0 | 0 | -113 | 149 | 903 | 0 |
| 344 | Nov | 27 | 2016 | 5 | 3008.00 | 0 | 0 | 0 | 230 | 134 | 1418 | 0 |
| 345 | Nov | 28 | 2016 | 3 | 3033.00 | 0 | 0 | 0 | 78 | 145 | 1349 | 0 |
| 346 | Nov | 29 | 2016 | 3 | 3171.00 | 0 | 0 | 0 | -245 | 154 | 1086 | 0 |
| 347 | Nov | 30 | 2016 | 16 | 3328.00 | 0 | 0 | 0 | -344 | 199 | 765 | 172 |

App. D - System Load Data

| A | B | C | D | E | F | G | H | I | J | K | L | M |
|-------|-------|-----|------|-------------|---------------------|---------------|---------------|----------------|---------------|--------------|---------------|----------------|
| Seq # | Month | Day | Year | Hr @ Min | Min Sys Net Load | TOTAL EDDY | TOTAL BLKW | TOTAL LAMAR | TOTAL SWPP | TOTAL LPL | TOTAL WIND | TOTAL SOLAR |
| 10 | | | | | | | | | | | | |
| 11 | | | | | | | | | | | | |
| 12 | | | | | | | | | | | | |
| 348 | Dec | 1 | 2016 | 16 | 3296.00 | 0 | 0 | 0 | -116 | 199 | 59 | 150 |
| 349 | Dec | 2 | 2016 | 2 | 3278.00 | 0 | 0 | 0 | -102 | 179 | 291 | 0 |
| 350 | Dec | 3 | 2016 | 4 | 3289.00 | 0 | 0 | 0 | -519 | 175 | 415 | 0 |
| 351 | Dec | 4 | 2016 | 16 | 3190.00 | 0 | 0 | 0 | -557 | 186 | 28 | 158 |
| 352 | Dec | 5 | 2016 | 17 | 3289.00 | 0 | 0 | 0 | -255 | 141 | 938 | 27 |
| 353 | Dec | 6 | 2016 | 2 | 3273.00 | 0 | 0 | 0 | -220 | 173 | 1161 | 0 |
| 354 | Dec | 7 | 2016 | 3 | 3516.00 | 0 | 0 | 0 | -85 | 202 | 1330 | 0 |
| 355 | Dec | 8 | 2016 | 2 | 3614.00 | 0 | 0 | 0 | -339 | 223 | 777 | 0 |
| 356 | Dec | 9 | 2016 | 17 | 3633.00 | 0 | 0 | 0 | 165 | 240 | 752 | 58 |
| 357 | Dec | 10 | 2016 | 17 | 3276.00 | 0 | 0 | 0 | 207 | 192 | 1331 | 13 |
| 358 | Dec | 11 | 2016 | 17 | 3253.00 | 0 | 0 | 0 | -270 | 185 | 670 | 25 |
| 359 | Dec | 12 | 2016 | 2 | 3274.00 | 0 | 0 | 0 | -48 | 138 | 423 | 0 |
| 360 | Dec | 13 | 2016 | 3 | 3239.00 | 0 | 0 | 0 | -473 | 167 | 667 | 0 |
| 361 | Dec | 14 | 2016 | 3 | 3435.00 | 0 | 0 | 0 | 276 | 197 | 1086 | 0 |
| 362 | Dec | 15 | 2016 | 1 | 3540.00 | 0 | 0 | 0 | -32 | 165 | 377 | 0 |
| 363 | Dec | 16 | 2016 | 0 | 3291.00 | 0 | 0 | 0 | 519 | 173 | 1577 | 0 |
| 364 | Dec | 17 | 2016 | 3 | 3175.00 | 0 | 0 | 0 | 459 | 157 | 1534 | 0 |
| 365 | Dec | 18 | 2016 | 16 | 3409.00 | 0 | 0 | 0 | 531 | 197 | 349 | 72 |
| 366 | Dec | 19 | 2016 | 16 | 3436.00 | 0 | 0 | 0 | 24 | 231 | 1166 | 143 |
| 367 | Dec | 20 | 2016 | 17 | 3263.00 | 0 | 0 | 0 | -267 | 201 | 23 | 59 |
| 368 | Dec | 21 | 2016 | 3 | 3341.00 | 0 | 0 | 0 | -454 | 186 | 1252 | 0 |
| 369 | Dec | 22 | 2016 | 3 | 3310.00 | 0 | 0 | 0 | -906 | 182 | 356 | 0 |
| 370 | Dec | 23 | 2016 | 17 | 3174.00 | 0 | 0 | 0 | -242 | 177 | 587 | 63 |
| 371 | Dec | 24 | 2016 | 16 | 3036.00 | 0 | 0 | 0 | 201 | 161 | 1414 | 47 |
| 372 | Dec | 25 | 2016 | 5 | 2860.00 | 0 | 0 | 0 | 217 | 134 | 1521 | 0 |
| 373 | Dec | 26 | 2016 | 16 | 3113.00 | 0 | 0 | 0 | -393 | 168 | 320 | 147 |
| 374 | Dec | 27 | 2016 | 2 | 3244.00 | 0 | 0 | 0 | -635 | 175 | 734 | 0 |
| 375 | Dec | 28 | 2016 | 3 | 3202.00 | 0 | 0 | 0 | -48 | 159 | 1488 | 0 |
| 376 | Dec | 29 | 2016 | 3 | 3274.00 | 0 | 0 | 0 | -578 | 157 | 1115 | 0 |
| 377 | Dec | 30 | 2016 | 3 | 3476.00 | 0 | 0 | 0 | -292 | 186 | 1618 | 0 |
| 378 | Dec | 31 | 2016 | 17 | 3256.00 | 0 | 0 | 0 | -761 | 178 | 44 | 21 |

| A | B | C | D | P | Q | R | S | T | U | V | W | X | Y | AA | AB | AC | AD | AE | AF |
|-------|-------|-----|------|--------------|-------------|---------------------|---------------|---------------|----------------|---------------|--------------|---------------|----------------|----|--------------|-----------------|----------------|------------|----|
| Seq # | Month | Day | Year | Total Min | Hr @ Max | Max Sys Net Load | TOTAL EDDY | TOTAL BLKW | TOTAL LAMAR | TOTAL SWPP | TOTAL LPL | TOTAL WIND | TOTAL SOLAR | | Total Max | Average Load | Study Value | % Error | |
| 10 | | | | | | | | | | | | | | | | | | | |
| 11 | | | | | | | | | | | | | | | | | | | |
| 12 | | | | | | | | | | | | | | | | | | | |
| 13 | 1 | Jan | 1 | 2016 | 3244 | 20 | 3494 | 0 | 0 | -373 | 224 | 474 | 0 | | 3494 | 3369 | 3379.7 | -0.32% | |
| 14 | 2 | Jan | 2 | 2016 | 3130 | 21 | 3481 | 0 | 0 | -431 | 242 | 85 | 0 | | 3481 | 3306 | 3379.7 | -2.20% | |
| 15 | 3 | Jan | 3 | 2016 | 3006 | 8 | 3491 | 0 | 0 | -441 | 206 | 396 | 0 | | 3491 | 3249 | 3379.7 | -3.88% | |
| 16 | 4 | Jan | 4 | 2016 | 3235 | 8 | 3735 | 40 | 0 | -124 | 235 | 301 | 3 | | 3735 | 3485 | 3379.7 | 3.12% | |
| 17 | 5 | Jan | 5 | 2016 | 3360 | 20 | 3847 | 0 | 0 | -104 | 220 | 1512 | 3 | | 3847 | 3604 | 3379.7 | 6.62% | |
| 18 | 6 | Jan | 6 | 2016 | 3323 | 8 | 3707 | 0 | 0 | -557 | 206 | 968 | 3 | | 3707 | 3515 | 3379.7 | 4.00% | |
| 19 | 7 | Jan | 7 | 2016 | 3240 | 8 | 3697 | 0 | 0 | -244 | 196 | 783 | 3 | | 3697 | 3469 | 3379.7 | 2.63% | |
| 20 | 8 | Jan | 8 | 2016 | 3240 | 19 | 3691 | 0 | 0 | -673 | 213 | 504 | 3 | | 3691 | 3466 | 3379.7 | 2.54% | |
| 21 | 9 | Jan | 9 | 2016 | 3422 | 10 | 3724 | 0 | 0 | -899 | 220 | 339 | 16 | | 3724 | 3573 | 3379.7 | 5.72% | |
| 22 | 10 | Jan | 10 | 2016 | 3469 | 21 | 3780 | 0 | 0 | -859 | 235 | 278 | 3 | | 3780 | 3625 | 3379.7 | 7.24% | |
| 23 | 11 | Jan | 11 | 2016 | 3340 | 8 | 3963 | 0 | 0 | -666 | 242 | 160 | 3 | | 3963 | 3652 | 3379.7 | 8.04% | |
| 24 | 12 | Jan | 12 | 2016 | 3263 | 8 | 3926 | 0 | 0 | -512 | 232 | 515 | 3 | | 3926 | 3595 | 3379.7 | 6.36% | |
| 25 | 13 | Jan | 13 | 2016 | 3224 | 8 | 3879 | 0 | 0 | -355 | 225 | 785 | 3 | | 3879 | 3552 | 3379.7 | 5.08% | |
| 26 | 14 | Jan | 14 | 2016 | 3210 | 8 | 3812 | 0 | 0 | -252 | 215 | 1202 | 3 | | 3812 | 3511 | 3379.7 | 3.88% | |
| 27 | 15 | Jan | 15 | 2016 | 3231 | 8 | 3749 | 0 | 0 | -738 | 246 | 185 | 0 | | 3749 | 3490 | 3379.7 | 3.26% | |
| 28 | 16 | Jan | 16 | 2016 | 3205 | 11 | 3559 | 0 | 0 | -472 | 229 | 85 | 28 | | 3559 | 3382 | 3379.7 | 0.07% | |
| 29 | 17 | Jan | 17 | 2016 | 3294 | 21 | 3641 | 0 | 0 | -447 | 228 | 96 | 0 | | 3641 | 3468 | 3379.7 | 2.60% | |
| 30 | 18 | Jan | 18 | 2016 | 3388 | 10 | 3880 | 0 | 0 | -35 | 230 | 172 | 11 | | 3880 | 3634 | 3379.7 | 7.52% | |
| 31 | 19 | Jan | 19 | 2016 | 3266 | 8 | 3729 | 0 | 0 | 263 | 224 | 1254 | 0 | | 3729 | 3498 | 3379.7 | 3.49% | |
| 32 | 20 | Jan | 20 | 2016 | 3235 | 8 | 3766 | 0 | 0 | 244 | 221 | 1439 | 0 | | 3766 | 3501 | 3379.7 | 3.57% | |
| 33 | 21 | Jan | 21 | 2016 | 3181 | 8 | 3703 | 0 | 0 | 603 | 208 | 1462 | 0 | | 3703 | 3442 | 3379.7 | 1.84% | |
| 34 | 22 | Jan | 22 | 2016 | 3207 | 8 | 3872 | 0 | 0 | -516 | 236 | 157 | 0 | | 3872 | 3540 | 3379.7 | 4.73% | |
| 35 | 23 | Jan | 23 | 2016 | 3122 | 9 | 3638 | 0 | 0 | -53 | 204 | 1128 | 13 | | 3638 | 3380 | 3379.7 | 0.01% | |
| 36 | 24 | Jan | 24 | 2016 | 3066 | 10 | 3411 | 0 | 0 | -181 | 206 | 1227 | 26 | | 3411 | 3239 | 3379.7 | -4.18% | |
| 37 | 25 | Jan | 25 | 2016 | 3058 | 8 | 3612 | 0 | 0 | -18 | 228 | 1294 | 0 | | 3612 | 3335 | 3379.7 | -1.32% | |
| 38 | 26 | Jan | 26 | 2016 | 3191 | 8 | 3669 | 0 | 0 | -556 | 215 | 272 | 0 | | 3669 | 3430 | 3379.7 | 1.49% | |
| 39 | 27 | Jan | 27 | 2016 | 3216 | 8 | 3900 | 0 | 0 | -256 | 242 | 542 | 0 | | 3900 | 3558 | 3379.7 | 5.28% | |
| 40 | 28 | Jan | 28 | 2016 | 3143 | 8 | 3774 | 0 | 0 | -723 | 248 | 150 | 0 | | 3774 | 3459 | 3379.7 | 2.33% | |
| 41 | 29 | Jan | 29 | 2016 | 3113 | 8 | 3622 | 0 | 0 | -161 | 223 | 1116 | 0 | | 3622 | 3368 | 3379.7 | -0.36% | |
| 42 | 30 | Jan | 30 | 2016 | 2997 | 8 | 3297 | 0 | 0 | -24 | 181 | 1184 | 0 | | 3297 | 3147 | 3379.7 | -6.89% | |
| 43 | 31 | Jan | 31 | 2016 | 2913 | 21 | 3235 | 0 | 0 | -18 | 198 | 791 | 7 | | 3235 | 3074 | 3379.7 | -9.05% | |

| | A | B | C | D | P | Q | R | S | T | U | V | W | X | Y | AA | AB | AC | AD | AE | AF |
|----|-------|-------|-----|------|-------|------|----------|-------|-------|-------|-------|-------|----------|-------|-------|-------|---------|--------|--------|----|
| | | | | | Total | Hr @ | Max Sys | Total | Total | Total | Total | Total | Total | TOTAL | | Total | Average | Study | % | |
| | Seq # | Month | Day | Year | Min | Max | Net Load | EDDY | BLKW | LAMAR | SWPP | LPL | TIE FLOW | WIND | SOLAR | Max | Load | Value | Error | |
| 10 | | | | | | | | | | | | | | | | | | | | |
| 11 | | | | | | | | | | | | | | | | | | | | |
| 12 | | | | | | | | | | | | | | | | | | | | |
| 44 | 32 | Feb | 1 | 2016 | 2980 | 8 | 3568 | 0 | 0 | 0 | 259 | 227 | 1265 | 0 | | 3568 | 3274 | 3379.7 | -3.13% | |
| 45 | 33 | Feb | 2 | 2016 | 3272 | 8 | 3741 | 0 | 0 | 0 | 140 | 240 | 1507 | 7 | | 3741 | 3507 | 3379.7 | 3.75% | |
| 46 | 34 | Feb | 3 | 2016 | 3334 | 8 | 3889 | 0 | 0 | 0 | -448 | 268 | 341 | 0 | | 3889 | 3612 | 3379.7 | 6.86% | |
| 47 | 35 | Feb | 4 | 2016 | 3240 | 8 | 3938 | 0 | 0 | 0 | 127 | 234 | 852 | 0 | | 3938 | 3589 | 3379.7 | 6.19% | |
| 48 | 36 | Feb | 5 | 2016 | 3329 | 8 | 3789 | 0 | 0 | 0 | 40 | 229 | 920 | 0 | | 3789 | 3559 | 3379.7 | 5.31% | |
| 49 | 37 | Feb | 6 | 2016 | 3040 | 8 | 3654 | 0 | 0 | 0 | -451 | 211 | 216 | 1 | | 3654 | 3347 | 3379.7 | -0.97% | |
| 50 | 38 | Feb | 7 | 2016 | 3069 | 9 | 3408 | 0 | 0 | 0 | -382 | 176 | 857 | 19 | | 3408 | 3239 | 3379.7 | -4.18% | |
| 51 | 39 | Feb | 8 | 2016 | 3157 | 8 | 3761 | 0 | 0 | 0 | -75 | 226 | 939 | 0 | | 3761 | 3459 | 3379.7 | 2.35% | |
| 52 | 40 | Feb | 9 | 2016 | 3163 | 8 | 3759 | 0 | 0 | 0 | -117 | 245 | 950 | 1 | | 3759 | 3461 | 3379.7 | 2.41% | |
| 53 | 41 | Feb | 10 | 2016 | 3090 | 8 | 3677 | 0 | 0 | 0 | 561 | 226 | 1318 | 1 | | 3677 | 3384 | 3379.7 | 0.11% | |
| 54 | 42 | Feb | 11 | 2016 | 3016 | 8 | 3542 | 0 | 0 | 0 | -9 | 214 | 443 | 1 | | 3542 | 3279 | 3379.7 | -2.98% | |
| 55 | 43 | Feb | 12 | 2016 | 3067 | 8 | 3570 | 0 | 0 | 0 | -61 | 223 | 746 | 1 | | 3570 | 3319 | 3379.7 | -1.81% | |
| 56 | 44 | Feb | 13 | 2016 | 3049 | 9 | 3418 | 0 | 0 | 0 | 620 | 193 | 1296 | 27 | | 3418 | 3234 | 3379.7 | -4.33% | |
| 57 | 45 | Feb | 14 | 2016 | 2975 | 10 | 3266 | 0 | 0 | 0 | 24 | 176 | 624 | 15 | | 3266 | 3121 | 3379.7 | -7.67% | |
| 58 | 46 | Feb | 15 | 2016 | 3020 | 8 | 3480 | 0 | 0 | 0 | -770 | 218 | 356 | 2 | | 3480 | 3250 | 3379.7 | -3.84% | |
| 59 | 47 | Feb | 16 | 2016 | 3053 | 8 | 3529 | 0 | 0 | 0 | -665 | 208 | 950 | 2 | | 3529 | 3291 | 3379.7 | -2.62% | |
| 60 | 48 | Feb | 17 | 2016 | 3080 | 8 | 3558 | 0 | 0 | 0 | -532 | 206 | 1045 | 3 | | 3558 | 3319 | 3379.7 | -1.80% | |
| 61 | 49 | Feb | 18 | 2016 | 2944 | 8 | 3397 | 0 | 0 | 0 | 60 | 187 | 1608 | 2 | | 3397 | 3171 | 3379.7 | -6.19% | |
| 62 | 50 | Feb | 19 | 2016 | 2882 | 20 | 3309 | 0 | 0 | 0 | -306 | 199 | 953 | 0 | | 3309 | 3096 | 3379.7 | -8.41% | |
| 63 | 51 | Feb | 20 | 2016 | 2869 | 20 | 3222 | 0 | 0 | 0 | -220 | 199 | 478 | 0 | | 3222 | 3046 | 3379.7 | -9.89% | |
| 64 | 52 | Feb | 21 | 2016 | 2837 | 20 | 3270 | 0 | 0 | 0 | -420 | 176 | 445 | 0 | | 3270 | 3054 | 3379.7 | -9.65% | |
| 65 | 53 | Feb | 22 | 2016 | 2971 | 20 | 3456 | 0 | 0 | 0 | -381 | 197 | 472 | 0 | | 3456 | 3214 | 3379.7 | -4.92% | |
| 66 | 54 | Feb | 23 | 2016 | 3119 | 20 | 3694 | 0 | 0 | 0 | -279 | 219 | 1159 | 0 | | 3694 | 3407 | 3379.7 | 0.79% | |
| 67 | 55 | Feb | 24 | 2016 | 3153 | 8 | 3753 | 0 | 0 | 0 | -334 | 214 | 835 | 6 | | 3753 | 3453 | 3379.7 | 2.17% | |
| 68 | 56 | Feb | 25 | 2016 | 3180 | 8 | 3628 | 0 | 0 | 0 | -626 | 205 | 522 | 5 | | 3628 | 3404 | 3379.7 | 0.72% | |
| 69 | 57 | Feb | 26 | 2016 | 3122 | 8 | 3699 | 0 | 0 | 0 | -11 | 206 | 1522 | 6 | | 3699 | 3411 | 3379.7 | 0.91% | |
| 70 | 58 | Feb | 27 | 2016 | 2995 | 8 | 3332 | 0 | 0 | 0 | -16 | 183 | 1311 | 6 | | 3332 | 3164 | 3379.7 | -6.40% | |
| 71 | 59 | Feb | 28 | 2016 | 2906 | 20 | 3206 | 0 | 0 | 0 | -53 | 194 | 343 | 0 | | 3206 | 3056 | 3379.7 | -9.58% | |
| 72 | 60 | Feb | 29 | 2016 | 2914 | 8 | 3413 | 0 | 0 | 0 | 339 | 195 | 1375 | 6 | | 3413 | 3164 | 3379.7 | -6.40% | |

| A | B | C | D | P | Q | R | S | T | U | V | W | X | Y | AA | AB | AC | AD | AE | AF |
|-----|-------|-------|-----|------|--------------|-------------|---------------------|---------------|---------------|----------------|---------------|--------------|-------------------|---------------|----------------|--------------|-----------------|----------------|------------|
| 10 | Seq # | Month | Day | Year | Total Min | Hr @ Max | Max Sys Net Load | TOTAL EDDY | TOTAL BLKW | TOTAL LAMAR | TOTAL SWPP | TOTAL LPL | TOTAL TIE FLOW | TOTAL WIND | TOTAL SOLAR | Total Max | Average Load | Study Value | % Error |
| 11 | 61 | Mar | 1 | 2016 | 2893 | 8 | 3359 | 0 | 0 | 0 | 121 | 188 | 1193 | 7 | | 3359 | 3126 | 3323.4 | -5.94% |
| 12 | 62 | Mar | 2 | 2016 | 3046 | 8 | 3490 | 0 | 0 | 0 | 338 | 199 | 1522 | 3 | | 3490 | 3268 | 3323.4 | -1.67% |
| 73 | 63 | Mar | 3 | 2016 | 2956 | 19 | 3379 | 0 | 0 | 0 | 340 | 201 | 287 | 0 | | 3379 | 3168 | 3323.4 | -4.69% |
| 74 | 64 | Mar | 4 | 2016 | 3057 | 8 | 3458 | 0 | 0 | 0 | 399 | 190 | 1462 | 5 | | 3458 | 3258 | 3323.4 | -1.98% |
| 75 | 65 | Mar | 5 | 2016 | 2983 | 20 | 3249 | 0 | 0 | -55 | 157 | 181 | 1347 | 0 | | 3249 | 3116 | 3323.4 | -6.24% |
| 76 | 66 | Mar | 6 | 2016 | 2936 | 20 | 3270 | 0 | 0 | 0 | 37 | 195 | 1387 | 0 | | 3270 | 3103 | 3323.4 | -6.63% |
| 77 | 67 | Mar | 7 | 2016 | 2887 | 20 | 3377 | 0 | 0 | 0 | -218 | 206 | 999 | 0 | | 3377 | 3132 | 3323.4 | -5.76% |
| 78 | 68 | Mar | 8 | 2016 | 2954 | 20 | 3375 | 0 | 0 | 0 | -78 | 206 | 379 | 0 | | 3375 | 3165 | 3323.4 | -4.78% |
| 79 | 69 | Mar | 9 | 2016 | 2959 | 21 | 3371 | 0 | 0 | 0 | -310 | 202 | 294 | 0 | | 3371 | 3165 | 3323.4 | -4.77% |
| 80 | 70 | Mar | 10 | 2016 | 3025 | 8 | 3417 | 0 | 0 | 0 | -163 | 189 | 206 | 9 | | 3417 | 3221 | 3323.4 | -3.08% |
| 81 | 71 | Mar | 11 | 2016 | 3076 | 8 | 3472 | 0 | 0 | 0 | -306 | 190 | 116 | 13 | | 3472 | 3274 | 3323.4 | -1.49% |
| 82 | 72 | Mar | 12 | 2016 | 3032 | 11 | 3259 | 0 | 0 | 0 | 374 | 171 | 1047 | 43 | | 3259 | 3146 | 3323.4 | -5.35% |
| 83 | 73 | Mar | 13 | 2016 | 2933 | 21 | 3236 | 0 | 0 | 0 | 152 | 187 | 367 | 0 | | 3236 | 3085 | 3323.4 | -7.19% |
| 84 | 74 | Mar | 14 | 2016 | 2884 | 21 | 3395 | 0 | 0 | 0 | 223 | 196 | 1601 | 0 | | 3395 | 3140 | 3323.4 | -5.53% |
| 85 | 75 | Mar | 15 | 2016 | 2942 | 21 | 3388 | 0 | 0 | 0 | -183 | 135 | 569 | 0 | | 3388 | 3165 | 3323.4 | -4.77% |
| 86 | 76 | Mar | 16 | 2016 | 3001 | 9 | 3416 | 0 | 0 | 0 | 174 | 168 | 919 | 13 | | 3416 | 3209 | 3323.4 | -3.46% |
| 87 | 77 | Mar | 17 | 2016 | 3057 | 9 | 3440 | 0 | 0 | 0 | -84 | 174 | 91 | 9 | | 3440 | 3249 | 3323.4 | -2.25% |
| 88 | 78 | Mar | 18 | 2016 | 3070 | 12 | 3572 | 43 | 0 | 0 | -146 | 179 | 1361 | 35 | | 3572 | 3321 | 3323.4 | -0.07% |
| 89 | 79 | Mar | 19 | 2016 | 3187 | 11 | 3516 | 0 | 0 | 0 | -875 | 190 | 236 | 33 | | 3516 | 3352 | 3323.4 | 0.85% |
| 90 | 80 | Mar | 20 | 2016 | 3109 | 9 | 3368 | 0 | 0 | 0 | -420 | 169 | 45 | 15 | | 3368 | 3239 | 3323.4 | -2.55% |
| 91 | 81 | Mar | 21 | 2016 | 3137 | 8 | 3663 | 0 | 0 | 0 | 75 | 205 | 1578 | 0 | | 3663 | 3400 | 3323.4 | 2.30% |
| 92 | 82 | Mar | 22 | 2016 | 3055 | 8 | 3493 | 0 | 0 | 0 | 456 | 190 | 1408 | 0 | | 3493 | 3274 | 3323.4 | -1.49% |
| 93 | 83 | Mar | 23 | 2016 | 3017 | 22 | 3458 | 0 | 0 | 0 | -273 | 189 | 1278 | 0 | | 3458 | 3238 | 3323.4 | -2.58% |
| 94 | 84 | Mar | 24 | 2016 | 3167 | 8 | 3624 | 0 | 0 | 0 | -243 | 212 | 855 | 0 | | 3624 | 3396 | 3323.4 | 2.17% |
| 95 | 85 | Mar | 25 | 2016 | 3204 | 10 | 3557 | 0 | 0 | 0 | 63 | 189 | 1117 | 21 | | 3557 | 3381 | 3323.4 | 1.72% |
| 96 | 86 | Mar | 26 | 2016 | 3097 | 10 | 3385 | 0 | 0 | 0 | 96 | 169 | 915 | 34 | | 3385 | 3241 | 3323.4 | -2.48% |
| 97 | 87 | Mar | 27 | 2016 | 3070 | 10 | 3395 | 0 | 0 | 0 | -63 | 175 | 334 | 34 | | 3395 | 3233 | 3323.4 | -2.74% |
| 98 | 88 | Mar | 28 | 2016 | 3079 | 8 | 3537 | 0 | 0 | 0 | 97 | 189 | 1491 | 0 | | 3537 | 3308 | 3323.4 | -0.46% |
| 99 | 89 | Mar | 29 | 2016 | 3049 | 21 | 3588 | 0 | 0 | 0 | 343 | 209 | 1618 | 0 | | 3588 | 3319 | 3323.4 | -0.15% |
| 100 | 90 | Mar | 30 | 2016 | 3078 | 17 | 3548 | 0 | 0 | 0 | 151 | 214 | 1316 | 45 | | 3548 | 3313 | 3323.4 | -0.31% |
| 101 | 91 | Mar | 31 | 2016 | 3138 | 8 | 3591 | 0 | 0 | 0 | -382 | 182 | 612 | 1 | | 3591 | 3365 | 3323.4 | 1.24% |

| A | B | C | D | P | Q | R | S | T | U | V | W | X | Y | AA | AB | AC | AD | AE | AF |
|-----|-------|-------|-----|------|--------------|-------------|---------------------|---------------|---------------|----------------|---------------|--------------|-------------------|---------------|----------------|--------------|-----------------|----------------|------------|
| 10 | Seq # | Month | Day | Year | Total Min | Hr @ Max | Max Sys Net Load | TOTAL EDDY | TOTAL BLKW | TOTAL LAMAR | TOTAL SWPP | TOTAL LPL | TOTAL TIE FLOW | TOTAL WIND | TOTAL SOLAR | Total Max | Average Load | Study Value | % Error |
| 11 | 92 | Apr | 1 | 2016 | 3202 | 11 | 3676.00 | 0 | 0 | 0 | -343 | 197 | 608 | 2 | | 3676 | 3439 | 3323.4 | 3.48% |
| 12 | 93 | Apr | 2 | 2016 | 3274 | 8 | 3628.00 | 0 | 0 | 0 | -548 | 185 | 339 | 1 | | 3628 | 3451 | 3323.4 | 3.84% |
| 104 | 94 | Apr | 3 | 2016 | 3186 | 22 | 3422.00 | 0 | 0 | 0 | -481 | 183 | 397 | 0 | | 3422 | 3304 | 3323.4 | -0.58% |
| 105 | 95 | Apr | 4 | 2016 | 3016 | 21 | 3637.00 | 0 | 0 | 0 | 248 | 221 | 1142 | 0 | | 3637 | 3327 | 3323.4 | 0.09% |
| 106 | 96 | Apr | 5 | 2016 | 3080 | 19 | 3681.00 | 0 | 0 | 0 | -104 | 216 | 1541 | 18 | | 3681 | 3381 | 3323.4 | 1.72% |
| 107 | 97 | Apr | 6 | 2016 | 3100 | 18 | 3631.00 | 0 | 0 | 0 | -737 | 213 | 226 | 26 | | 3631 | 3366 | 3323.4 | 1.27% |
| 108 | 98 | Apr | 7 | 2016 | 3133 | 21 | 3596.00 | 0 | 0 | 0 | -128 | 200 | 554 | 0 | | 3596 | 3365 | 3323.4 | 1.24% |
| 109 | 99 | Apr | 8 | 2016 | 3151 | 11 | 3555.00 | 0 | 0 | 0 | 109 | 185 | 493 | 9 | | 3555 | 3353 | 3323.4 | 0.89% |
| 110 | 100 | Apr | 9 | 2016 | 3155 | 18 | 3524.00 | 0 | 0 | 0 | -57 | 183 | 1235 | 39 | | 3524 | 3340 | 3323.4 | 0.48% |
| 111 | 101 | Apr | 10 | 2016 | 3118 | 21 | 3556.00 | 0 | 0 | 0 | -304 | 215 | 879 | 0 | | 3556 | 3337 | 3323.4 | 0.41% |
| 112 | 102 | Apr | 11 | 2016 | 3039 | 21 | 3618.00 | 0 | 0 | 0 | -352 | 200 | 439 | 0 | | 3618 | 3329 | 3323.4 | 0.15% |
| 113 | 103 | Apr | 12 | 2016 | 3199 | 22 | 3634.00 | 0 | 0 | 0 | -292 | 192 | 619 | 0 | | 3634 | 3417 | 3323.4 | 2.80% |
| 114 | 104 | Apr | 13 | 2016 | 3216 | 22 | 3557.00 | 0 | 0 | 0 | 156 | 194 | 911 | 0 | | 3557 | 3387 | 3323.4 | 1.90% |
| 115 | 105 | Apr | 14 | 2016 | 3076 | 17 | 3600.00 | 0 | 0 | -26 | 181 | 214 | 1185 | 43 | | 3600 | 3338 | 3323.4 | 0.44% |
| 116 | 106 | Apr | 15 | 2016 | 3033 | 16 | 3490.00 | 0 | 0 | 0 | 292 | 185 | 1413 | 42 | | 3490 | 3262 | 3323.4 | -1.86% |
| 117 | 107 | Apr | 16 | 2016 | 2971 | 17 | 3363.00 | 0 | 0 | 0 | 159 | 214 | 1125 | 44 | | 3363 | 3167 | 3323.4 | -4.71% |
| 118 | 108 | Apr | 17 | 2016 | 2941 | 22 | 3350.00 | 0 | 0 | 0 | 18 | 188 | 907 | 0 | | 3350 | 3146 | 3323.4 | -5.35% |
| 119 | 109 | Apr | 18 | 2016 | 2981 | 22 | 3444.00 | 0 | 0 | 0 | 193 | 189 | 554 | 0 | | 3444 | 3213 | 3323.4 | -3.34% |
| 120 | 110 | Apr | 19 | 2016 | 3033 | 12 | 3423.00 | 0 | 0 | 0 | 289 | 190 | 44 | 19 | | 3423 | 3228 | 3323.4 | -2.87% |
| 121 | 111 | Apr | 20 | 2016 | 2972 | 18 | 3475.00 | 0 | 0 | 0 | 429 | 215 | 349 | 40 | | 3475 | 3224 | 3323.4 | -3.01% |
| 122 | 112 | Apr | 21 | 2016 | 2940 | 18 | 3494.00 | 0 | 0 | 0 | -320 | 219 | 212 | 40 | | 3494 | 3217 | 3323.4 | -3.20% |
| 123 | 113 | Apr | 22 | 2016 | 2957 | 18 | 3617.00 | 41 | 0 | -1 | 406 | 235 | 542 | 39 | | 3617 | 3287 | 3323.4 | -1.10% |
| 124 | 114 | Apr | 23 | 2016 | 2982 | 18 | 3570.00 | 42 | 0 | 0 | 187 | 224 | 1559 | 34 | | 3570 | 3276 | 3323.4 | -1.43% |
| 125 | 115 | Apr | 24 | 2016 | 2971 | 19 | 3638.00 | -41 | 0 | 0 | 227 | 246 | 1127 | 31 | | 3638 | 3305 | 3323.4 | -0.57% |
| 126 | 116 | Apr | 25 | 2016 | 2932 | 18 | 3920.00 | 0 | 0 | 0 | 957 | 271 | 1061 | 41 | | 3920 | 3426 | 3323.4 | 3.09% |
| 127 | 117 | Apr | 26 | 2016 | 3064 | 15 | 3659.00 | 0 | 0 | 0 | 647 | 238 | 885 | 38 | | 3659 | 3362 | 3323.4 | 1.15% |
| 128 | 118 | Apr | 27 | 2016 | 3023 | 18 | 3686.00 | 0 | 0 | 0 | -200 | 239 | 176 | 41 | | 3686 | 3355 | 3323.4 | 0.94% |
| 129 | 119 | Apr | 28 | 2016 | 3051 | 18 | 3755.00 | 0 | 0 | 0 | 650 | 242 | 1377 | 41 | | 3755 | 3403 | 3323.4 | 2.40% |
| 130 | 120 | Apr | 29 | 2016 | 3076 | 17 | 3531.00 | 0 | 0 | 0 | 31 | 228 | 450 | 35 | | 3531 | 3304 | 3323.4 | -0.60% |
| 131 | 121 | Apr | 30 | 2016 | 3018 | 18 | 3374.00 | 0 | 0 | 0 | 112 | 202 | 434 | 35 | | 3374 | 3196 | 3323.4 | -3.83% |

| | A | B | C | D | P | Q | R | S | T | U | V | W | X | Y | AA | AB | AC | AD | AE | AF |
|-----|-------|-------|-----|------|-------|------|----------|-------|-------|-------|-------|----------|-------|-------|----|-------|---------|--------|--------|----|
| | | | | | Total | Hr @ | Max Sys | TOTAL | TOTAL | TOTAL | TOTAL | TOTAL | TOTAL | TOTAL | | Total | Average | Study | % | |
| 10 | Seq # | Month | Day | Year | Min | Max | Net Load | EDDY | BLKW | LAMAR | SWPP | LPL | WIND | SOLAR | | Max | Load | Value | Error | |
| 11 | | | | | | | | | | | | TIE FLOW | | | | | | | | |
| 12 | | | | | | | | | | | | | | | | | | | | |
| 134 | 122 | May | 1 | 2016 | 2988 | 22 | 3430.00 | 0 | 0 | 0 | 333 | 183 | 467 | 0 | | 3430 | 3209 | 3323.4 | -3.44% | |
| 135 | 123 | May | 2 | 2016 | 3046 | 22 | 3419.00 | 0 | 0 | 0 | 324 | 194 | 37 | 2 | | 3419 | 3233 | 3323.4 | -2.74% | |
| 136 | 124 | May | 3 | 2016 | 2992 | 17 | 3392.00 | 0 | 0 | 0 | 172 | 191 | 931 | 36 | | 3392 | 3192 | 3323.4 | -3.95% | |
| 137 | 125 | May | 4 | 2016 | 2947 | 19 | 3691.00 | 0 | 0 | 0 | -19 | 240 | -4 | 35 | | 3691 | 3319 | 3323.4 | -0.13% | |
| 138 | 126 | May | 5 | 2016 | 2986 | 18 | 3943.00 | 0 | 0 | 0 | 576 | 282 | 444 | 39 | | 3943 | 3465 | 3323.4 | 4.25% | |
| 139 | 127 | May | 6 | 2016 | 3080 | 18 | 3940.00 | 0 | 0 | 0 | 482 | 256 | 1614 | 33 | | 3940 | 3510 | 3323.4 | 5.61% | |
| 140 | 128 | May | 7 | 2016 | 3130 | 18 | 4001.00 | 0 | 0 | 0 | 347 | 278 | 1560 | 34 | | 4001 | 3566 | 3323.4 | 7.28% | |
| 141 | 129 | May | 8 | 2016 | 3079 | 18 | 3786.00 | 0 | 0 | 0 | 245 | 260 | 1521 | 32 | | 3786 | 3433 | 3323.4 | 3.28% | |
| 142 | 130 | May | 9 | 2016 | 3043 | 19 | 3882.00 | 0 | 0 | 0 | -3 | 254 | 473 | 33 | | 3882 | 3463 | 3323.4 | 4.19% | |
| 143 | 131 | May | 10 | 2016 | 3122 | 18 | 4313.00 | 0 | 0 | 0 | 702 | 298 | 1173 | 40 | | 4313 | 3718 | 3323.4 | 11.86% | |
| 144 | 132 | May | 11 | 2016 | 3236 | 18 | 4194.00 | 0 | 0 | 0 | -41 | 304 | 238 | 17 | | 4194 | 3715 | 3323.4 | 11.78% | |
| 145 | 133 | May | 12 | 2016 | 3187 | 19 | 3947.00 | 0 | 0 | 0 | 371 | 251 | 95 | 26 | | 3947 | 3567 | 3323.4 | 7.33% | |
| 146 | 134 | May | 13 | 2016 | 3226 | 17 | 4232.00 | 0 | 0 | 0 | -428 | 299 | 452 | 40 | | 4232 | 3729 | 3323.4 | 12.20% | |
| 147 | 135 | May | 14 | 2016 | 3159 | 1 | 3436.00 | 0 | 0 | -110 | -75 | 170 | 1099 | 0 | | 3436 | 3298 | 3323.4 | -0.78% | |
| 148 | 136 | May | 15 | 2016 | 2980 | 22 | 3388.00 | 0 | 0 | 0 | 127 | 183 | 902 | 0 | | 3388 | 3184 | 3323.4 | -4.19% | |
| 149 | 137 | May | 16 | 2016 | 2979 | 19 | 3736.00 | 0 | 0 | 0 | 484 | 264 | 1051 | 26 | | 3736 | 3358 | 3323.4 | 1.03% | |
| 150 | 138 | May | 17 | 2016 | 3010 | 12 | 3384.00 | 0 | 0 | 0 | 129 | 189 | 1350 | 9 | | 3384 | 3197 | 3323.4 | -3.80% | |
| 151 | 139 | May | 18 | 2016 | 2937 | 11 | 3283.00 | 0 | 0 | 0 | -30 | 193 | 173 | 4 | | 3283 | 3110 | 3323.4 | -6.42% | |
| 152 | 140 | May | 19 | 2016 | 2877 | 12 | 3210.00 | 0 | 0 | 0 | -182 | 190 | 303 | 11 | | 3210 | 3044 | 3323.4 | -8.42% | |
| 153 | 141 | May | 20 | 2016 | 2817 | 19 | 3497.00 | 0 | 0 | 0 | 308 | 211 | 1148 | 31 | | 3497 | 3157 | 3323.4 | -5.01% | |
| 154 | 142 | May | 21 | 2016 | 2867 | 18 | 3718.00 | 0 | 0 | 0 | 162 | 262 | 1488 | 37 | | 3718 | 3293 | 3323.4 | -0.93% | |
| 155 | 143 | May | 22 | 2016 | 2877 | 18 | 3795.00 | 0 | 0 | -126 | 121 | 288 | 1229 | 35 | | 3795 | 3336 | 3323.4 | 0.38% | |
| 156 | 144 | May | 23 | 2016 | 2860 | 18 | 4159.00 | 0 | 0 | 0 | -432 | 310 | 457 | 36 | | 4159 | 3510 | 3323.4 | 5.60% | |
| 157 | 145 | May | 24 | 2016 | 3055 | 17 | 4222.00 | 0 | 0 | 0 | -42 | 324 | 1031 | 20 | | 4222 | 3639 | 3323.4 | 9.48% | |
| 158 | 146 | May | 25 | 2016 | 3058 | 18 | 4327.00 | 0 | 0 | 0 | 614 | 332 | 1022 | 37 | | 4327 | 3693 | 3323.4 | 11.11% | |
| 159 | 147 | May | 26 | 2016 | 3145 | 18 | 4300.00 | 0 | 0 | 0 | 153 | 302 | 1568 | 33 | | 4300 | 3723 | 3323.4 | 12.01% | |
| 160 | 148 | May | 27 | 2016 | 3101 | 18 | 3970.00 | 0 | 0 | 0 | 51 | 265 | 734 | 38 | | 3970 | 3536 | 3323.4 | 6.38% | |
| 161 | 149 | May | 28 | 2016 | 3077 | 18 | 4069.00 | 0 | 0 | 26 | 232 | 284 | 118 | 38 | | 4069 | 3573 | 3323.4 | 7.51% | |
| 162 | 150 | May | 29 | 2016 | 3079 | 16 | 3756.00 | 0 | 0 | 0 | 509 | 268 | 1145 | 15 | | 3756 | 3418 | 3323.4 | 2.83% | |
| 163 | 151 | May | 30 | 2016 | 2875 | 18 | 3831.00 | 0 | 0 | 0 | 207 | 275 | 772 | 11 | | 3831 | 3353 | 3323.4 | 0.89% | |
| 164 | 152 | May | 31 | 2016 | 2939 | 17 | 3790.00 | 0 | 0 | 0 | -83 | 269 | 189 | 28 | | 3790 | 3365 | 3323.4 | 1.24% | |

| | A | B | C | D | P | Q | R | S | T | U | V | W | X | Y | AA | AB | AC | AD | AE | AF | |
|-----|-------|-------|-----|------|--------------|-------------|---------------------|---------------|---------------|----------------|---------------|--------------|-------------------|---------------|----------------|----|--------------|-----------------|----------------|------------|--|
| | Seq # | Month | Day | Year | Total Min | Hr @ Max | Max Sys Net Load | TOTAL EDDY | TOTAL BLKW | TOTAL LAMAR | TOTAL SWPP | TOTAL LPL | TOTAL TIE FLOW | TOTAL WIND | TOTAL SOLAR | | Total Max | Average Load | Study Value | % Error | |
| 10 | | | | | | | | | | | | | | | | | | | | | |
| 11 | | | | | | | | | | | | | | | | | | | | | |
| 12 | | | | | | | | | | | | | | | | | | | | | |
| 165 | 153 | Jun | 1 | 2016 | 2881 | 16 | 3373.00 | 0 | 0 | 0 | 130 | 190 | 482 | 31 | 31 | | 3373 | 3127 | 4432.1 | -29.45% | |
| 166 | 154 | Jun | 2 | 2016 | 2804 | 17 | 3509.00 | 0 | 0 | 0 | 152 | 222 | 314 | 18 | 18 | | 3509 | 3157 | 4432.1 | -28.78% | |
| 167 | 155 | Jun | 3 | 2016 | 2860 | 18 | 3888.00 | 0 | 0 | 0 | -160 | 265 | 104 | 37 | 37 | | 3888 | 3374 | 4432.1 | -23.87% | |
| 168 | 156 | Jun | 4 | 2016 | 2904 | 18 | 3820.00 | 0 | 0 | 0 | -418 | 261 | 484 | 17 | 17 | | 3820 | 3362 | 4432.1 | -24.14% | |
| 169 | 157 | Jun | 5 | 2016 | 2858 | 18 | 4002.00 | 0 | 0 | 49 | 287 | 298 | 75 | 36 | 36 | | 4002 | 3430 | 4432.1 | -22.61% | |
| 170 | 158 | Jun | 6 | 2016 | 2954 | 17 | 4290.00 | 51 | 0 | 86 | 252 | 310 | 285 | 20 | 20 | | 4290 | 3622 | 4432.1 | -18.28% | |
| 171 | 159 | Jun | 7 | 2016 | 3085 | 17 | 4383.00 | 40 | 0 | 101 | 888 | 269 | 1015 | 41 | 41 | | 4383 | 3734 | 4432.1 | -15.75% | |
| 172 | 160 | Jun | 8 | 2016 | 3122 | 18 | 4499.00 | 50 | 0 | 0 | 426 | 320 | 1416 | 39 | 39 | | 4499 | 3811 | 4432.1 | -14.02% | |
| 173 | 161 | Jun | 9 | 2016 | 3246 | 17 | 4623.00 | 50 | 0 | 0 | 420 | 327 | 1232 | 40 | 40 | | 4623 | 3935 | 4432.1 | -11.23% | |
| 174 | 162 | Jun | 10 | 2016 | 3146 | 17 | 4604.00 | 50 | 0 | 0 | 409 | 280 | 824 | 38 | 38 | | 4604 | 3875 | 4432.1 | -12.57% | |
| 175 | 163 | Jun | 11 | 2016 | 3323 | 17 | 4438.00 | 0 | 0 | 0 | 598 | 267 | 783 | 22 | 22 | | 4438 | 3881 | 4432.1 | -12.45% | |
| 176 | 164 | Jun | 12 | 2016 | 3145 | 18 | 4489.00 | 0 | 0 | 0 | 320 | 262 | 353 | 30 | 30 | | 4489 | 3817 | 4432.1 | -13.88% | |
| 177 | 165 | Jun | 13 | 2016 | 3360 | 17 | 4823.00 | 40 | 0 | 0 | 29 | 300 | 403 | 22 | 22 | | 4823 | 4092 | 4432.1 | -7.68% | |
| 178 | 166 | Jun | 14 | 2016 | 3342 | 18 | 4830.00 | 40 | 0 | 0 | 57 | 310 | 343 | 30 | 30 | | 4830 | 4086 | 4432.1 | -7.81% | |
| 179 | 167 | Jun | 15 | 2016 | 3500 | 17 | 5057.00 | 40 | 0 | 0 | 398 | 333 | 735 | 13 | 13 | | 5057 | 4279 | 4432.1 | -3.47% | |
| 180 | 168 | Jun | 16 | 2016 | 3370 | 17 | 5076.00 | 40 | 0 | 0 | 470 | 309 | 969 | 32 | 32 | | 5076 | 4223 | 4432.1 | -4.72% | |
| 181 | 169 | Jun | 17 | 2016 | 3634 | 17 | 5219.00 | 40 | 0 | 0 | -293 | 354 | 145 | 31 | 31 | | 5219 | 4427 | 4432.1 | -0.13% | |
| 182 | 170 | Jun | 18 | 2016 | 3643 | 18 | 5005.00 | 40 | 0 | 0 | -160 | 324 | 269 | 29 | 29 | | 5005 | 4324 | 4432.1 | -2.44% | |
| 183 | 171 | Jun | 19 | 2016 | 3622 | 18 | 4698.00 | 40 | 0 | 0 | -300 | 307 | 410 | 24 | 24 | | 4698 | 4160 | 4432.1 | -6.14% | |
| 184 | 172 | Jun | 20 | 2016 | 3583 | 17 | 5021.00 | 47 | 0 | 0 | -545 | 297 | 507 | 29 | 29 | | 5021 | 4302 | 4432.1 | -2.94% | |
| 185 | 173 | Jun | 21 | 2016 | 3661 | 18 | 5114.00 | 81 | 0 | 0 | 131 | 276 | 803 | 25 | 25 | | 5114 | 4388 | 4432.1 | -1.01% | |
| 186 | 174 | Jun | 22 | 2016 | 3805 | 18 | 5448.00 | 40 | 0 | 0 | -393 | 335 | 218 | 29 | 29 | | 5448 | 4627 | 4432.1 | 4.39% | |
| 187 | 175 | Jun | 23 | 2016 | 3872 | 17 | 5384.00 | 70 | 0 | 0 | 28 | 319 | 337 | 32 | 32 | | 5384 | 4628 | 4432.1 | 4.42% | |
| 188 | 176 | Jun | 24 | 2016 | 3865 | 18 | 5232.00 | 70 | 0 | 0 | 362 | 277 | 1315 | 30 | 30 | | 5232 | 4549 | 4432.1 | 2.63% | |
| 189 | 177 | Jun | 25 | 2016 | 3833 | 18 | 5113.00 | 40 | 0 | 0 | 19 | 264 | 1283 | 30 | 30 | | 5113 | 4473 | 4432.1 | 0.92% | |
| 190 | 178 | Jun | 26 | 2016 | 3719 | 16 | 4618.00 | 0 | 0 | 50 | 623 | 250 | 252 | 27 | 27 | | 4618 | 4169 | 4432.1 | -5.95% | |
| 191 | 179 | Jun | 27 | 2016 | 3615 | 17 | 5026.00 | 0 | 0 | 0 | 94 | 284 | 139 | 18 | 18 | | 5026 | 4321 | 4432.1 | -2.52% | |
| 192 | 180 | Jun | 28 | 2016 | 3748 | 17 | 5218.00 | 0 | 0 | 0 | -181 | 355 | 53 | 39 | 39 | | 5218 | 4483 | 4432.1 | 1.15% | |
| 193 | 181 | Jun | 29 | 2016 | 3806 | 18 | 5304.00 | 40 | 0 | 0 | 3 | 298 | 129 | 35 | 35 | | 5304 | 4555 | 4432.1 | 2.77% | |
| 194 | 182 | Jun | 30 | 2016 | 3854 | 17 | 5227.00 | 40 | 0 | 0 | 141 | 276 | 553 | 48 | 48 | | 5227 | 4541 | 4432.1 | 2.45% | |

| | A | B | C | D | P | Q | R | S | T | U | V | W | X | Y | AA | AB | AC | AD | AE | AF |
|-----|-------|-------|-----|------|-------|------|----------|-------|-------|-------|-------|----------|-------|-------|----|-------|---------|--------|--------|----|
| 10 | | | | | Total | Hr @ | Max Sys | Total | Total | Total | Total | Total | Total | TOTAL | | Total | Average | Study | % | |
| 11 | Seq # | Month | Day | Year | Min | Max | Net Load | EDDY | BLKW | LAMAR | SWPP | LPL | WIND | SOLAR | | Max | Load | Value | Error | |
| 12 | | | | | | | | | | | | TIE FLOW | | | | | | | | |
| 195 | 183 | Jul | 1 | 2016 | 3789 | 17 | 5077.00 | 40 | 0 | 0 | 8 | 276 | 1023 | 30 | | 5077 | 4433 | 4432.1 | 0.02% | |
| 196 | 184 | Jul | 2 | 2016 | 3834 | 19 | 4997.00 | 40 | 0 | 0 | -199 | 292 | 865 | 33 | | 4997 | 4416 | 4432.1 | -0.37% | |
| 197 | 185 | Jul | 3 | 2016 | 3738 | 18 | 5024.00 | 40 | 0 | 27 | -721 | 284 | 33 | 33 | | 5024 | 4381 | 4432.1 | -1.15% | |
| 198 | 186 | Jul | 4 | 2016 | 3701 | 18 | 5277.00 | 40 | 0 | 0 | -349 | 309 | 49 | 25 | | 5277 | 4489 | 4432.1 | 1.28% | |
| 199 | 187 | Jul | 5 | 2016 | 3934 | 17 | 5604.00 | 70 | 0 | 0 | -291 | 326 | 318 | 26 | | 5604 | 4769 | 4432.1 | 7.60% | |
| 200 | 188 | Jul | 6 | 2016 | 3997 | 16 | 5647.00 | 100 | 0 | 0 | -498 | 328 | 446 | 23 | | 5647 | 4822 | 4432.1 | 8.80% | |
| 201 | 189 | Jul | 7 | 2016 | 4054 | 17 | 5735.00 | 70 | 0 | 0 | -722 | 348 | 180 | 10 | | 5735 | 4895 | 4432.1 | 10.43% | |
| 202 | 190 | Jul | 8 | 2016 | 4220 | 18 | 5136.00 | 70 | 0 | 0 | 307 | 277 | 994 | 32 | | 5136 | 4678 | 4432.1 | 5.55% | |
| 203 | 191 | Jul | 9 | 2016 | 3958 | 18 | 5499.00 | 40 | 0 | 0 | -25 | 294 | 460 | 29 | | 5499 | 4729 | 4432.1 | 6.69% | |
| 204 | 192 | Jul | 10 | 2016 | 4091 | 17 | 5534.00 | 70 | 0 | 0 | 708 | 295 | 1043 | 46 | | 5534 | 4813 | 4432.1 | 8.58% | |
| 205 | 193 | Jul | 11 | 2016 | 4245 | 17 | 5849.00 | 100 | 0 | 0 | 149 | 345 | 1021 | 36 | | 5849 | 5047 | 4432.1 | 13.87% | |
| 206 | 194 | Jul | 12 | 2016 | 4309 | 18 | 5917.00 | 100 | 0 | 0 | -557 | 355 | 148 | 49 | | 5917 | 5113 | 4432.1 | 15.36% | |
| 207 | 195 | Jul | 13 | 2016 | 4366 | 17 | 6003.00 | 100 | 0 | 0 | -654 | 367 | 105 | 42 | | 6003 | 5185 | 4432.1 | 16.98% | |
| 208 | 196 | Jul | 14 | 2016 | 4373 | 16 | 5772.00 | 100 | 0 | 0 | -772 | 333 | 501 | 38 | | 5772 | 5073 | 4432.1 | 14.45% | |
| 209 | 197 | Jul | 15 | 2016 | 4061 | 17 | 5624.00 | 100 | 0 | 0 | -181 | 305 | 739 | 55 | | 5624 | 4843 | 4432.1 | 9.26% | |
| 210 | 198 | Jul | 16 | 2016 | 3881 | 18 | 5410.00 | 100 | 0 | 0 | -122 | 328 | 1241 | 56 | | 5410 | 4646 | 4432.1 | 4.81% | |
| 211 | 199 | Jul | 17 | 2016 | 4035 | 18 | 5467.00 | 100 | 0 | 0 | 167 | 303 | 1220 | 52 | | 5467 | 4751 | 4432.1 | 7.20% | |
| 212 | 200 | Jul | 18 | 2016 | 4085 | 17 | 5654.00 | 0 | 0 | 0 | 400 | 305 | 697 | 60 | | 5654 | 4870 | 4432.1 | 9.87% | |
| 213 | 201 | Jul | 19 | 2016 | 4168 | 18 | 5635.00 | 34 | 0 | 0 | 113 | 338 | 682 | 59 | | 5635 | 4902 | 4432.1 | 10.59% | |
| 214 | 202 | Jul | 20 | 2016 | 4226 | 18 | 5746.00 | 100 | 0 | 0 | -70 | 337 | 863 | 55 | | 5746 | 4986 | 4432.1 | 12.50% | |
| 215 | 203 | Jul | 21 | 2016 | 4325 | 17 | 5842.00 | 0 | 0 | 0 | -156 | 385 | 634 | 60 | | 5842 | 5084 | 4432.1 | 14.70% | |
| 216 | 204 | Jul | 22 | 2016 | 4299 | 18 | 5812.00 | 100 | -16 | 0 | 277 | 307 | 752 | 68 | | 5812 | 5056 | 4432.1 | 14.07% | |
| 217 | 205 | Jul | 23 | 2016 | 4207 | 18 | 5699.00 | 75 | -16 | 0 | 111 | 320 | 690 | 69 | | 5699 | 4953 | 4432.1 | 11.75% | |
| 218 | 206 | Jul | 24 | 2016 | 4172 | 18 | 5665.00 | 40 | -16 | 0 | 159 | 310 | 476 | 76 | | 5665 | 4919 | 4432.1 | 10.97% | |
| 219 | 207 | Jul | 25 | 2016 | 4223 | 16 | 5726.00 | 75 | -16 | 0 | -81 | 339 | 230 | 58 | | 5726 | 4975 | 4432.1 | 12.24% | |
| 220 | 208 | Jul | 26 | 2016 | 4209 | 17 | 5639.00 | 133 | -16 | 0 | -250 | 324 | 133 | 24 | | 5639 | 4924 | 4432.1 | 11.10% | |
| 221 | 209 | Jul | 27 | 2016 | 4197 | 16 | 5440.00 | 133 | 89 | 0 | -30 | 363 | 585 | 78 | | 5440 | 4819 | 4432.1 | 8.72% | |
| 222 | 210 | Jul | 28 | 2016 | 4100 | 18 | 5651.00 | 133 | 194 | 0 | -303 | 310 | 172 | 60 | | 5651 | 4876 | 4432.1 | 10.00% | |
| 223 | 211 | Jul | 29 | 2016 | 4217 | 17 | 5489.00 | 0 | 153 | 0 | 414 | 325 | 837 | 88 | | 5489 | 4853 | 4432.1 | 9.50% | |
| 224 | 212 | Jul | 30 | 2016 | 4032 | 18 | 5386.00 | 0 | 13 | 0 | 7 | 311 | 961 | 88 | | 5386 | 4709 | 4432.1 | 6.25% | |
| 225 | 213 | Jul | 31 | 2016 | 4066 | 18 | 5362.00 | 0 | -24 | 0 | 255 | 327 | 1265 | 27 | | 5362 | 4714 | 4432.1 | 6.36% | |

| A | B | C | D | P | Q | R | S | T | U | V | W | X | Y | AA | AB | AC | AD | AE | AF |
|-------|-------|-----|------|--------------|-------------|---------------------|---------------|---------------|----------------|---------------|--------------|---------------|----------------|----|--------------|-----------------|----------------|------------|----|
| Seq # | Month | Day | Year | Total Min | Hr @ Max | Max Sys Net Load | TOTAL EDDY | TOTAL BLKW | TOTAL LAMAR | TOTAL SWPP | TOTAL LPL | TOTAL WIND | TOTAL SOLAR | | Total Max | Average Load | Study Value | % Error | |
| 12 | | | | | | | | | | | | | | | | | | | |
| 226 | Aug | 1 | 2016 | 4145 | 17 | 5704.00 | 40 | -21 | 0 | 72 | 323 | 993 | 43 | | 5704 | 4925 | 4432.1 | 11.11% | |
| 227 | Aug | 2 | 2016 | 4275 | 17 | 5801.00 | 75 | -32 | 0 | 210 | 336 | 538 | 92 | | 5801 | 5038 | 4432.1 | 13.67% | |
| 228 | Aug | 3 | 2016 | 4098 | 17 | 5611.00 | 0 | 14 | 0 | 400 | 336 | 818 | 93 | | 5611 | 4855 | 4432.1 | 9.53% | |
| 229 | Aug | 4 | 2016 | 4229 | 17 | 5790.00 | 0 | 13 | 0 | -117 | 359 | 749 | 105 | | 5790 | 5010 | 4432.1 | 13.03% | |
| 230 | Aug | 5 | 2016 | 4220 | 17 | 5677.00 | 0 | 14 | 0 | -352 | 360 | 224 | 106 | | 5677 | 4949 | 4432.1 | 11.65% | |
| 231 | Aug | 6 | 2016 | 4165 | 18 | 5519.00 | 0 | -16 | 0 | -18 | 334 | 651 | 52 | | 5519 | 4842 | 4432.1 | 9.25% | |
| 232 | Aug | 7 | 2016 | 4106 | 16 | 5417.00 | 0 | -21 | 0 | 37 | 301 | 407 | 107 | | 5417 | 4762 | 4432.1 | 7.43% | |
| 233 | Aug | 8 | 2016 | 4096 | 16 | 5510.00 | 35 | -22 | 0 | -43 | 318 | 683 | 65 | | 5510 | 4803 | 4432.1 | 8.37% | |
| 234 | Aug | 9 | 2016 | 3994 | 17 | 5326.00 | 40 | 14 | 174 | 86 | 328 | 598 | 35 | | 5326 | 4660 | 4432.1 | 5.14% | |
| 235 | Aug | 10 | 2016 | 4030 | 16 | 5452.00 | 40 | 13 | 0 | -260 | 306 | 675 | 78 | | 5452 | 4741 | 4432.1 | 6.97% | |
| 236 | Aug | 11 | 2016 | 4096 | 16 | 5504.00 | 40 | 14 | 100 | -93 | 330 | 558 | 20 | | 5504 | 4800 | 4432.1 | 8.30% | |
| 237 | Aug | 12 | 2016 | 3967 | 17 | 5196.00 | 40 | -22 | 0 | 101 | 326 | 786 | 69 | | 5196 | 4582 | 4432.1 | 3.37% | |
| 238 | Aug | 13 | 2016 | 3787 | 17 | 4830.00 | 40 | -22 | 0 | -322 | 275 | 326 | 17 | | 4830 | 4309 | 4432.1 | -2.79% | |
| 239 | Aug | 14 | 2016 | 3704 | 18 | 4467.00 | 40 | -14 | 0 | -177 | 205 | 130 | 52 | | 4467 | 4086 | 4432.1 | -7.82% | |
| 240 | Aug | 15 | 2016 | 3683 | 18 | 5181.00 | 40 | 54 | 0 | -325 | 294 | 186 | 88 | | 5181 | 4432 | 4432.1 | 0.00% | |
| 241 | Aug | 16 | 2016 | 3869 | 17 | 5344.00 | 40 | -14 | 0 | -307 | 298 | 174 | 93 | | 5344 | 4607 | 4432.1 | 3.93% | |
| 242 | Aug | 17 | 2016 | 3911 | 17 | 5325.00 | 40 | 61 | 0 | -166 | 298 | 263 | 86 | | 5325 | 4618 | 4432.1 | 4.19% | |
| 243 | Aug | 18 | 2016 | 3999 | 17 | 5379.00 | 40 | -22 | 0 | -191 | 303 | 183 | 92 | | 5379 | 4689 | 4432.1 | 5.80% | |
| 244 | Aug | 19 | 2016 | 4024 | 17 | 5355.00 | 40 | -16 | 0 | -830 | 363 | 160 | 40 | | 5355 | 4690 | 4432.1 | 5.81% | |
| 245 | Aug | 20 | 2016 | 3867 | 18 | 4405.00 | 0 | -21 | 26 | -627 | 203 | 41 | 61 | | 4405 | 4136 | 4432.1 | -6.68% | |
| 246 | Aug | 21 | 2016 | 3646 | 18 | 4388.00 | 0 | 13 | 0 | -158 | 232 | 589 | 53 | | 4388 | 4017 | 4432.1 | -9.37% | |
| 247 | Aug | 22 | 2016 | 3616 | 18 | 4806.00 | 0 | 14 | 0 | -201 | 265 | 1154 | 36 | | 4806 | 4211 | 4432.1 | -4.99% | |
| 248 | Aug | 23 | 2016 | 3850 | 17 | 5117.00 | 40 | 14 | 0 | -72 | 293 | 927 | 27 | | 5117 | 4484 | 4432.1 | 1.16% | |
| 249 | Aug | 24 | 2016 | 3675 | 17 | 4541.00 | 75 | -16 | 26 | 472 | 248 | 744 | 83 | | 4541 | 4108 | 4432.1 | -7.31% | |
| 250 | Aug | 25 | 2016 | 3552 | 17 | 4542.00 | 75 | -21 | 51 | 457 | 239 | 212 | 25 | | 4542 | 4047 | 4432.1 | -8.69% | |
| 251 | Aug | 26 | 2016 | 3426 | 17 | 4475.00 | 0 | -21 | 0 | -36 | 251 | 226 | 44 | | 4475 | 3951 | 4432.1 | -10.87% | |
| 252 | Aug | 27 | 2016 | 3393 | 17 | 4483.00 | 0 | -41 | 0 | 599 | 288 | 441 | 86 | | 4483 | 3938 | 4432.1 | -11.15% | |
| 253 | Aug | 28 | 2016 | 3284 | 17 | 4333.00 | 0 | -125 | 76 | 154 | 287 | 271 | 81 | | 4333 | 3809 | 4432.1 | -14.07% | |
| 254 | Aug | 29 | 2016 | 3157 | 15 | 3879.00 | 0 | -46 | 0 | 489 | 229 | 225 | 74 | | 3879 | 3518 | 4432.1 | -20.62% | |
| 255 | Aug | 30 | 2016 | 3086 | 16 | 3687.00 | 0 | -43 | 0 | 949 | 235 | 50 | 43 | | 3687 | 3387 | 4432.1 | -23.59% | |
| 256 | Aug | 31 | 2016 | 2977 | 15 | 3622.00 | 0 | -70 | 0 | 425 | 238 | 39 | 57 | | 3622 | 3300 | 4432.1 | -25.55% | |

| A | B | C | D | P | Q | R | S | T | U | V | W | X | Y | AA | AB | AC | AD | AE | AF |
|-------|-------|-----|------|-------|------|---------|---------|------|-------|------|------|-------|------|-------|------|---------|--------|--------|-------|
| Seq # | Month | Day | Year | Total | Hr @ | Max Sys | TOTAL | BLKW | LAMAR | SWPP | LPL | TOTAL | WIND | TOTAL | Max | Average | Study | % | Error |
| 11 | 245 | Sep | 1 | 2016 | 2918 | 18 | 3858.00 | 0 | 166 | 0 | -498 | 299 | 144 | 89 | 3858 | 3388 | 3386.9 | 0.03% | |
| 12 | 246 | Sep | 2 | 2016 | 2962 | 17 | 3940.00 | 0 | 150 | 0 | -143 | 293 | 395 | 96 | 3940 | 3451 | 3386.9 | 1.89% | |
| 257 | 247 | Sep | 3 | 2016 | 3034 | 17 | 3962.00 | 0 | 14 | -50 | -368 | 277 | 1141 | 36 | 3962 | 3498 | 3386.9 | 3.28% | |
| 258 | 248 | Sep | 4 | 2016 | 3028 | 17 | 3990.00 | 0 | 72 | -50 | -133 | 209 | 1388 | 99 | 3990 | 3509 | 3386.9 | 3.61% | |
| 259 | 249 | Sep | 5 | 2016 | 3017 | 18 | 4129.00 | 0 | -30 | -75 | -147 | 245 | 1387 | 89 | 4129 | 3573 | 3386.9 | 5.50% | |
| 260 | 250 | Sep | 6 | 2016 | 3036 | 17 | 4229.00 | 0 | -15 | 0 | -488 | 270 | 987 | 16 | 4229 | 3633 | 3386.9 | 7.25% | |
| 261 | 251 | Sep | 7 | 2016 | 3047 | 18 | 4054.00 | 0 | -30 | 0 | -196 | 230 | 1110 | 71 | 4054 | 3551 | 3386.9 | 4.83% | |
| 262 | 252 | Sep | 8 | 2016 | 3078 | 17 | 4344.00 | 0 | -15 | 0 | -597 | 283 | 385 | 101 | 4344 | 3711 | 3386.9 | 9.57% | |
| 263 | 253 | Sep | 9 | 2016 | 3062 | 17 | 4479.00 | 0 | -16 | 0 | -820 | 293 | 66 | 89 | 4479 | 3771 | 3386.9 | 11.33% | |
| 264 | 254 | Sep | 10 | 2016 | 2921 | 18 | 3583.00 | 0 | -64 | 84 | -106 | 259 | 70 | 91 | 3583 | 3252 | 3386.9 | -3.98% | |
| 265 | 255 | Sep | 11 | 2016 | 2838 | 18 | 3857.00 | 0 | -16 | -119 | -619 | 232 | 901 | 78 | 3857 | 3348 | 3386.9 | -1.16% | |
| 266 | 256 | Sep | 12 | 2016 | 2933 | 17 | 4173.00 | 0 | 97 | 0 | -387 | 311 | 524 | 43 | 4173 | 3553 | 3386.9 | 4.90% | |
| 267 | 257 | Sep | 13 | 2016 | 2979 | 17 | 3901.00 | 0 | -17 | 26 | -141 | 304 | 133 | 102 | 3901 | 3440 | 3386.9 | 1.57% | |
| 268 | 258 | Sep | 14 | 2016 | 2952 | 17 | 3765.00 | 0 | -48 | 119 | -40 | 269 | 400 | 58 | 3765 | 3359 | 3386.9 | -0.84% | |
| 269 | 259 | Sep | 15 | 2016 | 2980 | 18 | 3834.00 | 0 | -16 | 0 | -432 | 250 | 704 | 18 | 3834 | 3407 | 3386.9 | 0.59% | |
| 270 | 260 | Sep | 16 | 2016 | 2776 | 18 | 3713.00 | 0 | -16 | 25 | -130 | 218 | 108 | 86 | 3713 | 3245 | 3386.9 | -4.20% | |
| 271 | 261 | Sep | 17 | 2016 | 2840 | 18 | 3648.00 | 0 | -16 | 76 | 161 | 196 | 665 | 53 | 3648 | 3244 | 3386.9 | -4.22% | |
| 272 | 262 | Sep | 18 | 2016 | 2825 | 18 | 4083.00 | 0 | -29 | 114 | 153 | 253 | 157 | 87 | 4083 | 3454 | 3386.9 | 1.98% | |
| 273 | 263 | Sep | 19 | 2016 | 2882 | 17 | 4357.00 | 0 | -16 | 103 | 367 | 294 | 172 | 87 | 4357 | 3620 | 3386.9 | 6.87% | |
| 274 | 264 | Sep | 20 | 2016 | 2981 | 17 | 4281.00 | 0 | -16 | -131 | -220 | 290 | 549 | 95 | 4281 | 3631 | 3386.9 | 7.21% | |
| 275 | 265 | Sep | 21 | 2016 | 3049 | 17 | 4202.00 | 0 | 90 | -191 | -127 | 275 | 1056 | 33 | 4202 | 3626 | 3386.9 | 7.05% | |
| 276 | 266 | Sep | 22 | 2016 | 3008 | 17 | 4193.00 | 0 | 95 | 0 | -71 | 268 | 1038 | 94 | 4193 | 3601 | 3386.9 | 6.31% | |
| 277 | 267 | Sep | 23 | 2016 | 3000 | 17 | 4157.00 | 0 | -16 | 0 | -173 | 281 | 1313 | 107 | 4157 | 3579 | 3386.9 | 5.66% | |
| 278 | 268 | Sep | 24 | 2016 | 3061 | 18 | 3782.00 | 0 | -16 | 0 | -383 | 210 | 395 | 105 | 3782 | 3422 | 3386.9 | 1.02% | |
| 279 | 269 | Sep | 25 | 2016 | 2915 | 21 | 3285.00 | 0 | 33 | 0 | -511 | 156 | 589 | 0 | 3285 | 3100 | 3386.9 | -8.47% | |
| 280 | 270 | Sep | 26 | 2016 | 2763 | 18 | 3396.00 | 0 | -15 | 0 | -517 | 160 | 30 | 14 | 3396 | 3080 | 3386.9 | -9.08% | |
| 281 | 271 | Sep | 27 | 2016 | 2867 | 18 | 3737.00 | 0 | 14 | 0 | -414 | 204 | 7 | 126 | 3737 | 3302 | 3386.9 | -2.51% | |
| 282 | 272 | Sep | 28 | 2016 | 2885 | 18 | 3949.00 | 0 | -16 | 0 | -589 | 285 | 100 | 122 | 3949 | 3417 | 3386.9 | 0.89% | |
| 283 | 273 | Sep | 29 | 2016 | 2931 | 17 | 3716.00 | 0 | -15 | 0 | -231 | 207 | 89 | 126 | 3716 | 3324 | 3386.9 | -1.87% | |
| 284 | 274 | Sep | 30 | 2016 | 2966 | 17 | 3681.00 | 0 | -16 | 0 | 63 | 199 | 911 | 146 | 3681 | 3324 | 3386.9 | -1.87% | |

| | A | B | C | D | P | Q | R | S | T | U | V | W | X | Y | AA | AB | AC | AD | AE | AF | |
|-----|-------|-------|-----|------|--------------|-------------|---------------------|---------------|---------------|----------------|---------------|--------------|-------------------|---------------|----------------|----|--------------|-----------------|----------------|------------|--|
| | Seq # | Month | Day | Year | Total Min | Hr @ Max | Max Sys Net Load | TOTAL EDDY | TOTAL BLKW | TOTAL LAMAR | TOTAL SWPP | TOTAL LPL | TOTAL TIE FLOW | TOTAL WIND | TOTAL SOLAR | | Total Max | Average Load | Study Value | % Error | |
| 10 | | | | | | | | | | | | | | | | | | | | | |
| 11 | | | | | | | | | | | | | | | | | | | | | |
| 12 | | | | | | | | | | | | | | | | | | | | | |
| 287 | 275 | Oct | 1 | 2016 | 3004 | 18 | 3826.00 | | 0 | 0 | -279 | 222 | 636 | 82 | | | 3826 | 3415 | 3386.9 | | |
| 288 | 276 | Oct | 2 | 2016 | 2977 | 18 | 3946.00 | | 0 | 0 | 28 | 283 | 985 | 102 | | | 3946 | 3462 | 3386.9 | 0.83% | |
| 289 | 277 | Oct | 3 | 2016 | 3001 | 18 | 4019.00 | | 0 | 0 | -34 | 224 | 1593 | 104 | | | 4019 | 3510 | 3386.9 | 2.20% | |
| 290 | 278 | Oct | 4 | 2016 | 3086 | 17 | 3909.00 | | 0 | 0 | 314 | 220 | 810 | 147 | | | 3909 | 3498 | 3386.9 | 3.64% | |
| 291 | 279 | Oct | 5 | 2016 | 2914 | 18 | 3849.00 | | 0 | 0 | 591 | 191 | 615 | 146 | | | 3849 | 3382 | 3386.9 | 3.27% | |
| 292 | 280 | Oct | 6 | 2016 | 3001 | 17 | 4026.00 | | 0 | 0 | 181 | 237 | 506 | 164 | | | 4026 | 3514 | 3386.9 | -0.16% | |
| 293 | 281 | Oct | 7 | 2016 | 2946 | 17 | 3364.00 | | 0 | 0 | -483 | 143 | 41 | 40 | | | 3364 | 3155 | 3386.9 | 3.74% | |
| 294 | 282 | Oct | 8 | 2016 | 2944 | 21 | 3322.00 | | 0 | 0 | -391 | 143 | 660 | 0 | | | 3322 | 3133 | 3386.9 | -6.85% | |
| 295 | 283 | Oct | 9 | 2016 | 2896 | 21 | 3365.00 | | 0 | 0 | -243 | 167 | 1196 | 0 | | | 3365 | 3131 | 3386.9 | -7.50% | |
| 296 | 284 | Oct | 10 | 2016 | 2827 | 18 | 3814.00 | | 0 | 0 | -829 | 213 | 250 | 123 | | | 3814 | 3321 | 3386.9 | -7.57% | |
| 297 | 285 | Oct | 11 | 2016 | 2939 | 17 | 4036.00 | | 0 | 0 | -349 | 247 | 726 | 155 | | | 4036 | 3488 | 3386.9 | -1.96% | |
| 298 | 286 | Oct | 12 | 2016 | 2998 | 17 | 3490.00 | | 0 | 0 | -671 | 176 | 589 | 170 | | | 3490 | 3244 | 3386.9 | 2.97% | |
| 299 | 287 | Oct | 13 | 2016 | 2882 | 21 | 3365.00 | | 0 | 0 | 206 | 199 | 1065 | 0 | | | 3365 | 3124 | 3386.9 | -4.22% | |
| 300 | 288 | Oct | 14 | 2016 | 2900 | 17 | 3527.00 | | 0 | 0 | -106 | 225 | 1245 | 103 | | | 3527 | 3214 | 3386.9 | -7.78% | |
| 301 | 289 | Oct | 15 | 2016 | 2931 | 18 | 3817.00 | | 0 | 0 | -404 | 224 | 392 | 128 | | | 3817 | 3374 | 3386.9 | -5.12% | |
| 302 | 290 | Oct | 16 | 2016 | 2865 | 18 | 3876.00 | | 0 | 0 | -191 | 273 | 1286 | 126 | | | 3876 | 3371 | 3386.9 | -0.38% | |
| 303 | 291 | Oct | 17 | 2016 | 2877 | 18 | 4048.00 | | 39 | 0 | -141 | 222 | 1206 | 85 | | | 4048 | 3463 | 3386.9 | -0.48% | |
| 304 | 292 | Oct | 18 | 2016 | 2909 | 17 | 3697.00 | | 39 | 0 | 522 | 228 | 58 | 159 | | | 3697 | 3303 | 3386.9 | 2.23% | |
| 305 | 293 | Oct | 19 | 2016 | 2898 | 17 | 3748.00 | | 39 | 0 | 420 | 275 | 922 | 158 | | | 3748 | 3323 | 3386.9 | -2.48% | |
| 306 | 294 | Oct | 20 | 2016 | 2919 | 17 | 3446.00 | | 40 | 0 | -262 | 170 | 17 | 148 | | | 3446 | 3183 | 3386.9 | -1.89% | |
| 307 | 295 | Oct | 21 | 2016 | 2944 | 17 | 3439.00 | | 40 | 0 | -371 | 203 | 399 | 170 | | | 3439 | 3192 | 3386.9 | -6.03% | |
| 308 | 296 | Oct | 22 | 2016 | 2932 | 18 | 3549.00 | | 0 | 0 | -561 | 216 | 1011 | 112 | | | 3549 | 3241 | 3386.9 | -5.77% | |
| 309 | 297 | Oct | 23 | 2016 | 2891 | 18 | 3639.00 | | 0 | 0 | 30 | 207 | 228 | 101 | | | 3639 | 3265 | 3386.9 | -4.32% | |
| 310 | 298 | Oct | 24 | 2016 | 2892 | 17 | 3806.00 | | 0 | 0 | 234 | 225 | 172 | 138 | | | 3806 | 3349 | 3386.9 | -3.60% | |
| 311 | 299 | Oct | 25 | 2016 | 3025 | 18 | 3764.00 | | 0 | 0 | -642 | 238 | 777 | 96 | | | 3764 | 3395 | 3386.9 | -1.12% | |
| 312 | 300 | Oct | 26 | 2016 | 3004 | 17 | 3816.00 | | 0 | 0 | 341 | 198 | 256 | 158 | | | 3816 | 3410 | 3386.9 | 0.22% | |
| 313 | 301 | Oct | 27 | 2016 | 3019 | 17 | 3817.00 | | 0 | 0 | 275 | 258 | 617 | 161 | | | 3817 | 3418 | 3386.9 | 0.68% | |
| 314 | 302 | Oct | 28 | 2016 | 3025 | 17 | 3829.00 | | 0 | 0 | -141 | 257 | 1380 | 49 | | | 3829 | 3427 | 3386.9 | -0.92% | |
| 315 | 303 | Oct | 29 | 2016 | 3028 | 18 | 3863.00 | | 0 | 0 | -780 | 250 | 163 | 93 | | | 3863 | 3446 | 3386.9 | 0.92% | |
| 316 | 304 | Oct | 30 | 2016 | 2974 | 18 | 3571.00 | | 0 | 0 | -138 | 199 | 136 | 85 | | | 3571 | 3273 | 3386.9 | 1.18% | |
| 317 | 305 | Oct | 31 | 2016 | 2941 | 17 | 3856.00 | | 0 | 0 | -561 | 264 | 1226 | 142 | | | 3856 | 3399 | 3386.9 | 1.73% | |
| 318 | 306 | Oct | | | | | | | | | | | | | | | | | -3.38% | | |

| A | B | C | D | P | Q | R | S | T | U | V | W | X | Y | AA | AB | AC | AD | AE | AF |
|-------|-------|-----|------|-------|------|----------|-------|------|-------|-------|-----|-------|------|-------|------|---------|--------|---------|-------|
| Seq # | Month | Day | Year | Total | Hr @ | Max Sys | TOTAL | BLKW | LAMAR | SWPP | LPL | TOTAL | WIND | TOTAL | Max | Average | Study | % | Error |
| 11 | | | | Min | Max | Net Load | EDDY | | | | | | | | | | | | |
| 12 | | | | | | | | | | | | | | | | | | | |
| 318 | Nov | 1 | 2016 | 2995 | 17 | 3825.00 | 0 | 0 | 0 | 10 | 236 | 113 | 147 | | 3825 | 3410 | 3386.9 | 0.68% | |
| 319 | Nov | 2 | 2016 | 3009 | 20 | 3487.00 | 0 | 0 | 0 | 82 | 210 | 482 | 0 | | 3487 | 3248 | 3386.9 | -4.10% | |
| 320 | Nov | 3 | 2016 | 2872 | 20 | 3433.00 | 0 | 0 | 0 | 40 | 209 | 66 | 0 | | 3433 | 3153 | 3386.9 | -6.92% | |
| 321 | Nov | 4 | 2016 | 2959 | 9 | 3361.00 | 0 | 0 | 0 | -16 | 189 | 173 | 2 | | 3361 | 3160 | 3386.9 | -6.70% | |
| 322 | Nov | 5 | 2016 | 2936 | 20 | 3277.00 | 0 | 0 | 0 | 172 | 185 | 1013 | 0 | | 3277 | 3107 | 3386.9 | -8.28% | |
| 323 | Nov | 6 | 2016 | 2802 | 19 | 3282.00 | 0 | 0 | 0 | -205 | 210 | 436 | 0 | | 3282 | 3042 | 3386.9 | -10.18% | |
| 324 | Nov | 7 | 2016 | 2788 | 19 | 3402.00 | 0 | 0 | 0 | 819 | 218 | 488 | 0 | | 3402 | 3095 | 3386.9 | -8.62% | |
| 325 | Nov | 8 | 2016 | 2860 | 19 | 3387.00 | 0 | 0 | 0 | 117 | 211 | 892 | 0 | | 3387 | 3124 | 3386.9 | -7.78% | |
| 326 | Nov | 9 | 2016 | 2965 | 19 | 3432.00 | 0 | 0 | 0 | 304 | 214 | 259 | 0 | | 3432 | 3199 | 3386.9 | -5.56% | |
| 327 | Nov | 10 | 2016 | 3023 | 19 | 3397.00 | 0 | 0 | 0 | -270 | 208 | 437 | 0 | | 3397 | 3210 | 3386.9 | -5.22% | |
| 328 | Nov | 11 | 2016 | 2990 | 10 | 3334.00 | 0 | 0 | 0 | -233 | 191 | 955 | 61 | | 3334 | 3162 | 3386.9 | -6.64% | |
| 329 | Nov | 12 | 2016 | 3001 | 19 | 3273.00 | 0 | 0 | 0 | 601 | 187 | 616 | 0 | | 3273 | 3137 | 3386.9 | -7.38% | |
| 330 | Nov | 13 | 2016 | 2999 | 20 | 3277.00 | 0 | 0 | 0 | -561 | 195 | 233 | 0 | | 3277 | 3138 | 3386.9 | -7.35% | |
| 331 | Nov | 14 | 2016 | 2893 | 19 | 3444.00 | 0 | 0 | 0 | 604 | 203 | 463 | 0 | | 3444 | 3169 | 3386.9 | -6.45% | |
| 332 | Nov | 15 | 2016 | 2949 | 19 | 3477.00 | 0 | 0 | 0 | 585 | 218 | 515 | 0 | | 3477 | 3213 | 3386.9 | -5.13% | |
| 333 | Nov | 16 | 2016 | 2941 | 19 | 3462.00 | 0 | 0 | 0 | 275 | 219 | 1383 | 0 | | 3462 | 3202 | 3386.9 | -5.47% | |
| 334 | Nov | 17 | 2016 | 2926 | 19 | 3467.00 | 0 | 0 | 0 | -298 | 216 | 1404 | 0 | | 3467 | 3197 | 3386.9 | -5.62% | |
| 335 | Nov | 18 | 2016 | 3026 | 9 | 3504.00 | 0 | 0 | 0 | -272 | 203 | 1067 | 150 | | 3504 | 3265 | 3386.9 | -3.60% | |
| 336 | Nov | 19 | 2016 | 3249 | 9 | 3527.00 | 0 | 0 | 0 | 837 | 204 | 721 | 153 | | 3527 | 3388 | 3386.9 | 0.03% | |
| 337 | Nov | 20 | 2016 | 3056 | 9 | 3359.00 | 0 | 0 | 0 | -289 | 182 | 983 | 153 | | 3359 | 3208 | 3386.9 | -5.30% | |
| 338 | Nov | 21 | 2016 | 2980 | 19 | 3516.00 | 0 | 0 | 0 | -187 | 211 | 1376 | 0 | | 3516 | 3248 | 3386.9 | -4.10% | |
| 339 | Nov | 22 | 2016 | 3040 | 19 | 3495.00 | 0 | 0 | 0 | -240 | 185 | 1374 | 0 | | 3495 | 3268 | 3386.9 | -3.52% | |
| 340 | Nov | 23 | 2016 | 3162 | 9 | 3516.00 | 0 | 0 | 0 | -543 | 200 | 218 | 147 | | 3516 | 3339 | 3386.9 | -1.41% | |
| 341 | Nov | 25 | 2016 | 3023 | 10 | 3368.00 | 0 | 0 | 0 | -304 | 184 | 493 | 118 | | 3368 | 3196 | 3386.9 | -5.65% | |
| 342 | Nov | 25 | 2016 | 3071 | 21 | 3391.00 | 0 | 0 | 0 | 16 | 165 | 856 | 0 | | 3391 | 3231 | 3386.9 | -4.60% | |
| 343 | Nov | 26 | 2016 | 3138 | 19 | 3409.00 | 0 | 0 | 0 | -120 | 191 | 1337 | 0 | | 3409 | 3274 | 3386.9 | -3.35% | |
| 344 | Nov | 27 | 2016 | 3008 | 19 | 3403.00 | 0 | 0 | 0 | 129 | 164 | 1347 | 0 | | 3403 | 3206 | 3386.9 | -5.36% | |
| 345 | Nov | 28 | 2016 | 3033 | 19 | 3624.00 | 0 | 0 | 0 | 193 | 206 | 1249 | 0 | | 3624 | 3329 | 3386.9 | -1.72% | |
| 346 | Nov | 29 | 2016 | 3171 | 21 | 3674.00 | 0 | 0 | 0 | -747 | 155 | 296 | 0 | | 3674 | 3423 | 3386.9 | 1.05% | |
| 347 | Nov | 30 | 2016 | 3328 | 8 | 3817.00 | 0 | 0 | 0 | -1023 | 194 | 288 | 2 | | 3817 | 3573 | 3386.9 | 5.48% | |

| A | B | C | D | P | Q | R | S | T | U | V | W | X | Y | AA | AB | AC | AD | AE | AF |
|-------|-------|-----|------|--------------|-------------|---------------------|---------------|---------------|----------------|---------------|--------------|---------------|----------------|----|--------------|-----------------|----------------|------------|----|
| Seq # | Month | Day | Year | Total Min | Hr @ Max | Max Sys Net Load | TOTAL EDDY | TOTAL BLKW | TOTAL LAMAR | TOTAL SWPP | TOTAL LPL | TOTAL WIND | TOTAL SOLAR | | Total Max | Average Load | Study Value | % Error | |
| 10 | | | | | | | | | | | | | | | | | | | |
| 11 | | | | | | | | | | | | | | | | | | | |
| 12 | | | | | | | | | | | | | | | | | | | |
| 348 | Dec | 1 | 2016 | 3296 | 8 | 3754.00 | 0 | 0 | 0 | -391 | 177 | 375 | 1 | | 3754 | 3525 | 3386.9 | 4.08% | |
| 349 | Dec | 2 | 2016 | 3278 | 19 | 3733.00 | 0 | 0 | 0 | -238 | 245 | 808 | 0 | | 3733 | 3506 | 3386.9 | 3.50% | |
| 350 | Dec | 3 | 2016 | 3289 | 19 | 3661.00 | 0 | 0 | 0 | -442 | 236 | 74 | 0 | | 3661 | 3475 | 3386.9 | 2.60% | |
| 351 | Dec | 4 | 2016 | 3190 | 21 | 3596.00 | 0 | 0 | 0 | 48 | 230 | 1000 | 0 | | 3596 | 3393 | 3386.9 | 0.18% | |
| 352 | Dec | 5 | 2016 | 3289 | 8 | 3793.00 | 0 | 0 | 0 | -236 | 203 | 1399 | 0 | | 3793 | 3536 | 3386.9 | 4.40% | |
| 353 | Dec | 6 | 2016 | 3273 | 21 | 3878.00 | 0 | 0 | 0 | -38 | 214 | 1282 | 0 | | 3878 | 3576 | 3386.9 | 5.57% | |
| 354 | Dec | 7 | 2016 | 3516 | 20 | 4024.00 | 0 | 0 | 0 | -419 | 273 | 1229 | 0 | | 4024 | 3770 | 3386.9 | 11.31% | |
| 355 | Dec | 8 | 2016 | 3614 | 19 | 4126.00 | 0 | 0 | 0 | -26 | 248 | 135 | 0 | | 4126 | 3870 | 3386.9 | 14.26% | |
| 356 | Dec | 9 | 2016 | 3633 | 8 | 4057.00 | 0 | 0 | 0 | 439 | 276 | 1205 | 0 | | 4057 | 3845 | 3386.9 | 13.53% | |
| 357 | Dec | 10 | 2016 | 3276 | 8 | 3805.00 | 0 | 0 | 0 | -374 | 238 | 963 | 0 | | 3805 | 3541 | 3386.9 | 4.54% | |
| 358 | Dec | 11 | 2016 | 3253 | 20 | 3546.00 | 0 | 0 | 0 | -502 | 201 | 311 | 0 | | 3546 | 3400 | 3386.9 | 0.37% | |
| 359 | Dec | 12 | 2016 | 3274 | 8 | 3832.00 | 0 | 0 | 0 | 596 | 204 | 1364 | 0 | | 3832 | 3553 | 3386.9 | 4.90% | |
| 360 | Dec | 13 | 2016 | 3239 | 21 | 3761.00 | 0 | 0 | 0 | 806 | 196 | 1015 | 0 | | 3761 | 3500 | 3386.9 | 3.34% | |
| 361 | Dec | 14 | 2016 | 3435 | 8 | 3894.00 | 0 | 0 | 0 | 477 | 208 | 653 | 0 | | 3894 | 3665 | 3386.9 | 8.20% | |
| 362 | Dec | 15 | 2016 | 3540 | 8 | 4035.00 | 0 | 0 | 0 | 309 | 220 | 1281 | 0 | | 4035 | 3788 | 3386.9 | 11.83% | |
| 363 | Dec | 16 | 2016 | 3291 | 8 | 3782.00 | 0 | 0 | 0 | 22 | 234 | 1732 | 0 | | 3782 | 3537 | 3386.9 | 4.42% | |
| 364 | Dec | 17 | 2016 | 3175 | 21 | 4187.00 | 0 | 0 | 0 | 60 | 268 | 1015 | 3 | | 4187 | 3681 | 3386.9 | 8.68% | |
| 365 | Dec | 18 | 2016 | 3409 | 8 | 3936.00 | 0 | 0 | 0 | 167 | 253 | 168 | 3 | | 3936 | 3673 | 3386.9 | 8.43% | |
| 366 | Dec | 19 | 2016 | 3436 | 8 | 3945.00 | 0 | 0 | 0 | -199 | 248 | 690 | 0 | | 3945 | 3691 | 3386.9 | 8.96% | |
| 367 | Dec | 20 | 2016 | 3263 | 8 | 3821.00 | 0 | 0 | 0 | -421 | 259 | 958 | 0 | | 3821 | 3542 | 3386.9 | 4.58% | |
| 368 | Dec | 21 | 2016 | 3341 | 8 | 3651.00 | 0 | 0 | 0 | -128 | 179 | 1343 | 0 | | 3651 | 3496 | 3386.9 | 3.22% | |
| 369 | Dec | 22 | 2016 | 3310 | 19 | 3769.00 | 0 | 0 | 0 | -414 | 194 | 201 | 5 | | 3769 | 3540 | 3386.9 | 4.51% | |
| 370 | Dec | 23 | 2016 | 3174 | 9 | 3697.00 | 0 | 0 | 0 | -344 | 136 | 1449 | 17 | | 3697 | 3436 | 3386.9 | 1.44% | |
| 371 | Dec | 24 | 2016 | 3036 | 8 | 3389.00 | 0 | 0 | 0 | -479 | 198 | 450 | 0 | | 3389 | 3213 | 3386.9 | -5.15% | |
| 372 | Dec | 25 | 2016 | 2860 | 22 | 3273.00 | 0 | 0 | 0 | -307 | 179 | 1266 | 0 | | 3273 | 3067 | 3386.9 | -9.46% | |
| 373 | Dec | 26 | 2016 | 3113 | 21 | 3461.00 | 0 | 0 | 0 | -541 | 204 | 533 | 0 | | 3461 | 3287 | 3386.9 | -2.95% | |
| 374 | Dec | 27 | 2016 | 3244 | 9 | 3666.00 | 0 | 0 | 0 | -418 | 222 | 614 | 64 | | 3666 | 3455 | 3386.9 | 2.01% | |
| 375 | Dec | 28 | 2016 | 3202 | 10 | 3563.00 | 0 | 0 | 0 | -469 | 204 | 1111 | 99 | | 3563 | 3383 | 3386.9 | -0.13% | |
| 376 | Dec | 29 | 2016 | 3274 | 21 | 3751.00 | 0 | 0 | 0 | 387 | 181 | 1183 | 0 | | 3751 | 3513 | 3386.9 | 3.71% | |
| 377 | Dec | 30 | 2016 | 3476 | 9 | 3798.00 | 0 | 0 | 0 | -631 | 223 | 1564 | 21 | | 3798 | 3637 | 3386.9 | 7.38% | |
| 378 | Dec | 31 | 2016 | 3256 | 10 | 3517.00 | 0 | 0 | 0 | -530 | 190 | 1294 | 131 | | 3517 | 3387 | 3386.2 | 0.01% | |

App. D - System Load Data

| | A | B | C | D | AG | AH | AI | AJ | AK | AL | AM | AN |
|----|-------|-------|-----|------|----|---------|-----|-------|----------|------|-------|-------|
| | Seq # | Month | Day | Year | | EDDY CO | PNM | LAMAR | FLOW Avg | SWPP | WIND | SOLAR |
| | | | | | | Avg | Avg | Avg | | Avg | Avg | Avg |
| 10 | | | | | | | | | | | | |
| 11 | | | | | | | | | | | | |
| 12 | | | | | | | | | | | | |
| 13 | 1 | Jan | 1 | 2016 | | 0 | 0 | 0 | 211 | -313 | 387 | 1 |
| 14 | 2 | Jan | 2 | 2016 | | 0 | 0 | 0 | 214 | -495 | 63 | 2 |
| 15 | 3 | Jan | 3 | 2016 | | 0 | 0 | 0 | 185 | -384 | 215 | 7 |
| 16 | 4 | Jan | 4 | 2016 | | 37 | 0 | 0 | 210 | -233 | 215 | 3 |
| 17 | 5 | Jan | 5 | 2016 | | 0 | 0 | 0 | 191 | -151 | 1,306 | 3 |
| 18 | 6 | Jan | 6 | 2016 | | 0 | 0 | 0 | 178 | -279 | 1,182 | 3 |
| 19 | 7 | Jan | 7 | 2016 | | 0 | 0 | 0 | 170 | -174 | 1,013 | 3 |
| 20 | 8 | Jan | 8 | 2016 | | 0 | 0 | 0 | 176 | -690 | 439 | 3 |
| 21 | 9 | Jan | 9 | 2016 | | 0 | 0 | 0 | 199 | -809 | 401 | 10 |
| 22 | 10 | Jan | 10 | 2016 | | 0 | 0 | 0 | 215 | -595 | 316 | 3 |
| 23 | 11 | Jan | 11 | 2016 | | 0 | 0 | 0 | 215 | -639 | 99 | 14 |
| 24 | 12 | Jan | 12 | 2016 | | 0 | 0 | 0 | 205 | -477 | 316 | 10 |
| 25 | 13 | Jan | 13 | 2016 | | 0 | 0 | 0 | 200 | -475 | 415 | 10 |
| 26 | 14 | Jan | 14 | 2016 | | 0 | 0 | 0 | 190 | -416 | 915 | 11 |
| 27 | 15 | Jan | 15 | 2016 | | 0 | 0 | 0 | 212 | -654 | 429 | 0 |
| 28 | 16 | Jan | 16 | 2016 | | 0 | 0 | 0 | 201 | -302 | 352 | 14 |
| 29 | 17 | Jan | 17 | 2016 | | 0 | 0 | 0 | 203 | -407 | 228 | 14 |
| 30 | 18 | Jan | 18 | 2016 | | 0 | 0 | 0 | 210 | -111 | 584 | 15 |
| 31 | 19 | Jan | 19 | 2016 | | 0 | 0 | 0 | 192 | 48 | 1,201 | 0 |
| 32 | 20 | Jan | 20 | 2016 | | 0 | 0 | 0 | 197 | 142 | 1,291 | 14 |
| 33 | 21 | Jan | 21 | 2016 | | 0 | 0 | 0 | 175 | 476 | 1,415 | 0 |
| 34 | 22 | Jan | 22 | 2016 | | 0 | 0 | 0 | 205 | -422 | 91 | 11 |
| 35 | 23 | Jan | 23 | 2016 | | 0 | 0 | 0 | 190 | -263 | 908 | 21 |
| 36 | 24 | Jan | 24 | 2016 | | 0 | 0 | 0 | 187 | 69 | 1,399 | 24 |
| 37 | 25 | Jan | 25 | 2016 | | 0 | 0 | 0 | 192 | 98 | 1,332 | 0 |
| 38 | 26 | Jan | 26 | 2016 | | 0 | 0 | 0 | 184 | -535 | 315 | 0 |
| 39 | 27 | Jan | 27 | 2016 | | 0 | 0 | 0 | 198 | -433 | 341 | 12 |
| 40 | 28 | Jan | 28 | 2016 | | 0 | 0 | 0 | 209 | -165 | 793 | 0 |
| 41 | 29 | Jan | 29 | 2016 | | 0 | 0 | 0 | 198 | -238 | 1,017 | 1 |
| 42 | 30 | Jan | 30 | 2016 | | 0 | 0 | 0 | 165 | 206 | 1,376 | 0 |
| 43 | 31 | Jan | 31 | 2016 | | 0 | 0 | 0 | 167 | 65 | 1,024 | 4 |

App. D - System Load Data

| | A | B | C | D | AG | AH | AI | AJ | AK | AL | AM | AN |
|----|-------|-------|-----|------|----|----------------|------------|--------------|-----------------|-------------|-------------|--------------|
| | Seq # | Month | Day | Year | | EDDY CO Avg | PNM Avg | LAMAR Avg | LPL FLOW Avg | SWPP Avg | WIND Avg | SOLAR Avg |
| 10 | | | | | | | | | | | | |
| 11 | | | | | | | | | | | | |
| 12 | | | | | | | | | | | | |
| 44 | 32 | Feb | 1 | 2016 | | 0 | 0 | 0 | 192 | 35 | 965 | 0 |
| 45 | 33 | Feb | 2 | 2016 | | 0 | 0 | 0 | 208 | 192 | 1,583 | 7 |
| 46 | 34 | Feb | 3 | 2016 | | 0 | 0 | 0 | 242 | -453 | 315 | 11 |
| 47 | 35 | Feb | 4 | 2016 | | 0 | 0 | 0 | 197 | -111 | 500 | 13 |
| 48 | 36 | Feb | 5 | 2016 | | 0 | 0 | 0 | 197 | 137 | 1,101 | 0 |
| 49 | 37 | Feb | 6 | 2016 | | 0 | 0 | 0 | 182 | -410 | 315 | 14 |
| 50 | 38 | Feb | 7 | 2016 | | 0 | 0 | 0 | 164 | -186 | 889 | 10 |
| 51 | 39 | Feb | 8 | 2016 | | 0 | 0 | 0 | 188 | 36 | 1,051 | 0 |
| 52 | 40 | Feb | 9 | 2016 | | 0 | 0 | 0 | 218 | -78 | 712 | 17 |
| 53 | 41 | Feb | 10 | 2016 | | 0 | 0 | 0 | 191 | 366 | 1,033 | 0 |
| 54 | 42 | Feb | 11 | 2016 | | 0 | 0 | 0 | 181 | 237 | 797 | 1 |
| 55 | 43 | Feb | 12 | 2016 | | 0 | 0 | 0 | 191 | -242 | 569 | 1 |
| 56 | 44 | Feb | 13 | 2016 | | 0 | 0 | 0 | 170 | 253 | 1,243 | 14 |
| 57 | 45 | Feb | 14 | 2016 | | 0 | 0 | 25 | 171 | -120 | 437 | 24 |
| 58 | 46 | Feb | 15 | 2016 | | 0 | 0 | 0 | 188 | -592 | 365 | 1 |
| 59 | 47 | Feb | 16 | 2016 | | 0 | 0 | 0 | 177 | -333 | 1,109 | 1 |
| 60 | 48 | Feb | 17 | 2016 | | 0 | 0 | 0 | 180 | -195 | 1,251 | 1 |
| 61 | 49 | Feb | 18 | 2016 | | 0 | 0 | 0 | 161 | 96 | 1,534 | 1 |
| 62 | 50 | Feb | 19 | 2016 | | 0 | 0 | 0 | 162 | -135 | 1,103 | 0 |
| 63 | 51 | Feb | 20 | 2016 | | 0 | 0 | 0 | 165 | -143 | 774 | 0 |
| 64 | 52 | Feb | 21 | 2016 | | 0 | 0 | 0 | 153 | -543 | 489 | 0 |
| 65 | 53 | Feb | 22 | 2016 | | 0 | 0 | 0 | 158 | -566 | 481 | 0 |
| 66 | 54 | Feb | 23 | 2016 | | 0 | 0 | 0 | 182 | -633 | 637 | 0 |
| 67 | 55 | Feb | 24 | 2016 | | 0 | 0 | 0 | 190 | -174 | 852 | 10 |
| 68 | 56 | Feb | 25 | 2016 | | 0 | 0 | 0 | 176 | -417 | 796 | 3 |
| 69 | 57 | Feb | 26 | 2016 | | 0 | 0 | 0 | 193 | -390 | 783 | 10 |
| 70 | 58 | Feb | 27 | 2016 | | 0 | 0 | -13 | 163 | 289 | 1,359 | 3 |
| 71 | 59 | Feb | 28 | 2016 | | 0 | 0 | -25 | 165 | 183 | 755 | 0 |
| 72 | 60 | Feb | 29 | 2016 | | 0 | 0 | 0 | 167 | 461 | 1,348 | 3 |

App. D - System Load Data

| | A | B | C | D | AG | AH | AI | AJ | AK | AL | AM | AN |
|-----|-------|-------|-----|------|----|----------------|------------|--------------|-----------------|-------------|-------------|--------------|
| | Seq # | Month | Day | Year | | EDDY CO Avg | PNM Avg | LAMAR Avg | LPL FLOW Avg | SWPP Avg | WIND Avg | SOLAR Avg |
| 10 | | | | | | | | | | | | |
| 11 | | | | | | | | | | | | |
| 12 | | | | | | | | | | | | |
| 73 | 61 | Mar | 1 | 2016 | | 0 | 0 | -12 | 158 | 94 | 1,179 | 4 |
| 74 | 62 | Mar | 2 | 2016 | | 0 | 0 | 0 | 175 | 124 | 1,101 | 2 |
| 75 | 63 | Mar | 3 | 2016 | | 0 | 0 | -25 | 168 | 284 | 677 | 0 |
| 76 | 64 | Mar | 4 | 2016 | | 0 | 0 | 0 | 164 | 430 | 1,471 | 3 |
| 77 | 65 | Mar | 5 | 2016 | | 0 | 0 | -28 | 160 | -36 | 1,057 | 0 |
| 78 | 66 | Mar | 6 | 2016 | | 0 | 0 | -57 | 160 | 147 | 1,350 | 0 |
| 79 | 67 | Mar | 7 | 2016 | | 0 | 0 | -25 | 168 | -134 | 1,077 | 0 |
| 80 | 68 | Mar | 8 | 2016 | | 0 | 0 | 0 | 171 | -207 | 485 | 0 |
| 81 | 69 | Mar | 9 | 2016 | | 0 | 0 | 0 | 168 | -266 | 334 | 0 |
| 82 | 70 | Mar | 10 | 2016 | | 0 | 0 | 0 | 166 | -231 | 218 | 4 |
| 83 | 71 | Mar | 11 | 2016 | | 0 | 0 | 0 | 165 | -230 | 392 | 7 |
| 84 | 72 | Mar | 12 | 2016 | | 0 | 0 | -31 | 155 | 204 | 1,057 | 22 |
| 85 | 73 | Mar | 13 | 2016 | | 0 | 0 | 0 | 155 | -51 | 469 | 0 |
| 86 | 74 | Mar | 14 | 2016 | | 0 | 0 | 0 | 162 | 72 | 1,291 | 0 |
| 87 | 75 | Mar | 15 | 2016 | | 0 | 0 | 0 | 128 | -229 | 665 | 0 |
| 88 | 76 | Mar | 16 | 2016 | | 0 | 0 | 0 | 126 | -132 | 735 | 6 |
| 89 | 77 | Mar | 17 | 2016 | | 0 | 0 | 0 | 152 | -350 | 180 | 4 |
| 90 | 78 | Mar | 18 | 2016 | | 22 | 0 | 0 | 155 | 57 | 1,371 | 18 |
| 91 | 79 | Mar | 19 | 2016 | | 0 | 0 | 0 | 174 | -857 | 294 | 25 |
| 92 | 80 | Mar | 20 | 2016 | | 0 | 0 | 0 | 167 | -249 | 169 | 23 |
| 93 | 81 | Mar | 21 | 2016 | | 0 | 0 | 0 | 174 | 151 | 1,500 | 0 |
| 94 | 82 | Mar | 22 | 2016 | | 0 | 0 | -62 | 162 | 479 | 1,415 | 0 |
| 95 | 83 | Mar | 23 | 2016 | | 0 | 0 | -18 | 159 | -94 | 1,300 | 0 |
| 96 | 84 | Mar | 24 | 2016 | | 0 | 0 | 0 | 181 | -117 | 1,041 | 0 |
| 97 | 85 | Mar | 25 | 2016 | | 0 | 0 | 0 | 167 | 161 | 1,246 | 11 |
| 98 | 86 | Mar | 26 | 2016 | | 0 | 0 | 0 | 151 | 162 | 1,001 | 17 |
| 99 | 87 | Mar | 27 | 2016 | | 0 | 0 | 41 | 163 | -11 | 187 | 34 |
| 100 | 88 | Mar | 28 | 2016 | | 0 | 0 | 0 | 164 | 85 | 1,469 | 0 |
| 101 | 89 | Mar | 29 | 2016 | | 0 | 0 | -50 | 166 | 220 | 1,450 | 0 |
| 102 | 90 | Mar | 30 | 2016 | | 0 | 0 | -43 | 174 | 101 | 1,239 | 22 |
| 103 | 91 | Mar | 31 | 2016 | | 0 | 0 | -25 | 158 | -123 | 923 | 0 |

App. D - System Load Data

| | A | B | C | D | AG | AH | AI | AJ | AK | AL | AM | AN |
|-----|-------|-------|-----|------|----|---------|-----|-------|----------|------|-------|-------|
| | Seq # | Month | Day | Year | | EDDY CO | PNM | LAMAR | LPL | SWPP | WIND | SOLAR |
| | | | | | | Avg | Avg | Avg | FLOW Avg | Avg | Avg | Avg |
| 10 | | | | | | | | | | | | |
| 11 | | | | | | | | | | | | |
| 12 | | | | | | | | | | | | |
| 104 | 92 | Apr | 1 | 2016 | | 0 | 0 | 0 | 166 | -428 | 601 | 1 |
| 105 | 93 | Apr | 2 | 2016 | | 0 | 0 | 0 | 168 | -368 | 715 | 0 |
| 106 | 94 | Apr | 3 | 2016 | | 0 | 0 | -44 | 159 | -185 | 908 | 0 |
| 107 | 95 | Apr | 4 | 2016 | | 0 | 0 | 0 | 173 | 45 | 783 | 0 |
| 108 | 96 | Apr | 5 | 2016 | | 0 | 0 | -13 | 173 | 94 | 1,478 | 9 |
| 109 | 97 | Apr | 6 | 2016 | | 0 | 0 | 0 | 172 | -379 | 764 | 13 |
| 110 | 98 | Apr | 7 | 2016 | | 0 | 0 | 0 | 163 | 129 | 891 | 0 |
| 111 | 99 | Apr | 8 | 2016 | | 0 | 0 | 0 | 158 | 46 | 596 | 5 |
| 112 | 100 | Apr | 9 | 2016 | | 0 | 0 | 0 | 155 | -45 | 1,141 | 20 |
| 113 | 101 | Apr | 10 | 2016 | | 0 | 0 | -50 | 167 | -134 | 1,126 | 0 |
| 114 | 102 | Apr | 11 | 2016 | | 0 | 0 | -13 | 165 | -222 | 692 | 0 |
| 115 | 103 | Apr | 12 | 2016 | | 0 | 0 | 0 | 164 | -455 | 336 | 0 |
| 116 | 104 | Apr | 13 | 2016 | | 0 | 0 | 0 | 167 | -72 | 742 | 0 |
| 117 | 105 | Apr | 14 | 2016 | | 0 | 0 | -26 | 173 | 185 | 1,234 | 22 |
| 118 | 106 | Apr | 15 | 2016 | | 0 | 0 | -25 | 155 | 252 | 1,372 | 21 |
| 119 | 107 | Apr | 16 | 2016 | | 0 | 0 | 0 | 172 | 289 | 1,199 | 22 |
| 120 | 108 | Apr | 17 | 2016 | | 0 | 0 | 0 | 155 | 387 | 1,080 | 0 |
| 121 | 109 | Apr | 18 | 2016 | | 0 | 0 | 0 | 160 | 302 | 889 | 0 |
| 122 | 110 | Apr | 19 | 2016 | | 0 | 0 | 0 | 163 | 29 | 145 | 9 |
| 123 | 111 | Apr | 20 | 2016 | | 0 | 0 | 0 | 173 | 77 | 211 | 20 |
| 124 | 112 | Apr | 21 | 2016 | | 0 | 0 | 0 | 176 | -387 | 238 | 20 |
| 125 | 113 | Apr | 22 | 2016 | | 40 | 0 | -1 | 185 | 164 | 455 | 20 |
| 126 | 114 | Apr | 23 | 2016 | | 42 | 0 | -25 | 178 | 232 | 1,568 | 17 |
| 127 | 115 | Apr | 24 | 2016 | | 0 | 0 | -25 | 188 | 186 | 1,222 | 15 |
| 128 | 116 | Apr | 25 | 2016 | | 0 | 0 | 0 | 203 | 597 | 974 | 21 |
| 129 | 117 | Apr | 26 | 2016 | | 0 | 0 | 0 | 188 | 366 | 1,005 | 19 |
| 130 | 118 | Apr | 27 | 2016 | | 0 | 0 | 0 | 183 | 10 | 693 | 20 |
| 131 | 119 | Apr | 28 | 2016 | | 0 | 0 | 0 | 186 | 172 | 1,052 | 20 |
| 132 | 120 | Apr | 29 | 2016 | | 0 | 0 | 0 | 187 | -9 | 698 | 17 |
| 133 | 121 | Apr | 30 | 2016 | | 0 | 0 | 0 | 166 | -52 | 378 | 18 |

App. D - System Load Data

| | A | B | C | D | AG | AH | AI | AJ | AK | AL | AM | AN |
|-----|-------|-------|-----|------|----|----------------|------------|--------------|-----------------|-------------|-------------|--------------|
| | Seq # | Month | Day | Year | | EDDY CO Avg | PNM Avg | LAMAR Avg | LPL FLOW Avg | SWPP Avg | WIND Avg | SOLAR Avg |
| 10 | | | | | | | | | | | | |
| 11 | | | | | | | | | | | | |
| 12 | | | | | | | | | | | | |
| 134 | 122 | May | 1 | 2016 | | 0 | 0 | 0 | 150 | 436 | 996 | 0 |
| 135 | 123 | May | 2 | 2016 | | 0 | 0 | 0 | 167 | 2 | 142 | 1 |
| 136 | 124 | May | 3 | 2016 | | 0 | 0 | 0 | 161 | 233 | 864 | 18 |
| 137 | 125 | May | 4 | 2016 | | 0 | 0 | 0 | 187 | -222 | 78 | 17 |
| 138 | 126 | May | 5 | 2016 | | 0 | 0 | 0 | 207 | 396 | 502 | 20 |
| 139 | 127 | May | 6 | 2016 | | 0 | 0 | 0 | 196 | 508 | 1,588 | 16 |
| 140 | 128 | May | 7 | 2016 | | 0 | 0 | 0 | 207 | 298 | 1,454 | 17 |
| 141 | 129 | May | 8 | 2016 | | 0 | 0 | 0 | 200 | 95 | 996 | 16 |
| 142 | 130 | May | 9 | 2016 | | 0 | 0 | 0 | 198 | -132 | 711 | 17 |
| 143 | 131 | May | 10 | 2016 | | 0 | 0 | 0 | 221 | 296 | 796 | 20 |
| 144 | 132 | May | 11 | 2016 | | 0 | 0 | 0 | 222 | 32 | 676 | 9 |
| 145 | 133 | May | 12 | 2016 | | 0 | 0 | 0 | 197 | -6 | 374 | 13 |
| 146 | 134 | May | 13 | 2016 | | 0 | 0 | -26 | 221 | -65 | 913 | 20 |
| 147 | 135 | May | 14 | 2016 | | 0 | 0 | -110 | 157 | -150 | 1,159 | 0 |
| 148 | 136 | May | 15 | 2016 | | 0 | 0 | 0 | 155 | -35 | 680 | 0 |
| 149 | 137 | May | 16 | 2016 | | 0 | 0 | 0 | 199 | 179 | 987 | 13 |
| 150 | 138 | May | 17 | 2016 | | 0 | 0 | 0 | 164 | 203 | 1,371 | 4 |
| 151 | 139 | May | 18 | 2016 | | 0 | 0 | 0 | 164 | -171 | 301 | 2 |
| 152 | 140 | May | 19 | 2016 | | 0 | 0 | 0 | 162 | -237 | 249 | 5 |
| 153 | 141 | May | 20 | 2016 | | 0 | 0 | 0 | 171 | 267 | 1,264 | 16 |
| 154 | 142 | May | 21 | 2016 | | 0 | 0 | -50 | 201 | 140 | 1,462 | 19 |
| 155 | 143 | May | 22 | 2016 | | 0 | 0 | -122 | 219 | 175 | 1,181 | 21 |
| 156 | 144 | May | 23 | 2016 | | 0 | 0 | 0 | 233 | -53 | 790 | 18 |
| 157 | 145 | May | 24 | 2016 | | 0 | 0 | 0 | 245 | 117 | 1,239 | 10 |
| 158 | 146 | May | 25 | 2016 | | 0 | 0 | 0 | 245 | 260 | 1,071 | 19 |
| 159 | 147 | May | 26 | 2016 | | 0 | 0 | 0 | 234 | 227 | 1,509 | 16 |
| 160 | 148 | May | 27 | 2016 | | 0 | 0 | 0 | 205 | -228 | 639 | 19 |
| 161 | 149 | May | 28 | 2016 | | 0 | 0 | 13 | 212 | -142 | 285 | 19 |
| 162 | 150 | May | 29 | 2016 | | 0 | 0 | 0 | 204 | 177 | 1,068 | 7 |
| 163 | 151 | May | 30 | 2016 | | 0 | 0 | 0 | 201 | -48 | 627 | 7 |
| 164 | 152 | May | 31 | 2016 | | 0 | 0 | -13 | 208 | -158 | 573 | 15 |

App. D - System Load Data

| | A | B | C | D | AG | AH | AI | AJ | AK | AL | AM | AN |
|-----|-------|-------|-----|------|----|---------|-----|-------|----------|------|-------|-------|
| | Seq # | Month | Day | Year | | EDDY CO | PNM | LAMAR | LPL | SWPP | WIND | SOLAR |
| | | | | | | Avg | Avg | Avg | FLOW Avg | Avg | Avg | Avg |
| 10 | | | | | | | | | | | | |
| 11 | | | | | | | | | | | | |
| 12 | | | | | | | | | | | | |
| 165 | 153 | Jun | 1 | 2016 | | 0 | 0 | 0 | 166 | -139 | 303 | 16 |
| 166 | 154 | Jun | 2 | 2016 | | 0 | 0 | 0 | 178 | -165 | 248 | 9 |
| 167 | 155 | Jun | 3 | 2016 | | 0 | 0 | 0 | 202 | -364 | 65 | 18 |
| 168 | 156 | Jun | 4 | 2016 | | 0 | 0 | 0 | 201 | -431 | 409 | 9 |
| 169 | 157 | Jun | 5 | 2016 | | 0 | 0 | 25 | 220 | -184 | 56 | 26 |
| 170 | 158 | Jun | 6 | 2016 | | 26 | 0 | 43 | 229 | 10 | 439 | 10 |
| 171 | 159 | Jun | 7 | 2016 | | 46 | 0 | 50 | 212 | 372 | 814 | 24 |
| 172 | 160 | Jun | 8 | 2016 | | 50 | 0 | 0 | 236 | 387 | 1,258 | 19 |
| 173 | 161 | Jun | 9 | 2016 | | 50 | 0 | 0 | 243 | 479 | 1,281 | 20 |
| 174 | 162 | Jun | 10 | 2016 | | 50 | 0 | 0 | 222 | 225 | 808 | 19 |
| 175 | 163 | Jun | 11 | 2016 | | 25 | 0 | 0 | 217 | 186 | 927 | 11 |
| 176 | 164 | Jun | 12 | 2016 | | 0 | 0 | 0 | 209 | 294 | 630 | 18 |
| 177 | 165 | Jun | 13 | 2016 | | 20 | 0 | 0 | 243 | 133 | 654 | 11 |
| 178 | 166 | Jun | 14 | 2016 | | 40 | 0 | 0 | 232 | -354 | 320 | 15 |
| 179 | 167 | Jun | 15 | 2016 | | 40 | 0 | 0 | 271 | 180 | 1,041 | 7 |
| 180 | 168 | Jun | 16 | 2016 | | 40 | 0 | 0 | 238 | 392 | 1,248 | 16 |
| 181 | 169 | Jun | 17 | 2016 | | 40 | 0 | 0 | 280 | -238 | 748 | 16 |
| 182 | 170 | Jun | 18 | 2016 | | 40 | 0 | 0 | 265 | -162 | 508 | 21 |
| 183 | 171 | Jun | 19 | 2016 | | 40 | 0 | 0 | 248 | -347 | 338 | 15 |
| 184 | 172 | Jun | 20 | 2016 | | 44 | 0 | 0 | 239 | -440 | 791 | 15 |
| 185 | 173 | Jun | 21 | 2016 | | 60 | 0 | 0 | 227 | -51 | 1,028 | 13 |
| 186 | 174 | Jun | 22 | 2016 | | 40 | 0 | 0 | 259 | -108 | 921 | 15 |
| 187 | 175 | Jun | 23 | 2016 | | 55 | 0 | 0 | 260 | -185 | 404 | 16 |
| 188 | 176 | Jun | 24 | 2016 | | 55 | 0 | 0 | 234 | 68 | 1,021 | 15 |
| 189 | 177 | Jun | 25 | 2016 | | 40 | 0 | -46 | 210 | -139 | 1,264 | 16 |
| 190 | 178 | Jun | 26 | 2016 | | 0 | 0 | 25 | 218 | 136 | 202 | 19 |
| 191 | 179 | Jun | 27 | 2016 | | 0 | 0 | 0 | 230 | -76 | 239 | 9 |
| 192 | 180 | Jun | 28 | 2016 | | 0 | 0 | 0 | 265 | -257 | 234 | 20 |
| 193 | 181 | Jun | 29 | 2016 | | 20 | 0 | 0 | 234 | -8 | 517 | 17 |
| 194 | 182 | Jun | 30 | 2016 | | 40 | 0 | 0 | 233 | -312 | 507 | 24 |

App. D - System Load Data

| | A | B | C | D | AG | AH | AI | AJ | AK | AL | AM | AN |
|-----|-------|-------|-----|------|----|---------|-----|-------|----------|------|-------|-------|
| | Seq # | Month | Day | Year | | EDDY CO | PNM | LAMAR | FLOW Avg | SWPP | WIND | SOLAR |
| | | | | | | Avg | Avg | Avg | | Avg | Avg | Avg |
| 10 | | | | | | | | | | | | |
| 11 | | | | | | | | | | | | |
| 12 | | | | | | | | | | | | |
| 195 | 183 | Jul | 1 | 2016 | | 40 | 0 | 0 | 229 | -148 | 866 | 15 |
| 196 | 184 | Jul | 2 | 2016 | | 40 | 0 | 0 | 234 | -443 | 927 | 17 |
| 197 | 185 | Jul | 3 | 2016 | | 40 | 0 | 14 | 235 | -445 | 203 | 24 |
| 198 | 186 | Jul | 4 | 2016 | | 40 | 0 | 0 | 238 | -414 | 168 | 13 |
| 199 | 187 | Jul | 5 | 2016 | | 55 | 0 | 0 | 273 | -459 | 479 | 13 |
| 200 | 188 | Jul | 6 | 2016 | | 70 | 0 | 0 | 261 | -203 | 831 | 11 |
| 201 | 189 | Jul | 7 | 2016 | | 55 | 0 | 0 | 259 | -453 | 871 | 5 |
| 202 | 190 | Jul | 8 | 2016 | | 55 | 0 | 0 | 241 | -141 | 1,070 | 16 |
| 203 | 191 | Jul | 9 | 2016 | | 40 | 0 | 0 | 226 | 24 | 748 | 17 |
| 204 | 192 | Jul | 10 | 2016 | | 55 | 0 | 0 | 235 | 329 | 1,163 | 32 |
| 205 | 193 | Jul | 11 | 2016 | | 70 | 0 | 0 | 277 | 13 | 1,221 | 18 |
| 206 | 194 | Jul | 12 | 2016 | | 70 | 0 | 0 | 288 | -608 | 474 | 25 |
| 207 | 195 | Jul | 13 | 2016 | | 70 | 0 | 0 | 298 | -368 | 793 | 21 |
| 208 | 196 | Jul | 14 | 2016 | | 70 | 0 | 0 | 274 | -660 | 809 | 19 |
| 209 | 197 | Jul | 15 | 2016 | | 70 | 0 | 0 | 241 | -364 | 526 | 28 |
| 210 | 198 | Jul | 16 | 2016 | | 70 | 0 | 0 | 250 | -283 | 902 | 28 |
| 211 | 199 | Jul | 17 | 2016 | | 75 | 0 | 0 | 244 | 173 | 1,371 | 30 |
| 212 | 200 | Jul | 18 | 2016 | | 0 | 0 | 0 | 246 | 51 | 1,010 | 30 |
| 213 | 201 | Jul | 19 | 2016 | | 17 | 0 | 0 | 266 | -38 | 833 | 30 |
| 214 | 202 | Jul | 20 | 2016 | | 70 | 0 | 0 | 268 | -70 | 1,184 | 28 |
| 215 | 203 | Jul | 21 | 2016 | | 20 | 0 | 0 | 295 | -113 | 1,069 | 30 |
| 216 | 204 | Jul | 22 | 2016 | | 70 | -8 | 0 | 255 | 112 | 1,035 | 34 |
| 217 | 205 | Jul | 23 | 2016 | | 58 | -16 | 0 | 256 | 178 | 1,011 | 47 |
| 218 | 206 | Jul | 24 | 2016 | | 40 | -16 | 0 | 250 | 20 | 619 | 49 |
| 219 | 207 | Jul | 25 | 2016 | | 58 | -1 | 0 | 275 | -503 | 154 | 29 |
| 220 | 208 | Jul | 26 | 2016 | | 86 | -16 | 0 | 261 | -689 | 212 | 12 |
| 221 | 209 | Jul | 27 | 2016 | | 86 | 37 | 0 | 254 | -601 | 493 | 39 |
| 222 | 210 | Jul | 28 | 2016 | | 86 | 89 | 37 | 247 | -821 | 231 | 30 |
| 223 | 211 | Jul | 29 | 2016 | | 0 | 65 | 0 | 259 | -73 | 894 | 44 |
| 224 | 212 | Jul | 30 | 2016 | | 25 | -6 | 0 | 249 | -259 | 696 | 55 |
| 225 | 213 | Jul | 31 | 2016 | | 0 | -65 | 0 | 257 | 76 | 1,235 | 27 |

App. D - System Load Data

| | A | B | C | D | AG | AH | AI | AJ | AK | AL | AM | AN |
|-----|-------|-------|-----|------|----|---------|-----|-------|----------|-------|-------|-------|
| | | | | | | EDDY CO | PNM | LAMAR | LPL | SWPPP | WIND | SOLAR |
| | Seq # | Month | Day | Year | | Avg | Avg | Avg | FLOW Avg | Avg | Avg | Avg |
| 10 | | | | | | | | | | | | |
| 11 | | | | | | | | | | | | |
| 12 | | | | | | | | | | | | |
| 226 | 214 | Aug | 1 | 2016 | | 20 | -21 | 0 | 263 | -37 | 1,197 | 25 |
| 227 | 215 | Aug | 2 | 2016 | | 57 | -26 | 0 | 272 | -445 | 544 | 50 |
| 228 | 216 | Aug | 3 | 2016 | | 23 | -39 | 0 | 271 | -309 | 505 | 50 |
| 229 | 217 | Aug | 4 | 2016 | | 0 | -4 | 0 | 282 | -344 | 1,003 | 52 |
| 230 | 218 | Aug | 5 | 2016 | | 0 | -3 | 0 | 284 | -458 | 221 | 53 |
| 231 | 219 | Aug | 6 | 2016 | | 0 | -16 | 0 | 267 | -303 | 451 | 37 |
| 232 | 220 | Aug | 7 | 2016 | | 0 | -21 | 0 | 246 | -367 | 381 | 64 |
| 233 | 221 | Aug | 8 | 2016 | | 18 | -21 | 0 | 262 | -500 | 650 | 33 |
| 234 | 222 | Aug | 9 | 2016 | | 40 | 14 | 87 | 258 | -330 | 668 | 17 |
| 235 | 223 | Aug | 10 | 2016 | | 40 | -40 | 0 | 250 | -206 | 952 | 39 |
| 236 | 224 | Aug | 11 | 2016 | | 40 | -84 | 50 | 263 | -380 | 690 | 10 |
| 237 | 225 | Aug | 12 | 2016 | | 40 | -21 | 0 | 264 | -363 | 467 | 35 |
| 238 | 226 | Aug | 13 | 2016 | | 40 | -21 | 0 | 212 | -528 | 238 | 8 |
| 239 | 227 | Aug | 14 | 2016 | | 40 | -18 | 0 | 181 | -365 | 96 | 27 |
| 240 | 228 | Aug | 15 | 2016 | | 40 | 34 | 0 | 226 | -260 | 387 | 44 |
| 241 | 229 | Aug | 16 | 2016 | | 40 | 0 | 0 | 233 | -312 | 681 | 47 |
| 242 | 230 | Aug | 17 | 2016 | | 40 | 38 | 0 | 232 | -355 | 539 | 43 |
| 243 | 231 | Aug | 18 | 2016 | | 40 | -21 | 0 | 244 | -443 | 426 | 46 |
| 244 | 232 | Aug | 19 | 2016 | | 40 | -16 | 0 | 273 | -865 | 238 | 20 |
| 245 | 233 | Aug | 20 | 2016 | | 0 | -21 | 13 | 192 | -580 | 526 | 31 |
| 246 | 234 | Aug | 21 | 2016 | | 0 | 13 | 0 | 191 | -488 | 444 | 27 |
| 247 | 235 | Aug | 22 | 2016 | | 0 | 14 | 0 | 212 | -229 | 1,126 | 18 |
| 248 | 236 | Aug | 23 | 2016 | | 40 | 14 | 0 | 234 | -4 | 1,159 | 14 |
| 249 | 237 | Aug | 24 | 2016 | | 75 | -16 | 13 | 210 | 62 | 920 | 41 |
| 250 | 238 | Aug | 25 | 2016 | | 75 | -21 | 25 | 204 | -95 | 161 | 13 |
| 251 | 239 | Aug | 26 | 2016 | | 0 | -21 | 0 | 204 | -128 | 238 | 22 |
| 252 | 240 | Aug | 27 | 2016 | | 0 | -13 | 0 | 222 | 243 | 772 | 43 |
| 253 | 241 | Aug | 28 | 2016 | | 0 | -55 | 38 | 225 | 5 | 366 | 40 |
| 254 | 242 | Aug | 29 | 2016 | | 0 | -16 | 0 | 198 | 192 | 209 | 37 |
| 255 | 243 | Aug | 30 | 2016 | | 0 | -32 | 0 | 197 | 372 | 37 | 21 |
| 256 | 244 | Aug | 31 | 2016 | | 0 | -45 | 0 | 198 | 129 | 24 | 29 |

App. D - System Load Data

| | A | B | C | D | AG | AH | AI | AJ | AK | AL | AM | AN |
|-----|-------|-------|-----|------|----|---------|-----|-------|----------|------|-------|-------|
| | Seq # | Month | Day | Year | | EDDY CO | PNM | LAMAR | FLOW Avg | SWPP | WIND | SOLAR |
| | | | | | | Avg | Avg | Avg | | Avg | Avg | Avg |
| 10 | | | | | | | | | | | | |
| 11 | | | | | | | | | | | | |
| 12 | | | | | | | | | | | | |
| 257 | 245 | Sep | 1 | 2016 | | 0 | 68 | 0 | 227 | -524 | 90 | 44 |
| 258 | 246 | Sep | 2 | 2016 | | 0 | 82 | 0 | 226 | -343 | 386 | 48 |
| 259 | 247 | Sep | 3 | 2016 | | 0 | 61 | -25 | 218 | -367 | 1,084 | 18 |
| 260 | 248 | Sep | 4 | 2016 | | 0 | 93 | -50 | 187 | -126 | 1,216 | 49 |
| 261 | 249 | Sep | 5 | 2016 | | 0 | -6 | -83 | 204 | -90 | 1,319 | 45 |
| 262 | 250 | Sep | 6 | 2016 | | 0 | 73 | 0 | 221 | -318 | 1,063 | 8 |
| 263 | 251 | Sep | 7 | 2016 | | 0 | -23 | -1 | 201 | -83 | 1,055 | 35 |
| 264 | 252 | Sep | 8 | 2016 | | 0 | -1 | 0 | 231 | -556 | 622 | 50 |
| 265 | 253 | Sep | 9 | 2016 | | 0 | 24 | -25 | 234 | -743 | 358 | 45 |
| 266 | 254 | Sep | 10 | 2016 | | 0 | 48 | -20 | 210 | -389 | 474 | 46 |
| 267 | 255 | Sep | 11 | 2016 | | 0 | 69 | -124 | 185 | -426 | 1,038 | 39 |
| 268 | 256 | Sep | 12 | 2016 | | 0 | 138 | -91 | 232 | -330 | 911 | 22 |
| 269 | 257 | Sep | 13 | 2016 | | 0 | 6 | -40 | 233 | -390 | 288 | 51 |
| 270 | 258 | Sep | 14 | 2016 | | 0 | -32 | 60 | 216 | -292 | 275 | 29 |
| 271 | 259 | Sep | 15 | 2016 | | 0 | 82 | 0 | 205 | -474 | 838 | 9 |
| 272 | 260 | Sep | 16 | 2016 | | 0 | 6 | 13 | 174 | -295 | 352 | 43 |
| 273 | 261 | Sep | 17 | 2016 | | 0 | -16 | 38 | 173 | -136 | 409 | 26 |
| 274 | 262 | Sep | 18 | 2016 | | 0 | 71 | 57 | 200 | -139 | 623 | 44 |
| 275 | 263 | Sep | 19 | 2016 | | 0 | 82 | 32 | 231 | -152 | 502 | 43 |
| 276 | 264 | Sep | 20 | 2016 | | 0 | -16 | -115 | 230 | -151 | 753 | 50 |
| 277 | 265 | Sep | 21 | 2016 | | 0 | 90 | -150 | 221 | -183 | 1,064 | 19 |
| 278 | 266 | Sep | 22 | 2016 | | 0 | 40 | -35 | 218 | -126 | 1,000 | 47 |
| 279 | 267 | Sep | 23 | 2016 | | 0 | -16 | 0 | 222 | -139 | 1,233 | 54 |
| 280 | 268 | Sep | 24 | 2016 | | 0 | -15 | 0 | 192 | -666 | 382 | 53 |
| 281 | 269 | Sep | 25 | 2016 | | 0 | 2 | 16 | 154 | -338 | 465 | 0 |
| 282 | 270 | Sep | 26 | 2016 | | 0 | -15 | 0 | 147 | -627 | 119 | 7 |
| 283 | 271 | Sep | 27 | 2016 | | 0 | -23 | 0 | 168 | -219 | 284 | 63 |
| 284 | 272 | Sep | 28 | 2016 | | 0 | -16 | 0 | 211 | -549 | 296 | 61 |
| 285 | 273 | Sep | 29 | 2016 | | 0 | -43 | 0 | 174 | -197 | 225 | 63 |
| 286 | 274 | Sep | 30 | 2016 | | 0 | -16 | 0 | 169 | -15 | 981 | 73 |

App. D - System Load Data

| | A | B | C | D | AG | AH | AI | AJ | AK | AL | AM | AN |
|-----|-------|-------|-----|------|----|----------------|------------|--------------|----------|-------------|-------------|--------------|
| | Seq # | Month | Day | Year | | EDDY CO Avg | PNM Avg | LAMAR Avg | FLOW Avg | SWPP Avg | WIND Avg | SOLAR Avg |
| 10 | | | | | | | | | | | | |
| 11 | | | | | | | | | | | | |
| 12 | | | | | | | | | | | | |
| 287 | 275 | Oct | 1 | 2016 | | 0 | 7 | 0 | 182 | -168 | 878 | 41 |
| 288 | 276 | Oct | 2 | 2016 | | 0 | 0 | 0 | 213 | -142 | 885 | 51 |
| 289 | 277 | Oct | 3 | 2016 | | 0 | 0 | 0 | 188 | 5 | 1,445 | 52 |
| 290 | 278 | Oct | 4 | 2016 | | 0 | 0 | 0 | 188 | 40 | 915 | 74 |
| 291 | 279 | Oct | 5 | 2016 | | 0 | 0 | 0 | 162 | 242 | 514 | 73 |
| 292 | 280 | Oct | 6 | 2016 | | 0 | 0 | 0 | 191 | 28 | 856 | 82 |
| 293 | 281 | Oct | 7 | 2016 | | 0 | 0 | 0 | 138 | -249 | 646 | 20 |
| 294 | 282 | Oct | 8 | 2016 | | 0 | 0 | 0 | 137 | -142 | 839 | 0 |
| 295 | 283 | Oct | 9 | 2016 | | 0 | 0 | 0 | 149 | -280 | 723 | 0 |
| 296 | 284 | Oct | 10 | 2016 | | 0 | 0 | 0 | 174 | -504 | 721 | 62 |
| 297 | 285 | Oct | 11 | 2016 | | 0 | 0 | 0 | 197 | -278 | 985 | 78 |
| 298 | 286 | Oct | 12 | 2016 | | 0 | 0 | 0 | 164 | -599 | 745 | 85 |
| 299 | 287 | Oct | 13 | 2016 | | 0 | 0 | 0 | 166 | -232 | 585 | 0 |
| 300 | 288 | Oct | 14 | 2016 | | 0 | 0 | 0 | 180 | 83 | 1,181 | 51 |
| 301 | 289 | Oct | 15 | 2016 | | 0 | 0 | 0 | 182 | -188 | 888 | 64 |
| 302 | 290 | Oct | 16 | 2016 | | 0 | 0 | 0 | 207 | -221 | 1,238 | 63 |
| 303 | 291 | Oct | 17 | 2016 | | 20 | 0 | 0 | 186 | -84 | 1,362 | 42 |
| 304 | 292 | Oct | 18 | 2016 | | 40 | 0 | 0 | 186 | 251 | 576 | 80 |
| 305 | 293 | Oct | 19 | 2016 | | 40 | 0 | 0 | 205 | 325 | 1,027 | 79 |
| 306 | 294 | Oct | 20 | 2016 | | 40 | 0 | 0 | 152 | -133 | 448 | 74 |
| 307 | 295 | Oct | 21 | 2016 | | 40 | 0 | 0 | 168 | -73 | 875 | 85 |
| 308 | 296 | Oct | 22 | 2016 | | 0 | 0 | 0 | 173 | -248 | 1,245 | 56 |
| 309 | 297 | Oct | 23 | 2016 | | 0 | 0 | 0 | 167 | -49 | 689 | 51 |
| 310 | 298 | Oct | 24 | 2016 | | 0 | 0 | 0 | 182 | 66 | 162 | 69 |
| 311 | 299 | Oct | 25 | 2016 | | 0 | 0 | 0 | 192 | -281 | 1,020 | 48 |
| 312 | 300 | Oct | 26 | 2016 | | 0 | 0 | 0 | 166 | 443 | 583 | 79 |
| 313 | 301 | Oct | 27 | 2016 | | 0 | 0 | 0 | 200 | 347 | 725 | 80 |
| 314 | 302 | Oct | 28 | 2016 | | 0 | 0 | 0 | 200 | -36 | 1,389 | 25 |
| 315 | 303 | Oct | 29 | 2016 | | 0 | 0 | 0 | 194 | -266 | 840 | 46 |
| 316 | 304 | Oct | 30 | 2016 | | 0 | 0 | 0 | 167 | -143 | 396 | 43 |
| 317 | 305 | Oct | 31 | 2016 | | 0 | 0 | 0 | 201 | -263 | 1,316 | 71 |


App. D - System Load Data

| | A | B | C | D | AG | AH | AI | AJ | AK | AL | AM | AN |
|-----|-------|-------|-----|------|----|----------------|------------|--------------|----------|-------------|-------------|--------------|
| | Seq # | Month | Day | Year | | EDDY CO Avg | PNM Avg | LAMAR Avg | FLOW Avg | SWPP Avg | WIND Avg | SOLAR Avg |
| 10 | | | | | | | | | | | | |
| 11 | | | | | | | | | | | | |
| 12 | | | | | | | | | | | | |
| 318 | 306 | Nov | 1 | 2016 | | 0 | 0 | 0 | 190 | -57 | 483 | 73 |
| 319 | 307 | Nov | 2 | 2016 | | 0 | 0 | 0 | 177 | -186 | 470 | 0 |
| 320 | 308 | Nov | 3 | 2016 | | 0 | 0 | 0 | 172 | -25 | 181 | 0 |
| 321 | 309 | Nov | 4 | 2016 | | 0 | 0 | 0 | 165 | -88 | 111 | 1 |
| 322 | 310 | Nov | 5 | 2016 | | 0 | 0 | 0 | 159 | 43 | 722 | 0 |
| 323 | 311 | Nov | 6 | 2016 | | 0 | 0 | 0 | 170 | -233 | 661 | 0 |
| 324 | 312 | Nov | 7 | 2016 | | 0 | 0 | 0 | 177 | 489 | 403 | 0 |
| 325 | 313 | Nov | 8 | 2016 | | 0 | 0 | 0 | 173 | 125 | 918 | 0 |
| 326 | 314 | Nov | 9 | 2016 | | 0 | 0 | 0 | 179 | 50 | 222 | 0 |
| 327 | 315 | Nov | 10 | 2016 | | 0 | 0 | 0 | 176 | -223 | 639 | 0 |
| 328 | 316 | Nov | 11 | 2016 | | 0 | 0 | 0 | 166 | -197 | 854 | 31 |
| 329 | 317 | Nov | 12 | 2016 | | 0 | 0 | 0 | 165 | 24 | 366 | 0 |
| 330 | 318 | Nov | 13 | 2016 | | 0 | 0 | 0 | 174 | -386 | 258 | 0 |
| 331 | 319 | Nov | 14 | 2016 | | 0 | 0 | 0 | 170 | 204 | 473 | 0 |
| 332 | 320 | Nov | 15 | 2016 | | 0 | 0 | 0 | 178 | 187 | 628 | 0 |
| 333 | 321 | Nov | 16 | 2016 | | 0 | 0 | 0 | 176 | 339 | 1,304 | 0 |
| 334 | 322 | Nov | 17 | 2016 | | 0 | 0 | 0 | 176 | -10 | 1,405 | 0 |
| 335 | 323 | Nov | 18 | 2016 | | 0 | 0 | 0 | 172 | -194 | 1,044 | 75 |
| 336 | 324 | Nov | 19 | 2016 | | 0 | 0 | 0 | 191 | 594 | 1,147 | 110 |
| 337 | 325 | Nov | 20 | 2016 | | 0 | 0 | 0 | 171 | -61 | 836 | 76 |
| 338 | 326 | Nov | 21 | 2016 | | 0 | 0 | 0 | 179 | -74 | 966 | 0 |
| 339 | 327 | Nov | 22 | 2016 | | 0 | 0 | 0 | 163 | -41 | 1,398 | 0 |
| 340 | 328 | Nov | 23 | 2016 | | 0 | 0 | 0 | 175 | -278 | 663 | 74 |
| 341 | 329 | Nov | 25 | 2016 | | 0 | 0 | 0 | 165 | -131 | 862 | 77 |
| 342 | 330 | Nov | 25 | 2016 | | 0 | 0 | 0 | 145 | -168 | 765 | 0 |
| 343 | 331 | Nov | 26 | 2016 | | 0 | 0 | 0 | 170 | -116 | 1,120 | 0 |
| 344 | 332 | Nov | 27 | 2016 | | 0 | 0 | 0 | 149 | 179 | 1,383 | 0 |
| 345 | 333 | Nov | 28 | 2016 | | 0 | 0 | 0 | 175 | 136 | 1,299 | 0 |
| 346 | 334 | Nov | 29 | 2016 | | 0 | 0 | 0 | 154 | -496 | 691 | 0 |
| 347 | 335 | Nov | 30 | 2016 | | 0 | 0 | 0 | 197 | -684 | 527 | 87 |


App. D - System Load Data

| | A | B | C | D | AG | AH | AI | AJ | AK | AL | AM | AN |
|-----|-------|-------|-----|------|----|----------------|------------|--------------|-----------------|-------------|-------------|--------------|
| | Seq # | Month | Day | Year | | EDDY CO Avg | PNM Avg | LAMAR Avg | LPL FLOW Avg | SWPP Avg | WIND Avg | SOLAR Avg |
| 10 | | | | | | | | | | | | |
| 11 | | | | | | | | | | | | |
| 12 | | | | | | | | | | | | |
| 348 | 336 | Dec | 1 | 2016 | | 0 | 0 | 0 | 188 | -253 | 217 | 76 |
| 349 | 337 | Dec | 2 | 2016 | | 0 | 0 | 0 | 212 | -170 | 550 | 0 |
| 350 | 338 | Dec | 3 | 2016 | | 0 | 0 | 0 | 205 | -481 | 245 | 0 |
| 351 | 339 | Dec | 4 | 2016 | | 0 | 0 | 0 | 208 | -255 | 514 | 79 |
| 352 | 340 | Dec | 5 | 2016 | | 0 | 0 | 0 | 172 | -245 | 1,169 | 13 |
| 353 | 341 | Dec | 6 | 2016 | | 0 | 0 | 0 | 193 | -129 | 1,221 | 0 |
| 354 | 342 | Dec | 7 | 2016 | | 0 | 0 | 0 | 238 | -252 | 1,280 | 0 |
| 355 | 343 | Dec | 8 | 2016 | | 0 | 0 | 0 | 235 | -182 | 456 | 0 |
| 356 | 344 | Dec | 9 | 2016 | | 0 | 0 | 0 | 258 | 302 | 979 | 29 |
| 357 | 345 | Dec | 10 | 2016 | | 0 | 0 | 0 | 215 | -83 | 1,147 | 7 |
| 358 | 346 | Dec | 11 | 2016 | | 0 | 0 | 0 | 193 | -386 | 491 | 12 |
| 359 | 347 | Dec | 12 | 2016 | | 0 | 0 | 0 | 171 | 274 | 894 | 0 |
| 360 | 348 | Dec | 13 | 2016 | | 0 | 0 | 0 | 181 | 167 | 841 | 0 |
| 361 | 349 | Dec | 14 | 2016 | | 0 | 0 | 0 | 202 | 377 | 870 | 0 |
| 362 | 350 | Dec | 15 | 2016 | | 0 | 0 | 0 | 193 | 138 | 829 | 0 |
| 363 | 351 | Dec | 16 | 2016 | | 0 | 0 | 0 | 204 | 271 | 1,655 | 0 |
| 364 | 352 | Dec | 17 | 2016 | | 0 | 0 | 0 | 213 | 259 | 1,274 | 1 |
| 365 | 353 | Dec | 18 | 2016 | | 0 | 0 | 0 | 225 | 349 | 259 | 38 |
| 366 | 354 | Dec | 19 | 2016 | | 0 | 0 | 0 | 239 | -87 | 928 | 72 |
| 367 | 355 | Dec | 20 | 2016 | | 0 | 0 | 0 | 230 | -344 | 490 | 30 |
| 368 | 356 | Dec | 21 | 2016 | | 0 | 0 | 0 | 183 | -291 | 1,297 | 0 |
| 369 | 357 | Dec | 22 | 2016 | | 0 | 0 | 0 | 188 | -660 | 279 | 3 |
| 370 | 358 | Dec | 23 | 2016 | | 0 | 0 | 0 | 157 | -293 | 1,018 | 40 |
| 371 | 359 | Dec | 24 | 2016 | | 0 | 0 | 0 | 179 | -139 | 932 | 23 |
| 372 | 360 | Dec | 25 | 2016 | | 0 | 0 | 0 | 157 | -45 | 1,393 | 0 |
| 373 | 361 | Dec | 26 | 2016 | | 0 | 0 | 0 | 186 | -467 | 427 | 74 |
| 374 | 362 | Dec | 27 | 2016 | | 0 | 0 | 0 | 199 | -526 | 674 | 32 |
| 375 | 363 | Dec | 28 | 2016 | | 0 | 0 | 0 | 182 | -259 | 1,300 | 49 |
| 376 | 364 | Dec | 29 | 2016 | | 0 | 0 | 0 | 169 | -95 | 1,149 | 0 |
| 377 | 365 | Dec | 30 | 2016 | | 0 | 0 | 0 | 205 | -461 | 1,591 | 10 |
| 378 | 366 | Dec | 31 | 2016 | | 0 | 0 | 0 | 184 | -645 | 669 | 76 |

App. D - System Load Data 6



App. D - System Load Data 6



Appendix E
Transmission Losses

| Line No. | Corona & Insulator Leakage Demand and Energy Losses | Miles | KW Loss/mile | Energy Losses MWH | Demand Losses MW |
|----------|---|--|--------------|----------------------|---------------------|
| 1 | 345 kV Line | 905.42 | 2.343 | 18,634 | 2.12 |
| 2 | 230 kV Line | 1,862.03 | 1.185 | 19,382 | 2.21 |
| 3 | 115 Kv Line | 3,140.28 | 0.403 | 11,116 | 1.27 |
| 4 | 69 kV Line | 1,547.58 | 0.197 | 2,678 | 0.30 |
| 5 | 7,455.31 Annual Losses | | | 51,811 MWH | 5.90 MW |
| 6 | Transmission Line Demand Loss | | | | |
| 7 | 345 kV Line | This data comes from the peak hour powerflow Case. App. N. | | | 8.26 |
| 8 | 230 kV Line | | | | 47.35 |
| 9 | 115 Kv Line | | | | 66.32 |
| 10 | 69 kV Line | | | | 19.19 |
| 11 | Transmission Line Energy Loss | | | | |
| 12 | Segment Name | Segment 1 | Segment 2 | Segment 3 | Segment 4 |
| 13 | Segment Load, MW | 3379.7 | 3323.4 | 4432.1 | 3386.9 |
| 14 | Segment Output to Lines, MWH | 4,685,818 | 7,256,647 | 10,175,397 | 9,640,414 |
| 15 | | Segment 1 | Segment 2 | Segment 3 | Segment 4 |
| 16 | | MW Loss | MWH Loss | MW Loss | MWH Loss |
| 17 | 345 kV Line | 8,960 | 12,422 | 21,512 | 30,989 |
| 18 | 230 kV Line | 27,264 | 37,801 | 40,522 | 44,361 |
| 19 | 115 Kv Line | 29,519 | 40,927 | 43,111 | 44,789 |
| 20 | 69 kV Line | 6,118 | 8,482 | 10,916 | 5,294 |
| 21 | | Factor | Factor | Factor | Factor |
| 22 | | 0.0027 | 0.0030 | 0.0017 | 0.0032 |
| 23 | | 0.0081 | 0.0146 | 0.0091 | 0.0133 |
| 24 | | 0.0087 | 0.0125 | 0.0097 | 0.0132 |
| 25 | | 0.0018 | 0.0018 | 0.0025 | 0.0016 |
| 26 | | | | | |
| 27 | | | | | |
| 28 | | | | | |
| 29 | | | | | |
| 30 | | | | | |
| 31 | | | | | |
| 32 | | | | | |
| 33 | | | | | |
| 34 | | | | | |
| 35 | | | | | |
| 36 | | | | | |
| 37 | | | | | |
| 38 | | | | | |
| 39 | | | | | |
| 40 | | | | | |
| 41 | | | | | |
| 42 | | | | | |
| 43 | | | | | |
| 44 | | | | | |
| 45 | | | | | |
| 46 | | | | | |
| 47 | | | | | |
| 48 | | | | | |
| 49 | | | | | |
| 50 | | | | | |
| 51 | | | | | |
| 52 | | | | | |
| 53 | | | | | |
| 54 | | | | | |
| 55 | | | | | |
| 56 | | | | | |
| 57 | | | | | |
| 58 | | | | | |
| 59 | | | | | |
| 60 | | | | | |
| 61 | | | | | |
| 62 | | | | | |
| 63 | | | | | |
| 64 | | | | | |
| 65 | | | | | |
| 66 | | | | | |
| 67 | | | | | |
| 68 | | | | | |
| 69 | | | | | |
| 70 | | | | | |
| 71 | | | | | |
| 72 | | | | | |
| 73 | | | | | |
| 74 | | | | | |
| 75 | | | | | |
| 76 | | | | | |
| 77 | | | | | |
| 78 | | | | | |
| 79 | | | | | |
| 80 | | | | | |
| 81 | | | | | |
| 82 | | | | | |
| 83 | | | | | |
| 84 | | | | | |
| 85 | | | | | |
| 86 | | | | | |
| 87 | | | | | |
| 88 | | | | | |
| 89 | | | | | |
| 90 | | | | | |
| 91 | | | | | |
| 92 | | | | | |
| 93 | | | | | |
| 94 | | | | | |
| 95 | | | | | |
| 96 | | | | | |
| 97 | | | | | |
| 98 | | | | | |
| 99 | | | | | |
| 100 | | | | | |
| 101 | | | | | |
| 102 | | | | | |
| 103 | | | | | |
| 104 | | | | | |
| 105 | | | | | |
| 106 | | | | | |
| 107 | | | | | |
| 108 | | | | | |
| 109 | | | | | |
| 110 | | | | | |
| 111 | | | | | |
| 112 | | | | | |
| 113 | | | | | |
| 114 | | | | | |
| 115 | | | | | |
| 116 | | | | | |
| 117 | | | | | |
| 118 | | | | | |
| 119 | | | | | |
| 120 | | | | | |
| 121 | | | | | |
| 122 | | | | | |
| 123 | | | | | |
| 124 | | | | | |
| 125 | | | | | |
| 126 | | | | | |
| 127 | | | | | |
| 128 | | | | | |
| 129 | | | | | |
| 130 | | | | | |
| 131 | | | | | |
| 132 | | | | | |
| 133 | | | | | |
| 134 | | | | | |
| 135 | | | | | |
| 136 | | | | | |
| 137 | | | | | |
| 138 | | | | | |
| 139 | | | | | |
| 140 | | | | | |
| 141 | | | | | |
| 142 | | | | | |
| 143 | | | | | |
| 144 | | | | | |
| 145 | | | | | |
| 146 | | | | | |
| 147 | | | | | |
| 148 | | | | | |
| 149 | | | | | |
| 150 | | | | | |
| 151 | | | | | |
| 152 | | | | | |
| 153 | | | | | |
| 154 | | | | | |
| 155 | | | | | |
| 156 | | | | | |
| 157 | | | | | |
| 158 | | | | | |
| 159 | | | | | |
| 160 | | | | | |
| 161 | | | | | |
| 162 | | | | | |
| 163 | | | | | |
| 164 | | | | | |
| 165 | | | | | |
| 166 | | | | | |
| 167 | | | | | |
| 168 | | | | | |
| 169 | | | | | |
| 170 | | | | | |
| 171 | | | | | |
| 172 | | | | | |
| 173 | | | | | |
| 174 | | | | | |
| 175 | | | | | |
| 176 | | | | | |
| 177 | | | | | |
| 178 | | | | | |
| 179 | | | | | |
| 180 | | | | | |
| 181 | | | | | |
| 182 | | | | | |
| 183 | | | | | |
| 184 | | | | | |
| 185 | | | | | |
| 186 | | | | | |
| 187 | | | | | |
| 188 | | | | | |
| 189 | | | | | |
| 190 | | | | | |
| 191 | | | | | |
| 192 | | | | | |
| 193 | | | | | |
| 194 | | | | | |
| 195 | | | | | |
| 196 | | | | | |
| 197 | | | | | |
| 198 | | | | | |
| 199 | | | | | |
| 200 | | | | | |
| 201 | | | | | |
| 202 | | | | | |
| 203 | | | | | |
| 204 | | | | | |
| 205 | | | | | |
| 206 | | | | | |
| 207 | | | | | |
| 208 | | | | | |
| 209 | | | | | |
| 210 | | | | | |
| 211 | | | | | |
| 212 | | | | | |
| 213 | | | | | |
| 214 | | | | | |
| 215 | | | | | |
| 216 | | | | | |
| 217 | | | | | |
| 218 | | | | | |
| 219 | | | | | |
| 220 | | | | | |
| 221 | | | | | |
| 222 | | | | | |
| 223 | | | | | |
| 224 | | | | | |
| 225 | | | | | |
| 226 | | | | | |
| 227 | | | | | |
| 228 | | | | | |
| 229 | | | | | |
| 230 | | | | | |
| 231 | | | | | |
| 232 | | | | | |
| 233 | | | | | |
| 234 | | | | | |
| 235 | | | | | |
| 236 | | | | | |
| 237 | | | | | |
| 238 | | | | | |
| 239 | | | | | |
| 240 | | | | | |
| 241 | | | | | |
| 242 | | | | | |
| 243 | | | | | |
| 244 | | | | | |
| 245 | | | | | |
| 246 | | | | | |
| 247 | | | | | |
| 248 | | | | | |
| 249 | | | | | |
| 250 | | | | | |
| 251 | | | | | |
| 252 | | | | | |
| 253 | | | | | |
| 254 | | | | | |
| 255 | | | | | |
| 256 | | | | | |
| 257 | | | | | |
| 258 | | | | | |
| 259 | | | | | |
| 260 | | | | | |
| 261 | | | | | |
| 262 | | | | | |
| 263 | | | | | |
| 264 | | | | | |
| 265 | | | | | |
| 266 | | | | | |
| 267 | | | | | |
| 268 | | | | | |
| 269 | | | | | |
| 270 | | | | | |
| 271 | | | | | |
| 272 | | | | | |
| 273 | | | | | |
| 274 | | | | | |
| 275 | | | | | |
| 276 | | | | | |
| 277 | | | | | |
| 278 | | | | | |
| 279 | | | | | |
| 280 | | | | | |
| 281 | | | | | |
| 282 | | | | | |
| 283 | | | | | |
| 284 | | | | | |
| 285 | | | | | |
| 286 | | | | | |
| 287 | | | | | |
| 288 | | | | | |
| 289 | | | | | |
| 290 | | | | | |
| 291 | | | | | |
| 292 | | | | | |
| 293 | | | | | |
| 294 | | | | | |
| 295 | | | | | |
| 296 | | | | | |
| 297 | | | | | |
| 298 | | | | | |
| 299 | | | | | |
| 300 | | | | | |
| 301 | | | | | |
| 302 | | | | | |
| 303 | | | | | |
| 304 | | | | | |
| 305 | | | | | |
| 306 | | | | | |
| 307 | | | | | |
| 308 | | | | | |
| 309 | | | | | |
| 310 | | | | | |
| 311 | | | | | |
| 312 | | | | | |
| 313 | | | | | |
| 314 | | | | | |
| 315 | | | | | |
| 316 | | | | | |
| 317 | | | | | |
| 318 | | | | | |
| 319 | | | | | |
| 320 | | | | | |
| 321 | | | | | |
| 322 | | | | | |
| 323 | | | | | |
| 324 | | | | | |
| 325 | | | | | |
| 326 | | | | | |
| 327 | | | | | |
| 328 | | | | | |
| 329 | | | | | |
| 330 | | | | | |
| 331 | | | | | |
| 332 | | | | | |
| 333 | | | | | |
| 334 | | | | | |
| 335 | | | | | |
| 336 | | | | | |
| 337 | | | | | |
| 338 | | | | | |
| 339 | | | | | |
| 340 | | | | | |
| 341 | | | | | |
| 342 | | | | | |
| 343 | | | | | |

Appendix F
Autotransformer Losses
Under Load

| | | | | | | | | | | | | | | | |
|----------|----------------------------------|---|------------------|-----------------|-------------------------------|------------------|-------------------|-------------------------------|------------------|-------------------|-------------------------------|------------------|-------------------|---------------------------------------|--|
| Line No. | | | | | | | | | | | | | | | |
| 1 | Autotransformer Line Demand Loss | | | | | | | | | | | | | | |
| 2 | MW | | | | | | | | | | | | | | |
| 3 | 345/230 kV Autos | This data comes from the peak hour powerflow. | | | | | | | | | | 0.80 | | | |
| 4 | | | | | | | | | | | | | | | |
| 5 | 230/115 kV Autos | | | | | | | | | | | 7.40 | | | |
| 6 | | | | | | | | | | | | | | | |
| 7 | 115/69 Kv Autos | | | | | | | | | | | 4.36 | | | |
| 8 | | | | | | | | | | | | | | | |
| 9 | | | | | | | | | | | | | | | |
| 10 | Autotransformer Energy Loss | | | | | | | | | | | | | | |
| 11 | | | | | | | | | | | | | | | |
| 12 | Segment Name | Segment 1 | Segment 2 | Segment 3 | Segment 4 | | | | | | | | | | |
| 13 | | | | | | | | | | | | | | | |
| 14 | Segment Load, MW | 3379.7 | 3323.4 | 4432.1 | 3386.9 | | | | | | | | | | |
| 15 | | | | | | | | | | | | | | | |
| 16 | Segment Output to Lines, MWH | 4,685,818 | 7,256,647 | 10,175,397 | 9,640,414 | | | | | | | | | | |
| 17 | | | | | | | | | | | | | | | |
| 18 | | | | | | | | | | | | | | | |
| 19 | | | | | | | | | | | | | | | |
| 20 | 345/230 kV Autos | MW Loss 0.674 | Factor 0.0002 | MWH Loss 934 | Segment 2 MW Loss 0.764 | Factor 0.0002 | MWH Loss 1,669 | Segment 3 MW Loss 0.853 | Factor 0.0002 | MWH Loss 1,959 | Segment 4 MW Loss 0.734 | Factor 0.0002 | MWH Loss 2,089 | Total Segment Losses, MWH 6,651 | |
| 21 | | | | | | | | | | | | | | | |
| 22 | 230/115 kV Autos | 4.880 | 0.0014 | 6,766 | 4.626 | 0.0014 | 10,101 | 5.503 | 0.0012 | 12,634 | 4.827 | 0.0014 | 13,740 | 43,241 | |
| 23 | | | | | | | | | | | | | | | |
| 24 | 115/69 Kv Autos | 2.564 | 0.0008 | 3,555 | 2.541 | 0.0008 | 5,548 | 3.202 | 0.0007 | 7,350 | 2.384 | 0.0007 | 6,785 | 23,239 | |
| 25 | | | | | | | | | | | | | | | |

Appendix G
Autotransformer
No-Load Losses

| Line No. | Location | Voltage | Nominal Rating MVA | Max Rating MVA | No Load Loss, Watts | Energy Losses, MWH | | | Demand Losses, KW | | |
|----------|-----------------|---------|--------------------------|----------------------|---------------------------|--------------------|--------|--------|-------------------|--------|--------|
| | | | | | | 345 Kv | 230 kV | 115 kV | 345 Kv | 230 kV | 115 kV |
| 1 | AMA_SOUTH | 230/120 | 135 | 252 | 55,500 | | 487.51 | | | 55.50 | |
| 2 | ARTESIA | 115/69 | 23.77 | 39.6 | 15,268 | | | 134.11 | | | 15.27 |
| 3 | ARTESIA | 115/69 | 23.77 | 39.6 | 15,268 | | | 134.11 | | | 15.27 |
| 4 | ATOKA | 115/69 | 23.77 | 39.62 | 21,060 | | | 184.99 | | | 21.06 |
| 5 | BAILEYCO | 115/69 | 50 | 84 | 17,540 | | | 154.07 | | | 17.54 |
| 6 | BAILEYCO | 115/69 | 50 | 84 | 18,460 | | | 162.15 | | | 18.46 |
| 7 | BLACKHAWK | 115/69 | 45 | 75 | 14,249 | | | 125.16 | | | 14.25 |
| 8 | BLACKHAWK | 115/69 | 45 | 75 | 14,335 | | | 125.92 | | | 14.34 |
| 9 | BOWERS | 120/69 | 45 | 84 | 14,340 | | | 125.96 | | | 14.34 |
| 10 | BOWERS | 115/69 | 50 | 84 | 20,615 | | | 181.08 | | | 20.62 |
| 11 | BUSHLAND | 230/115 | 90 | 150 | 86,001 | | 755.43 | | | 86.00 | |
| 12 | CARLISLE | 230/115 | 90 | 150 | 57,968 | | 509.19 | | | 57.97 | |
| 13 | CARLISLE | 115/69 | 23.77 | 39.62 | 18,380 | | | 161.45 | | | 18.38 |
| 14 | CARLSBAD | 115/69 | 23.77 | 39.62 | 22,450 | | | 197.20 | | | 22.45 |
| 15 | CARLSBAD | 115/69 | 23.77 | 39.62 | 16,900 | | | 148.45 | | | 16.90 |
| 16 | CASTRO_N | 120/69 | 45 | 84 | 14,901 | | | 130.89 | | | 14.90 |
| 17 | CASTRO_S | 120/69 | 45 | 84 | 14,917 | | | 131.03 | | | 14.92 |
| 18 | CHAVES CO INT E | 230/120 | 150 | 288 | 50,458 | | 443.22 | | | 50.46 | |
| 19 | CHAVES CO INT W | 230/120 | 135 | 252 | 61,380 | | 539.16 | | | 61.38 | |
| 20 | CHAVES INT | 115/69 | 23.77 | 39.62 | 18,700 | | | 164.26 | | | 18.70 |
| 21 | COCHRAN | 115/69 | 50 | 84 | 25,750 | | | 226.19 | | | 25.75 |
| 22 | COCHRAN | 115/69 | 50 | 84 | 26,050 | | | 228.82 | | | 26.05 |
| 23 | COULTER | 115/69 | 45 | 75 | 25,659 | | | 225.39 | | | 25.66 |
| 24 | COX | 120/69 | 45 | 84 | 17,390 | | | 152.75 | | | 17.39 |
| 25 | CROSBY | 115/69 | 50 | 84 | 18,920 | | | 166.19 | | | 18.92 |
| 26 | CROSBY | 115/69 | 50.4 | 84 | 19,647 | | | 172.58 | | | 19.65 |
| 27 | CUNNINGHAM | 230/115 | 90 | 150 | 84,128 | | 738.98 | | | 84.13 | |
| 28 | CURRY | 115/69 | 23.77 | 39.62 | 18,205 | | | 159.91 | | | 18.21 |
| 29 | CURRY | 115/69 | 23.77 | 39.62 | 20,110 | | | 176.65 | | | 20.11 |
| 30 | DALHART | 115/69 | 23.77 | 39.62 | 20,200 | | | 177.44 | | | 20.20 |
| 31 | DALLAM | 115/69 | 23.77 | 39.6 | 17,840 | | | 156.71 | | | 17.84 |
| 32 | DEAFSMITH | 230/120 | 150 | 250 | 39,230 | | 344.60 | | | 39.23 | |
| 33 | DEAFSMITH | 230/120 | 150 | 250 | 39,520 | | 347.14 | | | 39.52 | |
| 34 | DENVER_N | 115/69 | 50 | 84 | 18,660 | | | 163.91 | | | 18.66 |
| 35 | DENVER_S | 115/69 | 50 | 84 | 18,860 | | | 165.67 | | | 18.86 |
| 36 | DOSS | 115/69 | 50 | 84 | 17,000 | | | 149.33 | | | 17.00 |
| 37 | EAGLE_CREEK | 115/69 | 23.77 | 39.6 | 18,205 | | | 159.91 | | | 18.21 |
| 38 | EAST_PLANT | 230/120 | 135 | 252 | 71,492 | | 627.99 | | | 71.49 | |
| 39 | EAST_PLANT | 115/69 | 50 | 84 | 18,200 | | | 159.87 | | | 18.20 |
| 40 | EAST_PLANT | 115/69 | 50 | 84 | 17,340 | | | 152.31 | | | 17.34 |
| 41 | EDDY_CNTY | 345/230 | 300 | 560 | 75,788 | | 665.72 | | | 75.79 | |
| 42 | EDDY_NORTH | 230/115 | 150 | 250 | 37,500 | | 329.40 | | | 37.50 | |
| 43 | EDDY_SOUTH | 230/115 | 150 | 250 | 40,891 | | 359.19 | | | 40.89 | |
| 44 | FLOYD_CNTY | 115/69 | 50 | 84 | 26,300 | | | 231.02 | | | 26.30 |
| 45 | FLOYD_CNTY | 120/69 | 45 | 84 | 13,970 | | | 122.71 | | | 13.97 |
| 46 | GAINES | 115/69 | 23.77 | 39.6 | 10,900 | | | 95.75 | | | 10.90 |
| 47 | GAINES | 115/69 | 23.77 | 39.6 | 27,500 | | | 241.56 | | | 27.50 |
| 48 | GEORGIA | 115/69 | 45 | 75 | 20,602 | | | 180.97 | | | 20.60 |
| 49 | GRAHAM | 115/69 | 50 | 84 | 21,581 | | | 189.57 | | | 21.58 |
| 50 | GRAPEVINE | 230/115 | 150 | 250 | 38,500 | | 338.18 | | | 38.50 | |
| 51 | GRASSLAND | 230/115 | 150 | 250 | 41,860 | | 367.70 | | | 41.86 | |
| 52 | GRAY_CNTY | 115/69 | 45 | 75 | 24,519 | | | 215.37 | | | 24.52 |
| 53 | HALE_CNTY | 115/69 | 50 | 84 | 23,520 | | | 206.60 | | | 23.52 |
| 54 | HALE_CNTY | 115/69 | 50 | 84 | 23,910 | | | 210.03 | | | 23.91 |
| 55 | HAPPY_INT | 115/69 | 50 | 84 | 20,982 | | | 184.31 | | | 20.98 |
| 56 | HAPPY_INT | 115/69 | 50 | 84 | 22,351 | | | 196.33 | | | 22.35 |
| 57 | HEREFORD | 115/66 | 23.77 | 39.6 | 21,030 | | | 184.73 | | | 21.03 |
| 58 | HEREFORD | 115/69 | 23.77 | 39.6 | 23,340 | | | 205.02 | | | 23.34 |
| 59 | HITCHLAND | 345/230 | 336 | 560 | 86,954 | | 763.80 | | | 86.95 | |
| 60 | HITCHLAND | 230/115 | 150 | 250 | 62,938 | | | 552.85 | | 62.94 | |
| 61 | HITCHLAND | 345/230 | 336 | 560 | 74,704 | | 656.20 | | | 74.70 | |
| 62 | HOCKLEY | 115/69 | 50 | 84 | 25,080 | | | 220.30 | | | |
| 63 | HOCKLEY | 115/69 | 50 | 84 | 23,650 | | | 207.74 | | | 23.65 |
| 64 | HOWARD | 115/69 | 50 | 84 | 24,939 | | | 219.06 | | | 24.94 |
| 65 | HUTCH_S | 115/69 | 45 | 75 | 28,199 | | | 247.70 | | | 28.20 |
| 66 | HUTCHISON | 230/115 | 90 | 150 | 84,172 | | 739.37 | | | 84.17 | |
| 67 | HUTCHISON | 230/115 | 90 | 150 | 90,549 | | 795.38 | | | 90.55 | |
| 68 | KINGSMILL | 115/69 | 50 | 84 | 18,560 | | | 163.03 | | | 18.56 |
| 69 | KINGSMILL | 115/69 | 45 | 75 | 33,190 | | | 291.54 | | | 33.19 |
| 70 | KRESS_INT | 115/69 | 50 | 84 | 24,100 | | | 211.69 | | | 24.10 |
| 71 | LAMB_CNTY | 230/120 | 135 | 252 | 69,698 | | 612.23 | | | 69.70 | |
| 72 | LAMB_CNTY | 120/69 | 45 | 84 | 17,020 | | | 149.50 | | | 17.02 |
| 73 | LAMB_CNTY | 120/69 | 45 | 84 | 17,600 | | | 154.60 | | | 17.60 |
| 74 | LAMTON | 115/69 | 45 | 75 | 14,230 | | | 125.00 | | | 14.23 |
| 75 | LEGACY | 115/69 | 50 | 84 | 25,140 | | | 220.83 | | | 25.14 |
| 76 | LUBBCK_EST | 230/115 | 150 | 250 | 65,770 | | 577.72 | | | 65.77 | |
| 77 | LUBBCK_EST | 115/69 | 50 | 84 | 26,330 | | | 231.28 | | | 26.33 |
| 78 | LUBBCK_EST | 115/69 | 50 | 84 | 25,300 | | | 222.24 | | | 25.30 |
| 79 | LUBBCK_STH | 120/69 | 45 | 84 | 15,020 | | | 131.94 | | | 15.02 |
| 80 | LUBBCK_STH | 230/120 | 135 | 225 | 60,232 | | 529.08 | 529.08 | | 60.23 | |
| 81 | LUBBCK_STH | 230/115 | 150 | 288 | 40,980 | | 359.97 | | | 40.98 | |

Appendix G
Autotransformer
No-Load Losses

| Line No. | Location | Voltage | Nominal Rating MVA | Max Rating MVA | No Load Loss, Watts | Energy Losses, MWH | | | Demand Losses, KW | | |
|------------------------|--------------|---------|--------------------------|----------------------|---------------------------|---------------------------------|---------------|---------------|--------------------------------|---------------|---------------|
| | | | | | | 345 Kv | 230 kV | 115 kV | 345 Kv | 230 kV | 115 kV |
| 82 | LYNN_CNTY | 115/69 | 23.77 | 39.52 | 16,670 | | | 146.43 | | | 16.67 |
| 83 | LYNN_CNTY | 115/69 | 27 | 45 | 10,100 | | | 88.72 | | | 10.10 |
| 84 | MOORE_CNTY | 230/120 | 150 | 250 | 67,370 | | 591.78 | | | 67.37 | |
| 85 | MUSTANG | 230/115 | 150 | 250 | 66,670 | | 585.63 | | | 66.67 | |
| 86 | NE_HEREFORD | 120/69 | 50 | 84 | 19,000 | | | 166.90 | | | 19.00 |
| 87 | NE_HEREFORD | 115/69 | 50 | 84 | 18,840 | | | 165.49 | | | 18.84 |
| 88 | NEWHART | 230/120 | 150 | 250 | 37,900 | | | 332.91 | | | 37.90 |
| 89 | NICHOLS | 230/120 | 150 | 250 | 65,000 | | 570.96 | | | 65.00 | |
| 90 | NICHOLS | 230/120 | 150 | 250 | 66,200 | | 581.50 | | | 66.20 | |
| 91 | NORTHWEST | 120/69 | 45 | 84 | 14,390 | | | 126.40 | | | 14.39 |
| 92 | OASIS | 230/115 | 135 | 225 | 53,021 | | 465.74 | | | 53.02 | |
| 93 | OCHILTREE | 230/115 | 100 | 168 | 51,758 | | 454.64 | | | 51.76 | |
| 94 | PCA | 115/69 | 50 | 84 | 19,040 | | | 167.25 | | | 19.04 |
| 95 | PECOS | 230/115 | 90 | 150 | 50,428 | | 442.96 | | | 50.43 | |
| 96 | PERRYTON | 115/66 | 15 | 18.75 | 6,708 | | | 58.92 | | | 6.71 |
| 97 | PLANT_X | 230/120 | 135 | 225 | 71,721 | | 630.00 | | | 71.72 | |
| 98 | PORTALES | 115/69 | 45 | 70 | 11,167 | | | 98.09 | | | 11.17 |
| 99 | PORTALES | 115/69 | 45 | 70 | 14,894 | | | 130.83 | | | 14.89 |
| 100 | POTASH_JCT | 230/120 | 150 | 250 | 40,070 | | 351.97 | | | 40.07 | |
| 101 | POTASH_JCT | 115/69 | 50 | 84 | 20,961 | 184.12 | | 184.12 | | | 20.96 |
| 102 | POTASH_JCT | 115/69 | 23.77 | 39.62 | 25,320 | | | 222.41 | | | 25.32 |
| 103 | POTTER_CO | 345/230 | 150 | 250 | 65,980 | 579.57 | | | 65.98 | | |
| 104 | PRINGLE | 230/120 | 100 | 168 | 37,390 | | 328.43 | | | 37.39 | |
| 105 | RANDALL | 230/115 | 150 | 250 | 37,900 | | 332.91 | | | 37.90 | |
| 106 | RANDALL | 230/115 | 135 | 225 | 99,620 | | 875.06 | | | 99.62 | |
| 107 | RDRUNNER | 230/120 | 150 | 288 | 41,000 | | 360.14 | | | 41.00 | |
| 108 | RIVERVIEW | 115/69 | 23.77 | 39.63 | 24,770 | | | 217.58 | | | 24.77 |
| 109 | ROSEVELT_N | 230/115 | 135 | 225 | 52,272 | | 459.16 | | | 52.27 | |
| 110 | ROSWLL_INT | 115/69 | 23.77 | 39.62 | 18,740 | | | 164.61 | | | 18.74 |
| 111 | ROSWLL_INT | 115/69 | 23.77 | 44.37 | 17,400 | | 152.84 | | | | 17.40 |
| 112 | SEAGRAVES | 120/69 | 45 | 75 | 14,103 | | | 123.88 | | | 14.10 |
| 113 | SEMINOLE | 230/115 | 90 | 150 | 63,300 | | 556.03 | 556.03 | | 63.30 | |
| 114 | SEMINOLE | 230/115 | 90 | 150 | 58,700 | | 515.62 | | | 58.70 | |
| 115 | SEVEN_RIVERS | 115/69 | 90 | 150 | 58,220 | | | 511.40 | | | 58.22 |
| 116 | SEVEN_RIVERS | 230/115 | 23.77 | 39.62 | 15,520 | | 136.33 | | | 15.52 | |
| 117 | SPEARMAN | 115/69 | 50 | 84 | 24,620 | | | 216.26 | | | 24.62 |
| 118 | SULPHUR | 120/69 | 24 | 44.8 | 6,280 | | | 55.16 | | | 6.28 |
| 119 | SULPHUR | 120/69 | 24 | 44.8 | 8,900 | | | 78.18 | | | 8.90 |
| 120 | SUNDOWN | 230/118 | 100 | 166.66 | 60,604 | | 532.35 | | | 60.60 | |
| 121 | SWISHER | 230/115 | 150 | 288 | 40,270 | | 353.73 | | | 40.27 | |
| 122 | TERRY_CNTY | 115/69 | 50 | 84 | 24,480 | | | 215.03 | | | 24.48 |
| 123 | TERRY_CNTY | 115/69 | 50 | 84 | 24,050 | | | 211.26 | | | 24.05 |
| 124 | TOLK | 345/230 | 300 | 560 | 80,850 | 710.19 | | | 80.85 | | |
| 125 | TUCO_INT | 230/115 | 135 | 252 | 54,435 | | | 478.16 | | | 54.44 |
| 126 | TUCO_INT | 230/115 | 150 | 250 | 66,740 | | | 586.24 | | | 66.74 |
| 127 | TUCO_INT | 120/69 | 45 | 84 | 14,980 | | | 131.58 | | | 14.98 |
| 128 | TUCO_INT | 120/69 | 45 | 84 | 14,950 | | | 131.32 | | | 14.95 |
| 129 | TUCO_INT | 345/230 | 336 | 560 | 75,800 | 665.83 | | | 75.80 | | |
| 130 | TUCO_INT | 345/230 | 300 | 560 | 58,730 | 515.88 | | | 58.73 | | |
| 131 | TUCO_INT | 115/69 | 50 | 84 | 18,300 | | | 160.75 | | | 18.30 |
| 132 | TUCO_SVC | 230/13 | 90 | 150 | 39,090 | | 343.37 | | | 39.09 | |
| 133 | WHEELER | 230/120 | 150 | 250 | 62,631 | | 550.15 | | | 62.63 | |
| 134 | WOLFFORTH | 230/115 | 90 | 150 | 80,106 | | 703.65 | | | 80.11 | |
| 135 | YOAKUM | 230/115 | 90 | 150 | 69,850 | | 613.56 | | | 69.85 | |
| 136 | YOAKUM | 230/115 | 90 | 150 | 69,990 | | 614.79 | | | 69.99 | |
| | | | | | | Total Energy Losses, MWH | | | Total Demand Losses, KW | | |
| | | | | | | 345 Kv | 230 kV | 115 kV | 345 Kv | 230 kV | 115 kV |
| Hours in Period | | | | | | 4,741 | 21,905 | 17,276 | 519 | 2,539 | 1,755 |

APPENDIX H
USE BY LOSS LEVEL

Line No. SOUTHWESTERN PUBLIC SERVICE COMPANY
SCHEDULE: ADJUSTED TEST YEAR DATA BY RATE CLASS

TOTAL SYSTEM

FOR THE YEAR ENDED: DECEMBER 31, 2016

KWH ENERGY DELIVERED AT THE METER

(754,595,533)

| | Total Loss Level 6 | Total Loss Level 5 | Total Loss Level 4 | Total Loss Level 3 | Total Loss Level 2 | Total Retail | Wholesale 4 | Wholesale 3 | Wholesale 2 | Wholesale -@generator | Total Wholesale | Total System Energy |
|-------------|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|-----------------|----------------|----------------|----------------|--------------------------|--------------------|---------------------------|
| JANUARY '16 | 411,818,678 | 239,445,487 | 290,019,002 | 112,669,984 | 575,096,269 | 1,629,049,420 | 6,119,318 | 212,667,734 | 524,698,747 | 994,014 | 744,479,813 | 2,373,529,233 |
| FEBRUARY | 306,424,002 | 215,233,752 | 284,345,995 | 106,304,866 | 536,379,707 | 1,448,689,922 | 5,703,770 | 197,239,396 | 482,072,342 | 1,215,180 | 686,230,688 | 2,134,920,610 |
| MARCH | 274,044,235 | 235,445,146 | 307,275,100 | 115,241,024 | 575,920,992 | 1,507,926,097 | 6,627,423 | 251,879,763 | 515,210,580 | 1,265,837 | 774,983,603 | 2,282,908,700 |
| APRIL | 253,008,063 | 235,625,335 | 295,917,648 | 109,790,407 | 566,075,983 | 1,452,217,336 | 5,705,558 | 286,724,173 | 523,645,813 | 1,265,402 | 827,940,946 | 2,279,558,282 |
| MAY | 288,475,419 | 256,989,020 | 298,289,662 | 109,426,376 | 578,306,297 | 1,542,488,774 | 8,904,872 | 289,265,841 | 568,654,679 | 577,605 | 864,544,987 | 2,407,033,771 |
| JUNE | 406,851,507 | 300,650,169 | 296,223,566 | 107,963,511 | 579,057,304 | 1,690,685,157 | 8,904,872 | 353,598,849 | 666,014,213 | 661,620 | 1,029,179,589 | 2,719,864,746 |
| JULY | 507,898,658 | 363,164,023 | 316,969,540 | 112,379,069 | 602,921,193 | 1,903,332,703 | 10,761,338 | 596,342,978 | 917,704,745 | 728,004 | 1,425,737,065 | 3,329,069,768 |
| AUGUST | 423,304,713 | 329,159,595 | 314,011,852 | 114,821,152 | 610,482,006 | 1,796,769,918 | 10,046,554 | 516,345,423 | 740,498,309 | 830,696 | 1,267,721,184 | 3,064,511,102 |
| SEPTEMBER | 321,160,706 | 262,516,234 | 301,536,391 | 111,072,247 | 580,209,111 | 1,576,294,689 | 7,429,123 | 497,514,928 | 538,853,371 | 449,071 | 734,246,483 | 2,310,541,182 |
| OCTOBER | 272,653,649 | 239,186,166 | 314,376,279 | 107,582,599 | 594,932,589 | 1,546,631,681 | 6,546,395 | 294,780,726 | 509,908,761 | 247,567 | 762,355,449 | 2,311,025,130 |
| NOVEMBER | 288,654,629 | 249,034,357 | 297,597,740 | 105,665,493 | 574,825,518 | 1,516,946,067 | 6,166,397 | 222,506,172 | 470,704,438 | 24,434 | 689,397,591 | 2,216,546,068 |
| DECEMBER | 380,432,501 | 297,637,374 | 300,794,911 | 106,053,432 | 576,070,935 | 1,631,188,573 | 6,565,523 | 235,571,253 | 523,090,945 | 35,450 | 783,233,071 | 2,414,421,644 |
| TOTAL YEAR | 4,161,409,160 | 3,205,486,688 | 3,618,157,286 | 1,318,901,280 | 6,940,267,923 | 19,244,242,337 | 86,637,128 | 3,623,599,836 | 6,880,956,843 | 8,295,082 | 10,599,488,889 | 29,843,731,226 |

SOUTHWESTERN PUBLIC SERVICE COMPANY

SCHEDULE: ADJUSTED TEST YEAR DATA BY RATE CLASS

TOTAL SYSTEM

ADJUSTED CLASS COINCIDENT PEAK DEMAND

FOR THE YEAR ENDED: DECEMBER 31, 2016

ADJUSTED COINCIDENT PEAK DEMAND AT THE METER USING EXISTING LOSS FACTORS

| | Total Loss Level 6 | Total Loss Level 5 | Total Loss Level 4 | Total Loss Level 3 | Total Loss Level 2 | Total Retail | Total Wholesale 4 | Total Wholesale 3 | Total Wholesale 2 | Total Wholesale -@generator | Total Wholesale | Total System Demand |
|--------------|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|-----------------|-------------------------|-------------------------|-------------------------|-----------------------------------|--------------------|---------------------------|
| JANUARY '16 | 768,056 | 397,356 | 412,755 | 162,425 | 753,781 | 2,494,373 | 8,465 | 323,429 | 824,078 | 170 | 1,156,142 | 3,650,515 |
| FEBRUARY | 749,564 | 361,951 | 424,358 | 162,962 | 753,466 | 2,462,301 | 8,210 | 324,735 | 823,204 | 152 | 1,156,301 | 3,608,602 |
| MARCH | 640,780 | 360,817 | 416,098 | 162,601 | 712,659 | 2,192,925 | 9,207 | 366,246 | 762,313 | 4,381 | 1,142,149 | 3,335,074 |
| APRIL | 563,698 | 397,933 | 433,768 | 141,457 | 769,852 | 2,520,709 | 8,680 | 449,421 | 900,314 | 3,556 | 1,362,173 | 3,662,882 |
| MAY | 757,242 | 464,321 | 464,321 | 158,611 | 766,392 | 2,577,123 | 12,765 | 430,713 | 1,054,747 | 2,469 | 1,496,245 | 4,075,388 |
| JUNE | 1,069,093 | 541,535 | 457,105 | 157,320 | 853,280 | 3,076,342 | 12,765 | 700,985 | 1,269,058 | 16,599 | 2,009,111 | 5,077,453 |
| JULY | 1,154,734 | 690,746 | 419,381 | 156,553 | 854,639 | 3,165,282 | 15,593 | 834,832 | 1,409,556 | 422 | 2,361,368 | 5,521,453 |
| AUGUST | 1,050,761 | 600,746 | 419,381 | 156,553 | 854,639 | 3,165,282 | 15,593 | 834,832 | 1,409,556 | 422 | 2,361,368 | 5,521,453 |
| SEPTEMBER | 1,154,734 | 690,746 | 419,381 | 156,553 | 854,639 | 3,165,282 | 15,593 | 834,832 | 1,409,556 | 422 | 2,361,368 | 5,521,453 |
| OCTOBER | 613,095 | 409,727 | 409,727 | 146,216 | 785,125 | 2,471,422 | 10,345 | 393,492 | 1,003,893 | 984 | 1,355,042 | 3,432,398 |
| NOVEMBER | 613,095 | 409,727 | 409,727 | 146,216 | 785,125 | 2,471,422 | 10,345 | 393,492 | 1,003,893 | 984 | 1,355,042 | 3,432,398 |
| DECEMBER | 823,122 | 463,422 | 436,073 | 144,537 | 829,025 | 2,431,297 | 11,136 | 393,492 | 808,463 | 42 | 1,213,131 | 3,626,428 |
| AT Peak Hour | 1,114,734 | 640,746 | 419,391 | 155,553 | 834,859 | 3,165,282 | 17,363 | 934,932 | 1,409,556 | - | 2,361,851 | 5,527,133 |
| MAX PEAK | 1,114,734 | 640,746 | 480,798 | 170,214 | 853,280 | 3,165,282 | 17,363 | 935,031 | 1,409,556 | 4,381 | 2,361,851 | 5,527,133 |
| | | | | | | | | | | | | |

SOUTHWESTERN PUBLIC SERVICE COMPANY

SCHEDULE: ADJUSTED TEST YEAR DATA BY RATE CLASS

TOTAL SYSTEM

LOAD FACTOR USING KWH DELIVERED AND MAX KW AT THE METER

FOR THE YEAR ENDED: DECEMBER 31, 2016

LOAD FACTOR AT THE LOSS LEVEL

| | Total Loss Level 6 | Total Loss Level 5 | Total Loss Level 4 | Total Loss Level 3 | Total Loss Level 2 | Total Loss Level 1 | Total System Demand | HOURS |
|-------------|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|---------------------------|-------------|
| JANUARY '16 | 0.720676 | 0.751112 | 0.802575 | 0.825421 | 0.873566 | 0.873912 | 0.873912 | 744 |
| FEBRUARY | 0.674315 | 0.755302 | 0.788656 | 0.849591 | 0.850029 | 0.850029 | 0.850029 | 696 29 days |
| MARCH | 0.681163 | 0.759563 | 0.834074 | 0.862280 | 0.920747 | 0.920048 | 0.920048 | 744 |
| APRIL | 0.652986 | 0.712783 | 0.786737 | 0.836878 | 0.890021 | 0.899667 | 0.899667 | 720 |
| MAY | 0.652986 | 0.712783 | 0.786737 | 0.836878 | 0.890021 | 0.899667 | 0.899667 | 744 |
| JUNE | 0.528652 | 0.610098 | 0.674764 | 0.695772 | 0.742710 | 0.742531 | 0.742531 | 720 |
| JULY | 0.612397 | 0.666931 | 0.734996 | 0.781101 | 0.809385 | 0.809562 | 0.809562 | 744 |
| AUGUST | 0.543443 | 0.609974 | 0.675032 | 0.706414 | 0.759056 | 0.759203 | 0.759203 | 720 |
| SEPTEMBER | 0.521849 | 0.598943 | 0.697288 | 0.726975 | 0.776614 | 0.776580 | 0.776580 | 744 |
| OCTOBER | 0.597528 | 0.674446 | 0.736991 | 0.779300 | 0.841644 | 0.841691 | 0.841691 | 744 |
| NOVEMBER | 0.914387 | 0.828219 | 0.866342 | 0.860607 | 0.860607 | 0.872911 | 0.872911 | 720 |
| DECEMBER | 0.637542 | 0.740099 | 0.818669 | 0.832586 | 0.876004 | 0.875538 | 0.875538 | 744 |
| ANNUAL LF | 0.424988 | 0.477745 | 0.559290 | 0.542772 | 0.604185 | 0.614697 | 0.614697 | 8764 |

APPENDIX H
USE BY LOSS LEVEL

Line No. SOUTHWESTERN PUBLIC SERVICE COMPANY
SCHEDULE: ADJUSTED TEST YEAR DATA BY RATE CLASS

TOTAL SYSTEM

FOR THE YEAR ENDED: DECEMBER 31, 2016

KWH ENERGY DELIVERED AT THE METER

| | Residential - NM Water Heating | Residential RTX & RLNM | Residential RHTX & RHNM | Total Residential | NM & TX Small General Service | NM & TX Street Lighting | NM & TX Area Lighting | NM & TX Small Muni and School Service | TX Large Municipal Service | Total Loss Level 6 |
|----|-----------------------------------|---------------------------|----------------------------|----------------------|-------------------------------------|-------------------------------|-----------------------------|---|----------------------------------|--------------------------|
| 1 | - | 206,412,082 | 145,317,508 | 351,729,590 | 37,750,297 | 3,996,739 | 3,431,824 | 3,085,235 | 11,784,993 | 411,818,678 |
| 2 | - | 154,814,527 | 99,594,841 | 254,409,369 | 30,777,989 | 3,738,885 | 3,210,416 | 2,457,716 | 11,831,628 | 305,426,002 |
| 3 | - | 140,862,410 | 80,070,342 | 220,932,752 | 30,501,449 | 3,996,739 | 3,431,824 | 2,329,987 | 12,851,485 | 274,044,235 |
| 4 | - | 133,520,374 | 68,171,570 | 201,691,944 | 30,508,950 | 3,867,812 | 3,321,120 | 2,172,300 | 12,045,938 | 253,608,063 |
| 5 | - | 166,371,838 | 100,582,323 | 242,284,161 | 33,743,022 | 3,996,739 | 3,431,824 | 2,249,578 | 12,760,096 | 298,475,419 |
| 6 | - | 240,357,451 | 100,559,271 | 340,916,722 | 41,867,532 | 3,867,812 | 3,321,120 | 2,506,365 | 14,371,957 | 406,851,507 |
| 7 | - | 303,377,266 | 122,396,782 | 425,774,048 | 55,311,750 | 4,010,381 | 3,437,253 | 3,024,990 | 16,340,435 | 507,898,858 |
| 8 | - | 253,154,894 | 101,177,960 | 354,332,854 | 46,655,990 | 4,010,381 | 3,437,253 | 2,786,668 | 14,881,545 | 425,304,713 |
| 9 | - | 186,698,155 | 76,249,227 | 262,947,382 | 34,491,249 | 3,861,014 | 3,326,374 | 2,351,286 | 12,405,769 | 321,160,706 |
| 10 | - | 154,662,037 | 65,113,598 | 219,775,634 | 30,642,944 | 3,861,014 | 3,437,253 | 2,281,667 | 12,405,769 | 272,553,649 |
| 11 | - | 136,701,686 | 80,634,409 | 219,336,094 | 29,814,985 | 3,861,014 | 3,326,374 | 2,352,235 | 11,724,126 | 286,834,829 |
| 12 | - | 211,169,576 | 121,593,034 | 332,762,610 | 35,957,942 | 4,010,381 | 3,437,253 | 2,968,329 | 11,275,985 | 390,432,501 |
| 13 | - | 2,312,023,296 | 1,136,860,884 | 3,448,884,181 | 440,264,100 | 47,268,278 | 40,549,888 | 30,566,358 | 153,876,356 | 4,161,409,160 |

SOUTHWESTERN PUBLIC SERVICE COMPANY
SCHEDULE: ADJUSTED TEST YEAR DATA BY RATE CLASS

TOTAL SYSTEM

FOR THE YEAR ENDED: DECEMBER 31, 2016

ADJUSTED COINCIDENT PEAK DEMAND AT THE METER USING EXISTING LOSS FACTORS

| | Residential - NM Water Heating | Residential RTX & RLNM | Residential RHTX & RHNM | Total Residential | NM & TX Small General Service | NM & TX Street Lighting | NM & TX Area Lighting | NM & TX Small Muni and School Service | TX Large Municipal Service | Total Loss Level 6 |
|----|-----------------------------------|---------------------------|----------------------------|----------------------|-------------------------------------|-------------------------------|-----------------------------|---|----------------------------------|--------------------------|
| 1 | - | 385,452 | 286,647 | 682,099 | 61,122 | - | - | 5,193 | 19,642 | 768,056 |
| 2 | - | 388,920 | 312,555 | 671,475 | 56,988 | - | - | 4,601 | 16,500 | 749,564 |
| 3 | - | 288,519 | 205,400 | 473,919 | 45,250 | - | - | 4,169 | 17,412 | 540,750 |
| 4 | - | 446,078 | 211,003 | 657,081 | 49,912 | - | - | 2,736 | 20,501 | 563,688 |
| 5 | - | 678,538 | 289,848 | 968,386 | 76,323 | - | - | 3,100 | 20,736 | 757,242 |
| 6 | - | 680,705 | 292,098 | 972,803 | 108,913 | - | - | 3,746 | 21,563 | 1,069,093 |
| 7 | - | 543,402 | 271,558 | 814,960 | 108,913 | - | - | 4,604 | 23,234 | 1,114,734 |
| 8 | - | 543,402 | 271,558 | 814,960 | 108,913 | - | - | 4,604 | 23,234 | 1,114,734 |
| 9 | - | 380,801 | 163,983 | 544,783 | 68,990 | - | - | 4,292 | 19,411 | 854,761 |
| 10 | - | 270,287 | 104,300 | 374,587 | 47,173 | - | - | 3,558 | 17,571 | 613,085 |
| 11 | - | 439,543 | 287,496 | 727,040 | 62,090 | 5,390 | 4,620 | 3,410 | 18,302 | 440,239 |
| 12 | - | 690,776 | 282,008 | 972,784 | 108,913 | - | - | 5,160 | 18,823 | 823,122 |
| 13 | - | 690,776 | 312,555 | 972,784 | 108,913 | - | - | 4,804 | 28,234 | 1,114,734 |
| 14 | - | 690,776 | 312,555 | 972,784 | 108,913 | - | - | 5,194 | 28,234 | 1,114,734 |

APPENDIX H
USE BY LOSS LEVEL

Line No. SOUTHWESTERN PUBLIC SERVICE COMPANY
1 SCHEDULE: ADJUSTED TEST YEAR DATA BY RATE CLASS
2 TOTAL SYSTEM
3 FOR THE YEAR ENDED: DECEMBER 31, 2016
4 KWH ENERGY DELIVERED AT THE METER

| NM & TX Irrigation Service | NM Municipal and Schol Service | NM & TX Sec General Service | Total | | |
|----------------------------------|--------------------------------------|-----------------------------------|-----------------------|------------------|---------------|
| | | | LSSTX Large School | TX Loss Level | TX SAS-8 |
| 5 | 977,762 | 8,774,453 | 214,981,258 | 14,702,014 | 239,445,487 |
| 6 | 2,645,415 | 8,207,735 | 190,782,740 | 13,697,862 | 3,701,815 |
| 7 | 6,370,298 | 8,581,678 | 207,682,633 | 12,820,539 | 235,445,146 |
| 8 | 7,572,068 | 8,683,421 | 207,302,890 | 13,068,966 | 238,825,335 |
| 9 | 8,426,589 | 10,006,879 | 224,789,925 | 13,765,617 | 256,989,020 |
| 10 | 10,962,920 | 10,549,669 | 266,246,677 | 12,891,103 | 300,650,169 |
| 11 | 14,315,816 | 12,461,836 | 321,633,492 | 14,752,879 | 363,164,023 |
| 12 | 9,913,619 | 12,163,143 | 230,137,385 | 16,946,248 | 338,159,595 |
| 13 | 4,932,125 | 10,942,900 | 230,852,242 | 16,188,957 | 282,516,234 |
| 14 | 4,932,125 | 9,950,621 | 230,871,985 | 14,406,732 | 259,186,166 |
| 15 | 1,074,003 | 8,226,042 | 226,302,665 | 12,632,647 | 249,034,387 |
| 16 | 1,083,803 | 8,260,859 | 235,515,551 | 12,967,162 | 257,837,374 |
| 17 | 73,323,473 | 116,206,036 | 2,847,119,444 | 168,837,734 | 3,205,486,687 |
| 18 | | | | | |
| 19 | | | | | |
| 20 | | | | | |
| 21 | | | | | |
| 22 | | | | | |
| 23 | | | | | |
| 24 | | | | | |
| 25 | | | | | |
| 26 | | | | | |
| 27 | | | | | |
| 28 | | | | | |
| 29 | | | | | |
| 30 | | | | | |
| 31 | | | | | |
| 32 | | | | | |
| 33 | | | | | |
| 34 | | | | | |
| 35 | | | | | |
| 36 | | | | | |
| 37 | 712 | 14,731 | 345,139 | 36,774 | 2,964 |
| 38 | 1,279 | 14,480 | 316,391 | 29,852 | 3,052 |
| 39 | 6,684 | 12,863 | 310,004 | 31,257 | 3,867 |
| 40 | 11,252 | 15,724 | 342,863 | 22,094 | 4,463 |
| 41 | 16,159 | 16,062 | 383,626 | 22,111 | 4,465 |
| 42 | 18,089 | 21,400 | 460,501 | 21,155 | 5,186 |
| 43 | 19,965 | 23,342 | 567,267 | 30,572 | 4,958 |
| 44 | 23,342 | 23,342 | 557,146 | 30,572 | 4,958 |
| 45 | 9,432 | 24,697 | 427,104 | 38,704 | 3,577 |
| 46 | 6,362 | 19,593 | 396,008 | 25,648 | 3,675 |
| 47 | 5,392 | 22,288 | 406,768 | 29,034 | 3,155 |
| 48 | 1,629 | 11,223 | 323,608 | 17,734 | 2,898 |
| 49 | | | | | |
| 50 | 18,905 | 23,942 | 567,327 | 30,572 | 6,958 |
| 51 | 18,905 | 24,697 | 567,327 | 36,774 | 6,959 |
| 52 | | | | | |
| 53 | | | | | |
| 54 | | | | | |
| 55 | | | | | |
| 56 | | | | | |
| 57 | | | | | |
| 58 | | | | | |
| 59 | | | | | |
| 60 | | | | | |
| 61 | | | | | |
| 62 | | | | | |
| 63 | | | | | |
| 64 | | | | | |
| 65 | | | | | |
| 66 | | | | | |
| 67 | | | | | |
| 68 | | | | | |
| 69 | | | | | |
| 70 | | | | | |
| 71 | | | | | |
| 72 | | | | | |
| 73 | | | | | |
| 74 | | | | | |
| 75 | | | | | |
| 76 | | | | | |
| 77 | | | | | |
| 78 | | | | | |

SOUTHWESTERN PUBLIC SERVICE COMPANY
SCHEDULE: ADJUSTED TEST YEAR DATA BY RATE CLASS
TOTAL SYSTEM
ADJUSTED CLASS COINCIDENT PEAK DEMAND
FOR THE YEAR ENDED: DECEMBER 31, 2016

ADJUSTED COINCIDENT PEAK DEMAND AT THE METER USING EXISTING LOSS FACTORS

| | NM Irrigation Service | NM Municipal and Schol Service | NM & TX Sec General Service | TX LSSTX - Pri Large School | TX LMSTX - Pri Large Municipal | TX LSSTX - Pri Large School | TX Primary LGS SAS-8 | TX Primary QF Standby | Primary Low Load Factor | NM & TX Primary General Service | Total Loss Level 4 |
|----|-----------------------------|--------------------------------------|-----------------------------------|-----------------------------------|--------------------------------------|-----------------------------------|----------------------------|-----------------------------|-------------------------------|---------------------------------------|--------------------------|
| 36 | | | | | | | | | | | |
| 37 | 712 | 14,731 | 345,139 | 36,774 | 2,964 | 519 | 5,419 | 325 | 18 | 389,511 | 412,755 |
| 38 | 1,279 | 14,480 | 316,391 | 29,852 | 3,052 | 456 | 5,051 | 168 | 18 | 405,684 | 424,388 |
| 39 | 6,684 | 12,863 | 310,004 | 31,257 | 3,867 | 524 | 5,660 | 140 | 18 | 380,044 | 410,088 |
| 40 | 11,252 | 15,724 | 342,863 | 22,094 | 4,463 | 388 | 5,129 | 32 | 16 | 406,943 | 433,768 |
| 41 | 16,159 | 16,062 | 383,626 | 22,111 | 4,465 | 388 | 5,129 | 34 | 18 | 433,979 | 464,521 |
| 42 | 18,089 | 21,400 | 460,501 | 21,155 | 5,186 | 425 | 5,085 | 146 | 16 | 423,462 | 457,105 |
| 43 | 19,965 | 23,342 | 567,267 | 30,572 | 4,958 | 604 | 5,172 | 133 | 28 | 493,391 | 493,391 |
| 44 | 23,342 | 23,342 | 557,146 | 30,572 | 4,958 | 604 | 5,172 | 133 | 28 | 493,391 | 493,391 |
| 45 | 9,432 | 24,697 | 427,104 | 38,704 | 3,577 | 690 | 4,629 | 460 | 32 | 36,292 | 409,245 |
| 46 | 6,362 | 19,593 | 396,008 | 25,648 | 3,675 | 469 | 6,612 | 53 | 16 | 451,328 | 480,798 |
| 47 | 5,392 | 22,288 | 406,768 | 29,034 | 3,155 | 496 | 5,120 | 509 | 1,241 | 407,649 | 436,073 |
| 48 | 1,629 | 11,223 | 323,608 | 17,734 | 2,898 | 257 | 3,987 | 140 | 19 | 362,284 | 380,230 |
| 49 | | | | | | | | | | | |
| 50 | 18,905 | 23,942 | 567,327 | 30,572 | 6,958 | 604 | 5,172 | 83 | 26 | 392,123 | 419,391 |
| 51 | 18,905 | 24,697 | 567,327 | 36,774 | 6,959 | 681 | 6,612 | 509 | 1,241 | 451,328 | 480,798 |
| 52 | | | | | | | | | | | |
| 53 | | | | | | | | | | | |
| 54 | | | | | | | | | | | |
| 55 | | | | | | | | | | | |
| 56 | | | | | | | | | | | |
| 57 | | | | | | | | | | | |
| 58 | | | | | | | | | | | |
| 59 | | | | | | | | | | | |
| 60 | | | | | | | | | | | |
| 61 | | | | | | | | | | | |
| 62 | | | | | | | | | | | |
| 63 | | | | | | | | | | | |
| 64 | | | | | | | | | | | |
| 65 | | | | | | | | | | | |
| 66 | | | | | | | | | | | |
| 67 | | | | | | | | | | | |
| 68 | | | | | | | | | | | |
| 69 | | | | | | | | | | | |
| 70 | | | | | | | | | | | |
| 71 | | | | | | | | | | | |
| 72 | | | | | | | | | | | |
| 73 | | | | | | | | | | | |
| 74 | | | | | | | | | | | |
| 75 | | | | | | | | | | | |
| 76 | | | | | | | | | | | |
| 77 | | | | | | | | | | | |
| 78 | | | | | | | | | | | |

APPENDIX H
USE BY LOSS LEVEL

Line No. SOUTHWESTERN PUBLIC SERVICE COMPANY
1 SCHEDULE: ADJUSTED TEST YEAR DATA BY RATE CLASS

2 TOTAL SYSTEM

3 FOR THE YEAR ENDED: DECEMBER 31, 2016

4 KWH ENERGY DELIVERED AT THE METER

| | Sub-Trans. | | | Total | | | Transmission | | | Total | |
|----|------------|---------|------------|-------|---------|------------|--------------|---------|------------|------------|---|
| | LGS | Standby | Loss Level | LGS | Standby | Loss Level | LGS | Standby | Generation | Loss Level | 2 |
| 5 | | | | | | | | | | | |
| 6 | | | | | | | | | | | |
| 7 | | | | | | | | | | | |
| 8 | | | | | | | | | | | |
| 9 | | | | | | | | | | | |
| 10 | | | | | | | | | | | |
| 11 | | | | | | | | | | | |
| 12 | | | | | | | | | | | |
| 13 | | | | | | | | | | | |
| 14 | | | | | | | | | | | |
| 15 | | | | | | | | | | | |
| 16 | | | | | | | | | | | |
| 17 | | | | | | | | | | | |
| 18 | | | | | | | | | | | |
| 19 | | | | | | | | | | | |
| 20 | | | | | | | | | | | |
| 21 | | | | | | | | | | | |
| 22 | | | | | | | | | | | |
| 23 | | | | | | | | | | | |
| 24 | | | | | | | | | | | |
| 25 | | | | | | | | | | | |
| 26 | | | | | | | | | | | |
| 27 | | | | | | | | | | | |
| 28 | | | | | | | | | | | |
| 29 | | | | | | | | | | | |
| 30 | | | | | | | | | | | |
| 31 | | | | | | | | | | | |
| 32 | | | | | | | | | | | |
| 33 | | | | | | | | | | | |
| 34 | | | | | | | | | | | |
| 35 | | | | | | | | | | | |
| 36 | | | | | | | | | | | |
| 37 | | | | | | | | | | | |
| 38 | | | | | | | | | | | |
| 39 | | | | | | | | | | | |
| 40 | | | | | | | | | | | |
| 41 | | | | | | | | | | | |
| 42 | | | | | | | | | | | |
| 43 | | | | | | | | | | | |
| 44 | | | | | | | | | | | |
| 45 | | | | | | | | | | | |
| 46 | | | | | | | | | | | |
| 47 | | | | | | | | | | | |
| 48 | | | | | | | | | | | |
| 49 | | | | | | | | | | | |
| 50 | | | | | | | | | | | |
| 51 | | | | | | | | | | | |
| 52 | | | | | | | | | | | |
| 53 | | | | | | | | | | | |
| 54 | | | | | | | | | | | |
| 55 | | | | | | | | | | | |
| 56 | | | | | | | | | | | |
| 57 | | | | | | | | | | | |
| 58 | | | | | | | | | | | |
| 59 | | | | | | | | | | | |
| 60 | | | | | | | | | | | |
| 61 | | | | | | | | | | | |
| 62 | | | | | | | | | | | |
| 63 | | | | | | | | | | | |
| 64 | | | | | | | | | | | |
| 65 | | | | | | | | | | | |
| 66 | | | | | | | | | | | |
| 67 | | | | | | | | | | | |
| 68 | | | | | | | | | | | |
| 69 | | | | | | | | | | | |
| 70 | | | | | | | | | | | |
| 71 | | | | | | | | | | | |
| 72 | | | | | | | | | | | |
| 73 | | | | | | | | | | | |
| 74 | | | | | | | | | | | |
| 75 | | | | | | | | | | | |
| 76 | | | | | | | | | | | |
| 77 | | | | | | | | | | | |
| 78 | | | | | | | | | | | |

SOUTHWESTERN PUBLIC SERVICE COMPANY
SCHEDULE: ADJUSTED TEST YEAR DATA BY RATE CLASS

TOTAL SYSTEM

ADJUSTED CLASS COINCIDENT PEAK DEMAND

FOR THE YEAR ENDED: DECEMBER 31, 2016

ADJUSTED COINCIDENT PEAK DEMAND AT THE METER USING EXISTING LOSS FACTORS

| | Sub-Trans. | | | Total | | | Transmission | | | Total | |
|----|------------|---------|------------|-------|---------|------------|--------------|---------|------------|------------|---|
| | LGS | Standby | Loss Level | LGS | Standby | Loss Level | LGS | Standby | Generation | Loss Level | 2 |
| 36 | | | | | | | | | | | |
| 37 | | | | | | | | | | | |
| 38 | | | | | | | | | | | |
| 39 | | | | | | | | | | | |
| 40 | | | | | | | | | | | |
| 41 | | | | | | | | | | | |
| 42 | | | | | | | | | | | |
| 43 | | | | | | | | | | | |
| 44 | | | | | | | | | | | |
| 45 | | | | | | | | | | | |
| 46 | | | | | | | | | | | |
| 47 | | | | | | | | | | | |
| 48 | | | | | | | | | | | |
| 49 | | | | | | | | | | | |
| 50 | | | | | | | | | | | |
| 51 | | | | | | | | | | | |
| 52 | | | | | | | | | | | |
| 53 | | | | | | | | | | | |
| 54 | | | | | | | | | | | |
| 55 | | | | | | | | | | | |
| 56 | | | | | | | | | | | |
| 57 | | | | | | | | | | | |
| 58 | | | | | | | | | | | |
| 59 | | | | | | | | | | | |
| 60 | | | | | | | | | | | |
| 61 | | | | | | | | | | | |
| 62 | | | | | | | | | | | |
| 63 | | | | | | | | | | | |
| 64 | | | | | | | | | | | |
| 65 | | | | | | | | | | | |
| 66 | | | | | | | | | | | |
| 67 | | | | | | | | | | | |
| 68 | | | | | | | | | | | |
| 69 | | | | | | | | | | | |
| 70 | | | | | | | | | | | |
| 71 | | | | | | | | | | | |
| 72 | | | | | | | | | | | |
| 73 | | | | | | | | | | | |
| 74 | | | | | | | | | | | |
| 75 | | | | | | | | | | | |
| 76 | | | | | | | | | | | |
| 77 | | | | | | | | | | | |
| 78 | | | | | | | | | | | |

APPENDIX H
USE BY LOSS LEVEL

Line No. SOUTHWESTERN PUBLIC SERVICE COMPANY
1 SCHEDULE: ADJUSTED TEST YEAR DATA BY RATE CLASS

2 **TOTAL SYSTEM**

3 FOR THE YEAR ENDED: DECEMBER 31, 2016

4 **KWH ENERGY DELIVERED AT THE METER**

| | Total Wholesale Loss Level 4 | Total Wholesale LL 3 | Total Wholesale LL 2 | @ Generation Wholesale LL 1 | Total Wholesale |
|----|------------------------------------|----------------------------|----------------------------|-----------------------------------|--------------------|
| 5 | | | | | |
| 6 | | | | | |
| 7 | | | | | |
| 8 | | | | | |
| 9 | | | | | |
| 10 | 6,119,318 | 212,667,734 | 524,895,747 | 994,014 | 744,479,814 |
| 11 | 5,703,770 | 197,239,396 | 482,072,342 | 1,215,180 | 686,230,688 |
| 12 | 6,627,423 | 251,879,763 | 515,210,580 | 1,265,837 | 774,953,603 |
| 13 | 5,705,558 | 296,724,173 | 523,645,813 | 1,265,402 | 827,340,346 |
| 14 | 6,046,872 | 289,265,841 | 588,654,679 | 577,605 | 864,544,986 |
| 15 | 8,904,907 | 353,588,649 | 666,014,213 | 661,620 | 1,029,179,589 |
| 16 | 10,761,338 | 596,542,978 | 817,704,745 | 728,004 | 1,425,737,065 |
| 17 | 10,046,554 | 516,345,423 | 740,498,309 | 830,898 | 1,267,721,164 |
| 18 | 7,423,123 | 187,514,928 | 538,653,371 | 449,071 | 734,246,492 |
| 19 | 6,946,395 | 245,780,725 | 509,803,761 | 247,567 | 762,383,449 |
| 20 | 6,166,347 | 222,505,722 | 470,704,438 | 24,434 | 689,397,991 |
| 21 | 6,985,523 | 253,521,253 | 523,090,845 | 35,450 | 783,233,072 |
| 22 | | | | | |
| 23 | 147,312,062 | 344,822,539 | 492,134,601 | 8,295,083 | 10,599,488,890 |
| 24 | | | | | |
| 25 | | | | | |

26 SOUTHWESTERN PUBLIC SERVICE COMPANY
27 SCHEDULE: ADJUSTED TEST YEAR DATA BY RATE CLASS

28 **TOTAL SYSTEM**

29 ADJUSTED CLASS COINCIDENT PEAK DEMAND

30 FOR THE YEAR ENDED: DECEMBER 31, 2016

31 **ADJUSTED COINCIDENT PEAK DEMAND AT THE METER USING EXISTING LOSS FACTORS**

| | Total Loss Level 4 | Total Wholesale LL 3 | Total Wholesale LL 2 | @ Generation Wholesale LL 1 | Total Wholesale |
|----|-----------------------|----------------------------|----------------------------|-----------------------------------|--------------------|
| 32 | | | | | |
| 33 | | | | | |
| 34 | | | | | |
| 35 | | | | | |
| 36 | | | | | |
| 37 | 8,465 | 323,429 | 824,078 | 170 | 1,156,142 |
| 38 | 8,210 | 324,735 | 823,204 | 152 | 1,156,300 |
| 39 | 9,207 | 366,248 | 762,313 | 4,381 | 1,142,149 |
| 40 | 8,680 | 449,421 | 900,314 | 3,558 | 1,362,173 |
| 41 | 12,785 | 430,713 | 1,054,747 | - | 1,486,245 |
| 42 | 10,589 | 500,985 | 1,289,058 | 2,469 | 2,009,111 |
| 43 | 17,363 | 694,932 | 1,409,556 | - | 2,361,850 |
| 44 | 16,353 | 833,693 | 1,351,068 | 422 | 2,361,850 |
| 45 | 14,873 | 333,692 | 1,005,688 | 994 | 2,361,850 |
| 46 | 10,345 | 384,042 | 824,450 | 189 | 1,219,027 |
| 47 | 11,136 | 393,090 | 809,463 | 42 | 1,219,131 |
| 48 | 11,398 | 398,065 | 857,860 | 334 | 1,267,657 |
| 49 | | | | | |
| 50 | 17,363 | 934,932 | 1,409,556 | - | 2,361,850 |
| 51 | 17,363 | 935,031 | 1,409,556 | 4,381 | 2,361,850 |
| 52 | | | | | |
| 53 | | | | | |
| 54 | | | | | |
| 55 | | | | | |
| 56 | | | | | |
| 57 | | | | | |
| 58 | | | | | |
| 59 | | | | | |
| 60 | | | | | |
| 61 | | | | | |
| 62 | | | | | |
| 63 | | | | | |
| 64 | | | | | |
| 65 | | | | | |
| 66 | | | | | |
| 67 | | | | | |
| 68 | | | | | |
| 69 | | | | | |
| 70 | | | | | |
| 71 | | | | | |
| 72 | | | | | |
| 73 | | | | | |
| 74 | | | | | |
| 75 | | | | | |
| 76 | | | | | |
| 77 | | | | | |
| 78 | | | | | |

Appendix I
Distribution Substation Transformer Loss

| Line No. | | Voltage High Side, kV 2 | Low Side, kV 3 | Rated Nominal MVA 4 | Max MVA 5 | No Load Losses WATTS 6 | Full Load Losses WATTS 7 | Low Side Class 8 | Verify Flag R,L,E 9 | Exclude Flag 10 | Primary Load Factor 11 | No Load Losses MWH 12 | Full Load Losses MWH 13 | Number of Feeder Circuits 14 | Percent Transf. Excluded 15 |
|----------|---------------------------|----------------------------------|----------------------|------------------------------|-----------------|---------------------------------|-----------------------------------|---------------------------|------------------------------|-----------------------|---------------------------------|--------------------------------|----------------------------------|---------------------------------------|--------------------------------------|
| 1 | 34TH STREET | 115 | 13.2 | 22.4 | 37.3 | 19,005 | 64,617 | 13.2 | R,L | I | 0.5592897 | 166.94 | 317.45 | 4 | |
| 2 | ADAIR | 68.8 | 13.09 | 10 | 14 | 12,573 | 25,896 | 12.5 | R,E | I | 0.55929 | 110.44 | 127.22 | 1 | |
| 3 | AIKEN RURAL | 67 | 12.5 | 2.5 | 2.5 | 4,608 | 13,940 | 12.5 | R,E | I | 0.55929 | 40.48 | 68.48 | 1 | |
| 4 | ALLMON | 67 | 12.5 | 7.5 | 9.38 | 10,895 | 43,006 | 12.5 | R,L | I | 0.55929 | 95.70 | 211.28 | 1 | |
| 5 | ALLRED | 115 | 12.5 | 12 | 20 | 19,630 | 57,040 | 12.5 | R,L | E | 0.55929 | 34.49 | 56.05 | 2 | 80 |
| 6 | AM-FRAC | 115 | 2.4 | 5.6 | 7 | 5,677 | 24,595 | 2.4 | R,L | I | 0.55929 | 49.87 | 120.83 | 0 | |
| 7 | AMHERST | 67 | 2.4 | 3.75 | 4.687 | 7,840 | 28,640 | 2.4 | R,L | I | 0.55929 | 68.87 | 140.70 | 2 | |
| 8 | ARROWHEAD | 115 | 13.2 | 15 | 25 | 12,450 | 55,570 | 13.2 | R,L | I | 0.55929 | 109.36 | 273.00 | 2 | |
| 9 | ARTESIA COUNTRY CLUB | 67 | 12.5 | 7.5 | 9.38 | 12,000 | 40,000 | 12.5 | R,E | I | 0.55929 | 105.41 | 196.51 | 2 | |
| 10 | ARTESIA S RURAL | 69 | 13.2 | 11.2 | 14 | 8,663 | 46,721 | 13.2 | R,L | I | 0.55929 | 76.10 | 229.53 | 2 | |
| 11 | ARTESIA TOWN | 66 | 4.16 | 5 | 5 | 10,526 | 32,485 | 4.16 | R,E | I | 0.55929 | 92.46 | 159.59 | 3 | |
| 12 | ARTESIA WEST 13th St. | 67 | 4.16 | 7.5 | 11.26 | 9,800 | 55,797 | 4.16 | R,L | I | 0.55929 | 86.08 | 274.12 | 2 | |
| 13 | BAILEY PUMP | 67 | 12.5 | 5 | 5.6 | 11,000 | 35,000 | 12.5 | R,E | I | 0.55929 | 96.62 | 171.95 | 1 | |
| 14 | BAINER | 66 | 4.16 | 5 | 5 | 10,526 | 32,485 | 4.16 | R,E | I | 0.55929 | 92.46 | 159.59 | 1 | |
| 15 | BARWISE | 68.8 | 13.09 | 3.75 | 4.2 | 7,760 | 27,560 | 12.5 | R,L | I | 0.55929 | 68.16 | 135.40 | 2 | |
| 16 | BATTLE AXE T1 | 115 | 22.86 | 30 | 50 | 19,900 | 89,300 | 22 | R,L | I | 0.55929 | 174.80 | 438.71 | 3 | |
| 17 | BATTLE AXE T2 | 115 | 22.86 | 30 | 50 | 19,600 | 88,400 | 22 | R,L | I | 0.55929 | 172.17 | 434.29 | 3 | |
| 18 | BENNETT | 115 | 13.2 | 16.8 | 28 | 11,770 | 55,780 | 12.5 | R,L | I | 0.55929 | 103.39 | 274.04 | 3 | |
| 19 | BENSING | 118 | 13.2 | 17.5 | 29.5 | 11,700 | 67,500 | 12.5 | R,L | I | 0.55929 | 102.77 | 331.61 | 3 | |
| 20 | BOARDMAN | 69 | 13.2 | 12 | 20 | 9,410 | 45,960 | 12.5 | R,L | E | 0.55929 | 67.78 | 185.15 | 2 | 18 |
| 21 | BOOKER 4.16 KV | 69 | 4.2 | 3.75 | 3.75 | 7,900 | 24,500 | 4.16 | R,E | I | 0.55929 | 69.39 | 120.36 | 3 | |
| 22 | BOWERS | 67 | 13.8 | 7.5 | 9.375 | 19,800 | 56,515 | 13.2 | R,L | I | 0.55929 | 173.92 | 277.65 | 3 | |
| 23 | BRASHER | 115 | 13.2 | 15 | 25 | 13,500 | 57,700 | 13.2 | R,L | I | 0.55929 | 118.58 | 283.47 | 3 | |
| 24 | BRISCOE | 66 | 22 | 3 | 3.92 | 5,697 | 15,131 | 22 | R,E | I | 0.55929 | 50.04 | 74.33 | 2 | |
| 25 | BROWNFIELD SWITCH STATION | 67 | 22.9 | 5 | 5 | 13,410 | 31,360 | 22 | R,L | I | 0.55929 | 117.79 | 154.07 | 1 | |
| 26 | BUCKEYE | 115 | 12.5 | 7.5 | 10.5 | 20,620 | 74,550 | 12.5 | R,L | I | 0.55929 | 181.13 | 366.25 | 3 | |
| 27 | BUFFALO | 69 | 13.2 | 5 | 6.25 | 4,595 | 22,296 | 13.2 | R,L | I | 0.55929 | 40.36 | 109.54 | 2 | |
| 28 | BURNETT | 69 | 13.2 | 11.2 | 14 | 8,110 | 45,840 | 13.2 | R,L | I | 0.55929 | 71.24 | 225.20 | 2 | |
| 29 | BUSH | 115 | 13.8 | 15 | 25 | 24,880 | 60,701 | 13.2 | R,L | I | 0.55929 | 218.55 | 298.21 | 3 | |
| 30 | BYRD | 115 | 4.2 | 13.5 | 22.4 | 10,602 | 52,896 | 4.16 | R,L | I | 0.55929 | 93.13 | 259.87 | 0 | |
| 31 | CAMEX | 67 | 2.4 | 5 | 7 | 13,000 | 30,000 | 2.4 | R,L | I | 0.55929 | 114.19 | 147.38 | 3 | |
| 32 | CAMEX 115 | 118 | 13.2 | 16.8 | 28 | 12,650 | 71,450 | 13.2 | R,L | E | 0.55929 | 0.00 | 0.00 | 2 | 100 |
| 33 | CAMPBELL STREET | 115 | 12.5 | 15 | 25 | 18,192 | 65,727 | 12.5 | R,L | I | 0.55929 | 159.80 | 322.90 | 4 | |
| 34 | CANADIAN | 67 | 2.4 | 10 | 10 | 15,350 | 55,490 | 2.4 | R,L | I | 0.55929 | 134.83 | 272.61 | 2 | |
| 35 | CANYON EAST | 115 | 13.2 | 15 | 25 | 12,700 | 58,300 | 13.2 | R,L | I | 0.55929 | 111.56 | 286.42 | 2 | |
| 36 | CANYON WEST | 115 | 13.2 | 15 | 25 | 13,340 | 50,960 | 13.2 | R,L | I | 0.55929 | 117.18 | 250.36 | 3 | |
| 37 | CAPITAN | 69 | 13.2 | 15 | 25 | 10,610 | 57,270 | 13.2 | R,L | I | 0.55929 | 93.20 | 281.36 | 3 | |
| 38 | CARLSLE | 115 | 22.86 | 33.3 | 36.6 | 12,592 | 58,368 | 22 | R,E | I | 0.55929 | 110.61 | 286.75 | 3 | |
| 39 | CARLSBAD WATER | 67 | 12.5 | 3.75 | 3.75 | 6,912 | 20,909 | 12.5 | R,E | I | 0.55929 | 60.72 | 127.22 | 2 | |
| 40 | CARSON CO | 115 | 13.8 | 10 | 12.5 | 16,667 | 56,431 | 13.2 | R,L | I | 0.55929 | 146.40 | 277.23 | 2 | |
| 41 | CEDAR LAKE EAST | 66 | 12.5 | 2 | 2 | 4,000 | 25,000 | 12.5 | R,E | E | 0.55929 | 0.00 | 0.00 | 1 | 100 |
| 42 | CENTRE ST | 67 | 13.8 | 12 | 22.4 | 20,560 | 43,351 | 13.2 | R,L | I | 0.55929 | 180.60 | 212.97 | 2 | |
| 43 | CHANNING T1 | 230 | 34.5 | 16.8 | 28 | 17,700 | 63,100 | 33 | R,L | I | 0.55929 | 155.48 | 310.00 | 2 | |
| 44 | CHANNING T2 | 230 | 34.5 | 16.8 | 28 | 17,700 | 63,100 | 33 | R,L | I | 0.55929 | 155.48 | 310.00 | 1 | |
| 45 | CHERRY | 115 | 13.2 | 15 | 25 | 18,449 | 67,706 | 13.2 | R,L | I | 0.55929 | 162.06 | 332.63 | 2 | |
| 46 | CHINA DRAW T1 | 115 | 12.47 | 16.8 | 28 | 11,700 | 67,200 | 12.5 | R,L | I | 0.55929 | 102.77 | 330.14 | 2 | |
| 47 | CHINA DRAW T2 | 115 | 12.47 | 16.8 | 28 | 11,200 | 65,800 | 12.5 | R,L | I | 0.55929 | 98.38 | 323.26 | 2 | |
| 48 | CLIFFSIDE | 68.8 | 4.36 | 7.5 | 10.5 | 12,678 | 44,698 | 4.16 | R,L | I | 0.55929 | 111.36 | 219.59 | 0 | |
| 49 | COBLE | 67 | 12.5 | 10 | 11 | 16,500 | 55,000 | 12.5 | R,E | E | 0.55929 | 82.61 | 154.02 | 2 | 43 |
| 50 | COBURN CREEK | 118 | 13.2 | 16.8 | 28 | 11,700 | 69,000 | 13.2 | R,L | I | 0.55929 | 102.77 | 338.98 | 2 | |
| 51 | CONWAY | 115 | 13.8 | 12 | 20 | 21,840 | 48,390 | 13.2 | R,L | I | 0.55929 | 191.84 | 237.73 | 2 | |
| 52 | COOPER RANCH | 115 | 13.2 | 12 | 22.4 | 17,615 | 56,447 | 12.5 | R,E | I | 0.55929 | 154.73 | 277.31 | 2 | |
| 53 | CORTEZ | 115 | 4.2 | 5 | 6.25 | 10,530 | 27,280 | 4.16 | R,L | I | 0.55929 | 92.50 | 134.02 | 0 | |
| 54 | COTTONWOOD #1 | 66 | 12.5 | 1.5 | 1.88 | 3,158 | 9,745 | 12.5 | R,E | I | 0.55929 | 27.74 | 47.88 | 2 | |
| 55 | COULTER | 115 | 13.8 | 15 | 25 | 25,000 | 75,000 | 13.2 | R,L | I | 0.55929 | 219.60 | 368.46 | 3 | |
| 56 | COUNTY LINE | 69 | 12.47 | 18.75 | 25 | 36,600 | 89,810 | 12.5 | R,L | E | 0.55929 | 80.37 | 110.30 | 1 | 75 |
| 57 | CRMWA #1 | 115 | 4.16 | 7.5 | 9.37 | 20,493 | 50,307 | 4.16 | R,L | I | 0.55929 | 180.01 | 247.15 | 0 | |
| 58 | CRMWA #2 | 115 | 4.16 | 5 | 6.25 | 16,255 | 36,145 | 4.16 | R,L | I | 0.55929 | 142.78 | 177.57 | 0 | |
| 59 | CRMWA #3 | 115 | 4.16 | 5 | 6.25 | 14,481 | 35,758 | 4.16 | R,L | I | 0.55929 | 127.20 | 175.67 | 0 | |
| 60 | CRMWA #4 | 115 | 4.16 | 5 | 6.25 | 15,795 | 35,824 | 4.16 | R,L | I | 0.55929 | 138.66 | 176.00 | 0 | |
| 61 | CRMWA 21 (Adobe Creek) 13 | 67 | 13.2 | 10 | 14 | 23,000 | 80,000 | 13.2 | R,E | I | 0.55929 | 202.03 | 393.02 | 1 | |
| 62 | CRMWA 21 (Adobe Creek) 4 | 67 | 4.2 | 7.5 | 8.4 | 10,000 | 32,000 | 4.16 | R,E | I | 0.55929 | 87.84 | 157.21 | 1 | |
| 63 | CRMWA 22 | 69 | 4.2 | 3.75 | 4.687 | 7,900 | 24,500 | 4.16 | R,E | I | 0.55929 | 69.39 | 120.36 | 0 | |
| 64 | CRMWA 23 | 67 | 13.8 | 15 | 28 | 24,060 | 66,861 | 13.2 | R,L | I | 0.55929 | 211.34 | 328.47 | 0 | |
| 65 | CROUSE HINDS | 115 | 13.8 | 12 | 20 | 19,600 | 63,100 | 13.2 | R,L | I | 0.55929 | 172.17 | 310.00 | 0 | |
| 66 | CURRY CO | 67 | 24 | 12 | 20 | 18,465 | 52,230 | 22 | R,L | I | 0.55929 | 162.20 | 256.60 | 4 | |
| 67 | DALHART 12.5 KV | 67 | 12.5 | 12 | 22.4 | 15,855 | 50,503 | 12.5 | R,L | I | 0.55929 | 139.27 | 248.11 | 2 | |
| 68 | DALHART 2.4 KV | 67 | 2.4 | 3.75 | 4.68 | 11,960 | 38,450 | 2.4 | R,E | I | 0.55929 | 105.06 | 188.90 | 4 | |
| 69 | DALHART 35 KV | 67 | 34.5 | 7.5 | 7.5 | 17,590 | 42,475 | 33 | R,L | I | 0.55929 | 154.51 | 208.67 | 2 | |
| 70 | DAIRON | 69 | 13.2 | 7.5 | 10 | 17,250 | 55,850 | 13.2 | R,L | I | 0.55929 | 151.52 | 274.38 | 1 | |
| 71 | DAWN | 115 | 13.2 | 7.5 | 9.375 | 7,870 | 23,170 | 13.2 | R,L | I | 0.55929 | 69.13 | 113.83 | 2 | |
| 72 | DEAFSMITH | 115 | 13.8 | 12 | 20 | 19,600 | 63,100 | 13.2 | R,E | E | 0.55929 | 0.00 | 0.00 | 1 | 100 |
| 73 | DEXTER 34.5 KV | 69 | 34.5 | 5.6 | 7 | 7,047 | 32,076 | 33 | R,L | I | 0.55929 | 61.90 | 157.58 | 1 | |
| 74 | DEXTER 4.16 KV | 66 | 4.2 | 3.75 | 3.75 | 7,894 | 24,364 | 4.16 | R,E | I | 0.55929 | 69.34 | 119.69 | 2 | |
| 75 | DIEKEMPER | 66 | 4.2 | 1.5 | 1.5 | 2,105 | 6,497 | 4.16 | R,E | I | 0.55929 | 18.49 | 31.92 | 1 | |
| 76 | DIMMITT E | 67 | 13.8 | 15 | 25 | 21,980 | 69,170 | 12.5 | R,L | I | 0.55929 | 193.07 | 339.82 | 2 | |
| 77 | DIMMITT S | 67 | 12.5 | 10 | 12.5 | 9,216 | 27,879 | 12.5 | R,E | I | 0.55929 | 80.96 | 136.97 | 2 | |
| 78 | DOLLARHIDE | 115 | 13.2 | 12 | 22.4 | 11,100 | 46,800 | 12.5 | R,E | I | 0.55929 | 97.50 | 229.92 | 3 | |
| 79 | DOSS 12.5 KV | 69 | 12.5 | 16.8 | 28 | 9,851 | 71,031 | 12.5 | R,L | I | 0.55929 | 86.53 | 348.96 | 3 | |
| 80 | DOSS 22 KV | 67 | 24.9 | 12 | 20 | 18,330 | 62,470 | 22 | R,L | I | 0.55929 | 161.01 | 306.90 | 2 | |
| 81 | DRINKARD | 115 | 13.2 | 12 | 22.4 | 11,190 | 38,840 | 13.2 | R,L | I | 0.55929 | 98.29 | 190.81 | 3 | |
| 82 | DUMAS 19TH 12.5 KV | 115 | 12.5 | 12 | 20 | 19,400 | 63,400 | 12.5 | R,L | I | 0.55929 | 170.41 | 311.47 | 3 | |
| 83 | DUMAS 19TH 35 KV | 115 | 34.5 | 12 | 20 | 20,700 | 51,675 | 33 | R,L | I | 0.55929 | 181.83 | 253.87 | 2 | |
| 84 | DUVAL #3 | 67 | 4.2 | 5 | 7 | 10,526 | 32,485 | 4.16 | R,L | I | 0.55929 | 92.46 | 159.59 | 1 | |
| 85 | EAST CLOVIS | 118 | 13.2 | 16.8 | 28 | 8,768 | 67,351 | 12.5 | R,L | I | 0.55929 | 77.02 | 330.88 | 3 | |
| 86 | EAST DENVER CITY | 67 | 12.5 | 10 | 12.5 | 16,500 | 55,000 | 12.5 | R,E | I | 0.55929 | 144.94 | 270.20 | 3 | |

Appendix I
Distribution Substation Transformer Loss

| Line No. | | Voltage High Side, kV 2 | Low Side, kV 3 | Ratings Nominal MVA 4 | Max MVA 5 | No Load Losses WATTS 6 | Full Load Losses WATTS 7 | Low Side Class 8 | Verify Flag R,L,E 9 | Exclude Flag 10 | Primary Load Factor 11 | No Load Losses MWH 12 | Full Load Losses MWH 13 | Number of Feeder Circuits 14 | Percent Transf. Excluded 15 |
|----------|---------------------------------|----------------------------------|----------------------|--------------------------------|-----------------|---------------------------------|-----------------------------------|------------------------|------------------------------|-----------------------|---------------------------------|--------------------------------|----------------------------------|---------------------------------------|--------------------------------------|
| 101 | FIESTA | 115 | 13.2 | 15 | 28 | 15,523 | 65,978 | 12.5 | R,L | I | 0.55929 | 136.35 | 324.14 | 3 | 45 |
| 102 | FLANNAGAN | 69 | 13.2 | 11.2 | 14 | 10,800 | 37,984 | 12.5 | R,L | E | 0.55929 | 52.18 | 102.63 | 1 | |
| 103 | FRIONA RURAL | 115 | 22.9 | 12 | 20 | 21,350 | 49,200 | 22 | R,L | I | 0.55929 | 187.54 | 241.71 | 2 | |
| 104 | FRITCH | 115 | 13.2 | 7.5 | 9.38 | 13,825 | 41,819 | 13.2 | R,E | I | 0.55929 | 121.44 | 205.45 | 2 | |
| 105 | GARZA N | 72 | 25 | 11.2 | 14 | 6,497 | 45,517 | 22 | R,L | I | 0.55929 | 57.07 | 223.62 | 1 | |
| 106 | GARZA S | 72 | 25 | 11.2 | 14 | 9,304 | 47,534 | 22 | R,L | I | 0.55929 | 81.73 | 233.53 | 1 | |
| 107 | GOODPASTURE | 69 | 12.5 | 2 | 2 | 6,300 | 18,000 | 12.5 | R,E | I | 0.55929 | 55.34 | 88.43 | 1 | |
| 108 | GREYHOUND | 118 | 13.2 | 17.5 | 29.5 | 1,170 | 67,500 | 12.5 | R,L | I | 0.55929 | 10.28 | 331.61 | 1 | |
| 109 | HALE CENTER | 67 | 12.5 | 5 | 5 | 10,000 | 35,000 | 12.5 | R,E | I | 0.55929 | 87.84 | 171.95 | 2 | |
| 110 | HAPPY CITY | 66 | 12.5 | 6 | 7 | 11,100 | 36,880 | 12.5 | R,L | I | 0.55929 | 97.50 | 181.18 | 2 | |
| 111 | HART INDUSTRIAL | 67 | 12.5 | 5 | 6.25 | 12,425 | 31,575 | 12.5 | R,L | I | 0.55929 | 109.14 | 155.12 | 2 | |
| 112 | HASTINGS | 67 | 13.2 | 15 | 25 | 27,190 | 77,050 | 13.2 | R,L | I | 0.55929 | 238.84 | 378.53 | 4 | |
| 113 | HENDRICKS | 66 | 22 | 10 | 13.33 | 16,500 | 50,000 | 22 | R,L | I | 0.55929 | 144.94 | 245.64 | 3 | |
| 114 | HEREFORD | 118 | 13.2 | 16.8 | 28 | 16,000 | 82,000 | 13.2 | R,E | I | 0.55929 | 140.54 | 402.85 | 2 | |
| 115 | HERRING | 115 | 34.5 | 12 | 20 | 25,140 | 51,450 | 33 | R,L | I | 0.55929 | 220.83 | 252.76 | 2 | |
| 116 | HIGHLAND PARK | 115 | 13.8 | 25 | 41.6 | 30,680 | 101,010 | 13.2 | R,E | E | 0.55929 | 134.75 | 248.12 | 2 | |
| 117 | HILLSIDE | 118 | 13.2 | 16.8 | 28 | 8,807 | 67,624 | 13.2 | R,L | I | 0.55929 | 77.36 | 332.22 | 3 | |
| 118 | HOBGOOD | 69 | 4.2 | 0.23 | 0.23 | 1,096 | 3,150 | 4.16 | R,E | I | 0.55929 | 9.63 | 15.48 | 1 | |
| 119 | HOPI | 69 | 13.2 | 16.8 | 28 | 9,927 | 70,540 | 12.5 | R,L | I | 0.55929 | 87.20 | 346.55 | 3 | |
| 120 | HOWARD | 118 | 13.2 | 11.2 | 14 | 7,531 | 41,570 | 13.2 | R,L | I | 0.55929 | 66.15 | 204.23 | 2 | |
| 121 | IMC #3 Strata | 69 | 12.5 | 5 | 6.25 | 12,000 | 48,000 | 12.5 | R,L | I | 0.55929 | 105.41 | 235.81 | 2 | |
| 122 | IMC #4 | 69 | 13.2 | 5 | 5 | 7,789 | 20,101 | 13.2 | R,L | I | 0.55929 | 68.42 | 98.75 | 0 | |
| 123 | INDUSTRIAL | 67 | 13.8 | 12 | 20 | 19,700 | 57,300 | 13.2 | R,L | I | 0.55929 | 173.04 | 281.50 | 3 | |
| 124 | IRICK | 66 | 12.5 | 6 | 7.26 | 11,450 | 36,845 | 12.5 | R,L | I | 0.55929 | 100.58 | 181.01 | 2 | |
| 125 | JAL | 115 | 13.8 | 12 | 20 | 18,800 | 63,000 | 12.5 | R,L | I | 0.55929 | 165.14 | 309.51 | 3 | |
| 126 | JAYBEE | 69 | 12.5 | 2.5 | 3.125 | 4,608 | 13,940 | 12.5 | R,E | I | 0.55929 | 40.48 | 68.48 | 1 | |
| 127 | KINGSMILL | 69 | 13.2 | 16.8 | 28 | 16,300 | 67,300 | 13.2 | R,L | I | 0.55929 | 143.18 | 330.63 | 5 | |
| 128 | KINNEY | 69 | 2.4 | 1 | 1.5 | 3,800 | 11,875 | 2.4 | R,E | I | 0.55929 | 33.38 | 58.34 | 0 | |
| 129 | KISER | 118 | 13.2 | 16.8 | 28 | 16,000 | 82,000 | 12.5 | R,L | I | 0.55929 | 140.54 | 402.85 | 2 | |
| 130 | KITE | 67 | 13.2 | 12 | 20 | 17,800 | 55,630 | 13.2 | R,L | I | 0.55929 | 156.36 | 273.30 | 3 | |
| 131 | KRESS RURAL | 69 | 12.5 | 6 | 6 | 10,515 | 10,922 | 12.5 | R,L | I | 0.55929 | 92.36 | 53.66 | 3 | |
| 132 | LAKE MEREDITH | 118 | 13.2 | 11.2 | 14 | 8,004 | 40,923 | 13.2 | R,L | I | 0.55929 | 70.31 | 201.05 | 3 | |
| 133 | LARIAT | 67 | 12.5 | 7.5 | 9.375 | 10,895 | 43,006 | 12.5 | R,E | I | 0.55929 | 95.70 | 211.28 | 1 | |
| 134 | LAWRENCE PK E #1 | 67 | 13.8 | 15 | 25 | 23,899 | 60,360 | 13.2 | R,L | I | 0.55929 | 209.93 | 296.54 | 3 | |
| 135 | LAWRENCE PK W #2 | 67 | 13.8 | 15 | 25 | 24,200 | 71,126 | 13.2 | R,L | I | 0.55929 | 212.57 | 349.43 | 3 | |
| 136 | LEA NATIONAL | 115 | 13.2 | 11.2 | 14 | 7,806 | 43,297 | 13.2 | R,L | I | 0.55929 | 68.57 | 212.71 | 2 | |
| 137 | LEA ROAD | 115 | 12.5 | 10 | 12.5 | 17,615 | 56,447 | 12.5 | R,L | E | 0.55929 | 49.51 | 88.74 | 2 | |
| 138 | LEHMAN | 115 | 12.5 | 12 | 20 | 19,400 | 63,000 | 12.5 | R,L | I | 0.55929 | 170.41 | 309.51 | 2 | |
| 139 | LEVELLAND (EAST XFMR) | 66 | 2.4 | 1.5 | 1.5 | 3,800 | 11,875 | 2.4 | R,E | I | 0.55929 | 33.38 | 58.34 | 2 | |
| 140 | LEVELLAND CITY | 69 | 13.2 | 12 | 22.4 | 9,800 | 49,600 | 12.5 | R,L | I | 0.55929 | 86.08 | 243.67 | 2 | |
| 141 | LIPSCOMB 12.5 KV | 118 | 13.2 | 5.6 | 7 | 2,161 | 6,482 | 13.2 | R,L | I | 0.55929 | 18.98 | 31.84 | 2 | |
| 142 | LIPSCOMB 35 KV | 118 | 36.2 | 16.8 | 28 | 13,516 | 62,374 | 33 | R,L | I | 0.55929 | 118.72 | 306.43 | 1 | |
| 143 | LITTLEFIELD CITY | 67 | 4.2 | 5 | 6.25 | 10,000 | 30,000 | 4.16 | R,E | I | 0.55929 | 87.84 | 147.38 | 4 | |
| 144 | LITTLEFIELD SOUTH | 67 | 12.5 | 7.5 | 9.375 | 10,000 | 35,000 | 12.5 | R,E | I | 0.55929 | 87.84 | 171.95 | 2 | |
| 145 | LIVINGSTON RIDGE | 69 | 13.2 | 11.2 | 14 | 6,396 | 44,866 | 12.5 | R,L | I | 0.55929 | 56.18 | 220.42 | 3 | |
| 146 | LOCKNEY RURAL | 69 | 12.5 | 2.5 | 2.5 | 4,608 | 13,940 | 12.5 | R,E | I | 0.55929 | 40.48 | 68.48 | 2 | |
| 147 | LOCKNEY RURAL 23 | 69 | 22.86 | 10 | 10 | 12,004 | 35,123 | 22 | R,L | I | 0.55929 | 105.44 | 172.55 | 2 | |
| 148 | LYNN | 69 | 22.9 | 10 | 10 | 12,233 | 37,682 | 22 | R,L | I | 0.55929 | 107.45 | 185.12 | 3 | |
| 149 | LYONS | 67 | 13.8 | 12 | 20 | 21,550 | 52,560 | 13.2 | R,L | I | 0.55929 | 189.30 | 258.22 | 2 | |
| 150 | MALJAMAR | 115 | 12.5 | 10 | 12.5 | 17,450 | 58,016 | 12.5 | R,L | E | 0.55929 | 65.91 | 122.56 | 0 | |
| 151 | MALJAMAR #2 | 115 | 4.2 | 7 | 12.4 | 6,316 | 29,319 | 4.16 | R,L | I | 0.55929 | 55.48 | 144.04 | 0 | |
| 152 | MALLET | 67 | 13.8 | 5 | 5 | 10,641 | 39,077 | 12.5 | R,L | I | 0.55929 | 93.47 | 191.98 | 2 | |
| 153 | MANHATTAN | 115 | 13.8 | 15 | 25 | 24,640 | 63,513 | 13.2 | R,L | I | 0.55929 | 216.44 | 312.03 | 3 | |
| 154 | McCLELLAN (GROOM PUMP STATION) | 115 | 13.2 | 5 | 5 | 9,216 | 27,879 | 13.2 | R,E | I | 0.55929 | 80.96 | 136.97 | 1 | |
| 155 | MCCULLOGH | 67 | 13.2 | 15 | 25 | 23,044 | 65,351 | 13.2 | R,L | I | 0.55929 | 202.42 | 321.06 | 3 | |
| 156 | MCCLEAN RURAL | 115 | 13.2 | 7.5 | 9.375 | 17,700 | 58,000 | 13.2 | R,L | E | 0.55929 | 66.86 | 122.53 | 2 | |
| 157 | MID AM #3 -in Swisher area | 67 | 2.4 | 5 | 5.6 | 14,150 | 42,000 | 2.4 | R,E | I | 0.55929 | 124.29 | 206.34 | 0 | |
| 158 | MID-AM #2 | 67 | 2.4 | 3.75 | 3.75 | 8,800 | 23,950 | 2.4 | R,L | I | 0.55929 | 77.30 | 117.66 | 0 | |
| 159 | MIDDLETON | 67 | 12.5 | 10 | 12.5 | 14,400 | 54,818 | 12.5 | R,L | I | 0.55929 | 126.49 | 269.31 | 2 | |
| 160 | MILLEN | 115 | 12.5 | 12 | 20 | 19,889 | 63,525 | 12.5 | R,L | I | 0.55929 | 174.70 | 312.09 | 3 | |
| 161 | MISS CHEM #2 | 67 | 12.5 | 3.75 | 4.69 | 7,851 | 27,329 | 12.5 | R,E | I | 0.55929 | 68.96 | 134.26 | 0 | |
| 162 | NMOROE | 66 | 22 | 10 | 13.3 | 20,680 | 47,900 | 22 | R,E | I | 0.55929 | 181.65 | 225.32 | 1 | |
| 163 | MONUMENT | 118 | 13.2 | 16.8 | 28 | 10,781 | 65,108 | 12.5 | R,L | I | 0.55929 | 94.70 | 319.86 | 3 | |
| 164 | MOORE CO | 115 | 13.2 | 15 | 28 | 12,650 | 52,720 | 13.2 | R,L | I | 0.55929 | 111.12 | 259.00 | 3 | |
| 165 | MORTON | 67 | 2.4 | 5 | 6.25 | 10,526 | 32,485 | 2.4 | R,E | I | 0.55929 | 92.46 | 159.59 | 2 | |
| 166 | MOSS | 67 | 24.9 | 10 | 10 | 17,985 | 47,480 | 22 | R,L | I | 0.55929 | 157.98 | 233.26 | 2 | |
| 167 | MULESHOE CITY | 67 | 2.4 | 3.75 | 3.75 | 9,501 | 29,687 | 2.4 | R,E | I | 0.55929 | 83.45 | 145.85 | 2 | |
| 168 | MULESHOE VALLEY | 118 | 13.2 | 11.2 | 14 | 11,250 | 54,950 | 12.5 | R,L | I | 0.55929 | 98.82 | 269.96 | 1 | |
| 169 | MULESHOE WATERFIELD @ Bailey Co | 66 | 12.5 | 1.5 | 1.5 | 2,765 | 8,364 | 12.5 | R,L | I | 0.55929 | 24.29 | 41.09 | 1 | |
| 170 | MURPHY | 115 | 22.86 | 20 | 33 | 12,592 | 58,368 | 22 | R,E | I | 0.55929 | 110.61 | 286.75 | 3 | |
| 171 | N CLOVIS | 118 | 13.2 | 16.8 | 28 | 11,544 | 61,309 | 13.2 | R,L | I | 0.55929 | 101.40 | 301.20 | 2 | |
| 172 | N E HOBBS | 115 | 13.2 | 15 | 28 | 11,232 | 59,268 | 12.5 | R,L | I | 0.55929 | 98.66 | 291.17 | 4 | |
| 173 | N HOBBS #1 | 115 | 12.5 | 12 | 20 | 21,320 | 41,510 | 12.5 | R,E | I | 0.55929 | 187.27 | 203.93 | 3 | |
| 174 | N HOBBS #2 | 115 | 12.5 | 12 | 20 | 20,830 | 57,290 | 12.5 | R,L | I | 0.55929 | 182.97 | 281.45 | 2 | |
| 175 | N PLAINVIEW | 67 | 12.5 | 10 | 10 | 16,500 | 55,000 | 12.5 | R,E | I | 0.55929 | 144.94 | 270.20 | 2 | |
| 176 | NAVAJO MALAGA | 66 | 4.16 | 3 | 3 | 6,316 | 19,491 | 4.16 | R,E | I | 0.55929 | 55.48 | 95.75 | 0 | |
| 177 | NM POTASH | 69 | 13.8 | 7.5 | 10.5 | 16,680 | 44,960 | 12.5 | R,E | I | 0.55929 | 146.52 | 220.88 | 0 | |
| 178 | NORRIS ST | 115 | 13.2 | 12 | 20 | 13,396 | 37,753 | 12.5 | R,L | I | 0.55929 | 117.67 | 185.47 | 2 | |
| 179 | NORTH CANAL | 115 | 13.2 | 15 | 25 | 15,291 | 56,220 | 12.5 | R,L | I | 0.55929 | 134.32 | 276.20 | 3 | |
| 180 | NORTH LOVING | 118 | 13.2 | 16.8 | 28 | 11,300 | 66,100 | 12.5 | R,L | I | 0.55929 | 99.26 | 324.74 | 2 | |
| 181 | OCHOA | 118 | 13.2 | 16.8 | 28 | 10,000 | 69,000 | 12.5 | R,L | I | 0.55929 | 87.84 | 338.98 | 2 | |
| 182 | OCOTILLO | 118 | | | | | | | | | | | | | |

Appendix I
Distribution Substation Transformer Loss

| Line No. | | Voltage High Side, kV 2 | Low Side, kV 3 | Rated Nominal MVA 4 | Max MVA 5 | No Load Losses WATTS 6 | Full Load Losses WATTS 7 | Low Side Class 8 | Verify Flag R,L,E 9 | Exclude Flag 10 | Primary Load Factor 11 | No Load Losses MWH 12 | Full Load Losses MWH 13 | Number of Feeder Circuits 14 | Percent Transf. Excluded 15 |
|----------|---------------------------|----------------------------------|----------------------|------------------------------|-----------------|---------------------------------|-----------------------------------|---------------------------|------------------------------|-----------------------|---------------------------------|--------------------------------|----------------------------------|---------------------------------------|--------------------------------------|
| 201 | PORTALES #2 A | 67 | 12.47 | 10 | 14 | 6,316 | 19,491 | 4.16 | R,L | I | 0.55929 | 55.48 | 95.75 | 1 | |
| 202 | PORTALES #2 B | 67 | 4.2 | 5 | 5 | 8,777 | 40,107 | 4.16 | R,L | I | 0.55929 | 77.10 | 197.04 | 2 | |
| 203 | PORTALES SOUTH | 67 | 4.16 | 7.5 | 9.375 | 12,000 | 44,565 | 4.16 | R,L | I | 0.55929 | 105.41 | 218.94 | 2 | |
| 204 | PORTALES WATER FIELD | 115 | 12.5 | 10 | 14 | 11,700 | 33,600 | 13.2 | R,L | I | 0.55929 | 102.77 | 165.07 | 2 | |
| 205 | POST CITY (Garza #3) | 67 | 4.2 | 5 | 5 | 10,304 | 34,922 | 4.16 | R,L | I | 0.55929 | 90.51 | 171.56 | 2 | |
| 206 | POTASH JUNCTION | 67 | 12.5 | 10 | 12.5 | 14,470 | 58,190 | 12.5 | R,L | I | 0.55929 | 127.10 | 285.88 | 1 | |
| 207 | PRENTICE W | 115 | 13.2 | 15 | 28 | 12,281 | 52,074 | 13.2 | R,L | E | 0.55929 | 7.55 | 17.91 | 1 | 93 |
| 208 | PRICE | 118 | 13.2 | 17.5 | 29.5 | 11,700 | 67,500 | 12.5 | R,L | I | 0.55929 | 102.77 | 331.61 | 3 | |
| 209 | PRINGLE INT | 115 | 34.5 | 16.8 | 28 | 13,106 | 68,952 | 33 | R,L | I | 0.55929 | 115.12 | 338.75 | 1 | |
| 210 | PUCKETT WEST | 115 | 13.2 | 15 | 25 | 15,460 | 58,647 | 13.2 | R,L | I | 0.55929 | 135.80 | 288.12 | 3 | |
| 211 | PULLMAN | 115 | 13.2 | 15 | 25 | 11,990 | 52,620 | 13.2 | R,L | I | 0.55929 | 105.32 | 258.51 | 3 | |
| 212 | RIAC EAST | 67 | 4.2 | 5 | 5.25 | 10,526 | 32,485 | 4.16 | R,L | I | 0.55929 | 92.46 | 159.59 | 3 | |
| 213 | RIAC WEST | 69 | 4.2 | 7.5 | 9.375 | 11,800 | 44,605 | 4.16 | R,L | I | 0.55929 | 103.65 | 219.14 | 2 | |
| 214 | RILEY | 67 | 12.5 | 3.75 | 5 | 6,912 | 20,909 | 12.5 | R,E | I | 0.55929 | 60.72 | 102.72 | 2 | |
| 215 | RIVERVIEW | 115 | 13.2 | 15 | 25 | 16,074 | 56,237 | 13.2 | R,L | I | 0.55929 | 141.19 | 276.28 | 3 | |
| 216 | ROBERTS CO | 67 | 4.16 | 5 | 6.25 | 6,851 | 19,040 | 13.2 | R,E | I | 0.55929 | 60.18 | 93.54 | 2 | |
| 217 | ROSWELL CITY N | 115 | 12.5 | 15 | 25 | 17,636 | 65,206 | 12.5 | R,E | I | 0.55929 | 154.91 | 320.34 | 2 | |
| 218 | ROSWELL CITY S | 115 | 12.5 | 15 | 25 | 17,600 | 65,000 | 12.5 | R,E | I | 0.55929 | 154.60 | 319.33 | 2 | |
| 219 | ROXANA | 69 | 13.8 | 10 | 14 | 10,742 | 23,613 | 13.2 | R,E | I | 0.55929 | 94.36 | 116.01 | 2 | |
| 220 | RUSSELL SUB E TRANSFORMER | 115 | 12.5 | 12 | 20 | 20,200 | 63,100 | 12.5 | R,L | E | 0.55929 | 63.88 | 111.60 | 1 | 64 |
| 221 | RUSSELL SUB W TRANSFORMER | 115 | 13.2 | 15 | 28 | 12,369 | 51,686 | 13.2 | R,L | E | 0.55929 | 39.11 | 91.41 | 2 | 64 |
| 222 | S FLOYDADA | 66 | 22 | 5 | 5 | 10,100 | 32,392 | 22 | R,L | I | 0.55929 | 88.72 | 159.14 | 2 | |
| 223 | S HOBBS E | 115 | 13.2 | 12 | 20 | 14,677 | 40,275 | 12.5 | R,L | I | 0.55929 | 128.92 | 197.86 | 2 | |
| 224 | S HOBBS W | 115 | 12.5 | 12 | 20 | 18,500 | 57,000 | 12.5 | R,L | E | 0.55929 | 35.75 | 61.61 | 2 | 78 |
| 225 | S PLAINVIEW | 67 | 12.5 | 10 | 14 | 16,500 | 55,000 | 12.5 | R,E | I | 0.55929 | 144.94 | 270.20 | 3 | |
| 226 | SAGE BRUSH | 115 | 22.86 | 30 | 50 | 20,600 | 91,000 | 22 | R,L | I | 0.55929 | 180.95 | 447.06 | 3 | |
| 227 | SAMSON | 115 | 13.2 | 12 | 20 | 18,820 | 46,500 | 12.5 | R,L | I | 0.55929 | 165.31 | 228.45 | 2 | |
| 228 | SAND DUNES | 67 | 12.5 | 7.5 | 8.4 | 9,500 | 30,000 | 12.5 | R,L | I | 0.55929 | 83.45 | 147.38 | 3 | |
| 229 | SEMINOLE INTG | 115 | 22.86 | 16.8 | 28 | 12,592 | 58,368 | 22 | R,L | I | 0.55929 | 110.61 | 286.75 | 2 | |
| 230 | SHAMROCK PUMP | 66 | 2.4 | 1 | 1 | 2,534 | 7,917 | 2.4 | R,E | I | 0.55929 | 22.25 | 38.89 | 0 | |
| 231 | SHELL C3 | 115 | 4.16 | 10 | 14 | 11,852 | 31,876 | 4.16 | R,L | E | 0.55929 | 80.15 | 111.19 | 0 | 29 |
| 232 | SHERMAN CO | 115 | 34.5 | 12 | 12 | 27,100 | 53,900 | 33 | R,L | I | 0.55929 | 238.05 | 264.80 | 3 | |
| 233 | SLATON | 69 | 22.9 | 10 | 10 | 13,067 | 35,044 | 22 | R,L | I | 0.55929 | 114.78 | 172.16 | 2 | |
| 234 | SLATON CITY | 67 | 4.2 | 3.75 | 3.75 | 7,894 | 24,364 | 4.16 | R,E | I | 0.55929 | 69.34 | 119.69 | 2 | |
| 235 | SLAUGHTER | 67 | 2.4 | 3.75 | 4.2 | 6,960 | 22,330 | 2.4 | R,L | I | 0.55929 | 61.14 | 109.70 | 1 | |
| 236 | SMITH | 67 | 4.2 | 3.75 | 3.75 | 7,894 | 24,364 | 4.16 | R,E | I | 0.55929 | 69.34 | 119.69 | 2 | |
| 237 | SONCY | 67 | 13.8 | 20 | 20 | 24,981 | 94,630 | 13.2 | R,L | I | 0.55929 | 219.43 | 464.90 | 4 | |
| 238 | SOUTH GEORGIA EAST | 115 | 13.8 | 15 | 25 | 21,120 | 56,040 | 13.2 | R,L | I | 0.55929 | 185.52 | 275.31 | 3 | |
| 239 | SOUTH GEORGIA WEST | 118 | 13.2 | 16.8 | 28 | 9,052 | 75,940 | 13.2 | R,L | I | 0.55929 | 79.51 | 373.08 | 3 | |
| 240 | SOUTH LOVING | 69 | 13.2 | 11.2 | 17.5 | 7,835 | 43,091 | 13.2 | R,L | I | 0.55929 | 68.82 | 211.70 | 3 | |
| 241 | SOUTHEAST | 115 | 13.2 | 15 | 25 | 18,490 | 50,440 | 13.2 | R,L | I | 0.55929 | 162.33 | 247.80 | 2 | |
| 242 | SOUTHLAND | 69 | 2.4 | 1.5 | 1.5 | 3,158 | 9,745 | 2.4 | R,E | I | 0.55929 | 27.74 | 47.88 | 1 | |
| 243 | SPEARMAN INTERCHANGE | 67 | 34.4 | 10 | 10 | 14,320 | 61,030 | 33 | R,L | I | 0.55929 | 125.79 | 299.83 | 1 | |
| 244 | SPEARMAN SUB EAST XFMR | 115 | 4.16 | 7.5 | 10.5 | 12,416 | 40,872 | 4.16 | R,L | I | 0.55929 | 109.06 | 200.80 | 2 | |
| 245 | SPEARMAN SUB WEST XFMR | 115 | 4.16 | 7.5 | 10.5 | 13,440 | 41,855 | 4.16 | R,L | I | 0.55929 | 118.06 | 205.63 | 2 | |
| 246 | SPRING DRAW | 118 | 13.2 | 16.8 | 28 | 11,713 | 67,783 | 13.2 | R,L | I | 0.55929 | 102.89 | 333.00 | 3 | |
| 247 | SPRINGCREEK | 67 | 13.2 | 7.5 | 9.375 | 15,760 | 41,150 | 13.2 | R,E | I | 0.55929 | 138.44 | 202.16 | 2 | |
| 248 | SPRINGLAKE | 67 | 13.2 | 7.5 | 7.5 | 11,060 | 52,193 | 13.2 | R,L | I | 0.55929 | 97.15 | 256.41 | 2 | |
| 249 | SUDAN RURAL | 66 | 12.5 | 2.5 | 2.5 | 4,608 | 13,940 | 12.5 | R,E | I | 0.55929 | 40.48 | 68.48 | 2 | |
| 250 | SUNSET T1 | 115 | 13.2 | 15 | 28 | 15,300 | 46,900 | 13.2 | R,L | I | 0.55929 | 134.40 | 230.41 | 3 | |
| 251 | SUNSET T2 | 118 | 13.2 | 16.8 | 28 | 14,300 | 63,300 | 13.2 | R,L | I | 0.55929 | 125.61 | 310.98 | 2 | |
| 252 | TEAGUE | 115 | 12.5 | 10 | 14 | 13,610 | 30,300 | 12.5 | R,E | I | 0.55929 | 119.55 | 148.86 | 2 | |
| 253 | TENNECO | 69 | 13.2 | 15 | 25 | 11,170 | 57,590 | 13.2 | R,L | I | 0.55929 | 98.12 | 282.93 | 1 | |
| 254 | TEXACO | 67 | 12.5 | 12 | 20 | 20,146 | 52,610 | 12.5 | R,L | E | 0.55929 | 21.24 | 31.02 | 2 | 88 |
| 255 | TEXAS FARMS | 115 | 13.2 | 7.5 | 9.375 | 7,670 | 23,270 | 13.2 | R,L | I | 0.55929 | 67.37 | 114.32 | 1 | |
| 256 | TMC | 67 | 4.2 | 10 | 12.5 | 15,600 | 54,420 | 4.16 | R,L | I | 0.55929 | 137.03 | 267.35 | 0 | |
| 257 | TOKIO | 67 | 12.5 | 5 | 6.25 | 9,216 | 27,879 | 12.5 | R,E | I | 0.55929 | 80.96 | 136.97 | 1 | |
| 258 | TRANSPETCO | 67 | 4.2 | 7.5 | 7.5 | 11,657 | 37,611 | 4.16 | R,L | I | 0.55929 | 102.40 | 184.78 | 2 | |
| 259 | TUCO | 67 | 12.5 | 10 | 13.3 | 16,050 | 58,110 | 12.5 | R,L | I | 0.55929 | 140.98 | 285.48 | 2 | |
| 260 | TWEEDY | 115 | 13.2 | 12 | 20 | 10,260 | 33,790 | 13.2 | R,L | E | 0.55929 | 19.83 | 36.52 | 2 | 78 |
| 261 | UNITED SALT | 69 | 12.4 | 0.75 | 0.75 | 1,382 | 4,182 | 12.5 | R,E | I | 0.55929 | 12.14 | 20.54 | 1 | |
| 262 | URTON | 115 | 12.4 | 12 | 12 | 21,940 | 63,559 | 12.5 | R,L | I | 0.55929 | 192.72 | 312.25 | 2 | |
| 263 | VAN BUREN #1 | 67 | 13.2 | 15 | 25 | 29,725 | 70,460 | 13.2 | R,L | I | 0.55929 | 261.10 | 346.16 | 3 | |
| 264 | VAN BUREN #2 | 67 | 13.8 | 15 | 25 | 23,760 | 62,700 | 13.2 | R,L | I | 0.55929 | 208.71 | 308.03 | 3 | |
| 265 | VEGA | 69 | 13.2 | 11.2 | 14 | 10,575 | 43,151 | 13.2 | R,L | I | 0.55929 | 92.89 | 211.99 | 2 | |
| 266 | VICKERS | 69 | 23.9 | 10 | 14 | 23,600 | 50,236 | 22 | R,L | I | 0.55929 | 207.30 | 246.80 | 1 | |
| 267 | W ANTON | 66 | 22 | 6 | 6 | 11,394 | 30,261 | 22 | R,E | I | 0.55929 | 100.09 | 148.67 | 1 | |
| 268 | W BENDER | 115 | 13.2 | 12 | 22.4 | 11,190 | 38,840 | 13.2 | R,L | I | 0.55929 | 98.29 | 190.81 | 2 | |
| 269 | W BORGER | 115 | 13.2 | 15 | 25 | 14,838 | 55,493 | 13.2 | R,L | I | 0.55929 | 130.34 | 272.63 | 2 | |
| 270 | W CLOVIS 13.2 KV | 115 | 13.2 | 15 | 25 | 12,160 | 55,680 | 13.2 | R,L | I | 0.55929 | 106.81 | 273.54 | 3 | |
| 271 | W CLOVIS 23 KV | 67 | 24 | 12 | 22.4 | 10,800 | 47,800 | 22 | R,L | I | 0.55929 | 94.87 | 234.83 | 1 | |
| 272 | W LITTLEFIELD | 69 | 12.5 | 1.5 | 1.5 | 2,765 | 8,364 | 12.5 | R,E | I | 0.55929 | 24.29 | 41.09 | 1 | |
| 273 | W MULESHOE | 69 | 13.2 | 11.2 | 1400 | 9,800 | 66,850 | 12.5 | R,L | I | 0.55929 | 86.08 | 328.42 | 2 | |
| 274 | W PLAINVIEW | 67 | 12.5 | 12.5 | 20 | 16,500 | 55,000 | 12.5 | R,E | I | 0.55929 | 144.94 | 270.20 | 4 | |
| 275 | WADE | 118 | 13.2 | 5.6 | 7 | 2,088 | 6,265 | 12.5 | R,E | I | 0.55929 | 18.34 | 30.78 | 1 | |
| 276 | WARD | 115 | 12.5 | 4 | 4 | 13,610 | 30,300 | 12.5 | R,L | I | 0.55929 | 119.55 | 148.86 | 1 | |
| 277 | WASSON | 67 | 2.4 | 2 | 2 | 5,160 | 15,661 | 2.4 | R,L | I | 0.55929 | 45.33 | 76.94 | 0 | |
| 278 | WATERFIELD | 67 | 13.8 | 10 | 12.5 | 13,670 | 68,760 | 13.2 | R,L | I | 0.55929 | 120.08 | 337.80 | 3 | |
| 279 | WEATHERLY | 67 | 13.8 | 10 | 11.2 | 15,760 | 41,150 | 13.2 | R,E | I | 0.55929 | 138.44 | 202.16 | 2 | |
| 280 | WELLMAN | 67 | 12.5 | 5 | 6.25 | 5,000 | 15,000 | 12.5 | R,E | I | 0.55929 | 43.92 | 73.69 | 1 | |
| 281 | WESTRIDGE | 69 | 13.2 | 12 | 20 | 9,020 | 45,460 | 13.2 | R,L | I | 0.55929 | 79.23 | 223.34 | 2 | |
| 282 | WHERRY HOUSING | 67 | 12.5 | 3 | 3.65 | 5,530 | 16,728 | 12.5 | R,E | I | 0.55929 | 48.57 | 82.18 | 2 | |
| 283 | WHITAKER | 115 | 13.8 | 15 | 25 | 22,520 | 72,200 | 13.2 | R,L | I | 0.55929 | 197.82 | 354.70 | 3 | |
| 284 | WHITE CITY | 67 | 12.5 | 2.5 | 2.5 | 4,608 | 13,940 | 12.5 | R,E | I | 0.55929 | 40.48 | 68.48 | 2 | |
| 285 | WHITEFACE | 67 | 12.5 | 10 | 10 | 14,695 | 57,235 | 12.5 | R,L | I | 0.55929 | 129.08 | 281.18 | 2 | |
| 286 | WHITEHEAD AMOCO | 67 | 2.4 | 3.75 | 4.69 | 7,120 | 27,771 | 2.4 | R,E | I | 0.55929 | 62.54 | 136.43 | 1 | |
| 287 | WHITHARR | | | | | | | | | | | | | | |

Appendix I
Distribution Substation Transformer Loss

| Line No. | | Voltage High Side, KV | Low Side, KV | Ratings Nominal MVA | Max MVA | No Load Losses WATTS | Full Load Losses WATTS | Low Side Class | Verify Flag R,L,E | Exclude Flag | Primary Load Factor | No Load Losses MWH | Full Load Losses MWH | Number of Feeder Circuits | Percent Transf. Excluded |
|----------|--|-----------------------------|-----------------|---------------------------|---------------|----------------------------|------------------------------|----------------------|-------------------------|-----------------|---------------------------|--------------------------|----------------------------|---------------------------------|--------------------------------|
| | | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | 11 | 12 | 13 | 14 | 15 |
| 309 | 1 | | | | | | | | | | | | | | |
| 310 | | | | | | | | | | | | | | | |
| 311 | | | | | | | | | | | | | | | |
| 312 | Summary Information | | | | | | | | | | | | | | |
| 313 | KV Level | 33 | 22 | 13.2 | 12.5 | 4.16 | 2.4 | Total | | | | | | | |
| 314 | Total Nominal MVA by Voltage | 153.30 | 327.00 | 1,151.70 | 1,091.75 | 218.48 | 83.85 | 3,026.08 | | | | | | | |
| 315 | Load by Voltage | 111.77 | 238.42 | 839.72 | 796.01 | 159.30 | 61.14 | 2,206.35 | | | | | | | |
| 316 | Load on transformers without feeders | 0.00 | 0.00 | 23.69 | 8.33 | 54.98 | 17.29 | 104.29 | | | | | | | |
| 317 | Total Feeders | 19.00 | 50.00 | 205.00 | 224.00 | 47.00 | 28.00 | 573.00 | | | | | | | |
| 318 | Feeders excluding partial feeders | 18.07 | 50.00 | 196.09 | 212.94 | 47.00 | 28.00 | 552.10 | | | | | | | |
| 319 | Load on Feeders | 111.77 | 238.42 | 816.02 | 787.68 | 104.32 | 43.85 | 2,102.06 | | | | | | | |

Exhibit No. SPS-0005_2016 Loss Study-FINAL.xlsx App. J - Dist. Primary Loss

Appendix K
Distribution Line Transformer
Loss

| | | | | | | | |
|----------|---|---------|-------------|---------------|------------|------------------|---------------------|
| Line No. | Demand Losses | | | | | | |
| 1 | | | | | | | |
| 2 | | | | | | | |
| 3 | | | | | | | |
| 4 | Commercial customers may come only off the transformer or larger service drops. | | | | | | |
| 5 | Adjusted Meters | | | | | | |
| 6 | Residential | 301,809 | meters | 331,812 | 97,184 | trans. | 3.41427 mtr/trans. |
| 7 | | | | | | | |
| 8 | Commercial | 79,198 | meters | 49,195 | 45,116 | trans. | 1.09041 mtr/trans. |
| 9 | | | | | | | |
| 10 | 3 Ph Commercial | 49,195 | meters | | | | |
| 11 | | | | | | | |
| 12 | | | | | | | |
| 13 | | | | | | | |
| 14 | Residential and small commercial | | | 1,114,734 | KW | 4,161,409,160 | KWH (Level 6) |
| 15 | | | | | | | |
| 16 | Commercial Load | | | 640,746 | KW | 3,205,486,688 | KWH (Level 5) |
| 17 | | | | | | | |
| 18 | Total Load | | | 1,755,480 | KW | 7,366,895,848 | KWH |
| 19 | | | | | | | |
| 20 | | | | | | | |
| 21 | Load/Residential Customer | | | 3.36 | KW | Load/transformer | 11.47 KW |
| 22 | | | | | | | |
| 23 | Load/Commercial Customer | | | 13.02 | KW | Load/transformer | 14.20 KW |
| 24 | | | | | | | |
| 25 | | | | | | | |
| 26 | Typical Transformer Losses | 76 | NL watts | | 323 | FL watts | 25 KVA Transformer |
| 27 | | 207 | NL watts | | 892 | FL watts | 100 KVA Transformer |
| 28 | | | | | | | |
| 29 | Residential Transformer Losses(Watts) | | | 189.33 | | | |
| 30 | | | | | | | |
| 31 | Commercial Transformer Losses(Watts) | | | 304.28 | | | |
| 32 | | | | | | | |
| 33 | | | | | | | |
| 34 | | | Residential | | Commercial | | |
| 35 | No Load Losses(KW) | | 7,385.98 | | 9,339.01 | | |
| 36 | | | | | | | |
| 37 | Load Losses(KW) | | 18,399.57 | | 13,728.12 | | |
| 38 | | | | | | | |
| 39 | Total Losses(KW) | | 25,785.55 | | 23,067.13 | | |
| 40 | | | | | | | |
| 41 | Total Line Transformer Losses (KW) | | | | 48,853 | | |
| 42 | | | | | | | |
| 43 | | | | | | | |
| 44 | Energy Losses | | | | | | |
| 45 | | | | | | | |
| 46 | | | | | | | |
| 47 | Total Sales | | | 7,366,895,848 | KWH | | |
| 48 | | | | | | | |
| 49 | Load Factor - Based on Total Secondary | | | 0.4777 | | | |
| 50 | Demand and Energy Above | | | | | | |
| 51 | Loss Factor | | | 0.3031 | | | |
| 52 | | | | | | | |
| 53 | Total Dist. Line Transformer Losses | | | 130,063 | MWH | | |

Appendix L Secondary and Service Loss

Secondary Demand Losses

| | | | | |
|----------|---|-------------|--------------------------|--|
| Line No. | Demand Served at Secondary Level | | | |
| 1 | Level 5 - Sec. Distribution Transformers | | 640,746 KW | |
| 2 | Level 6 - Sec. Distribution Lines | | 1,114,734 KW | |
| 3 | Total Demand | | 1,755,480 KW | |
| 4 | | | | |
| 5 | Energy Served at Secondary Level | | | |
| 6 | Level 5 - Sec. Distribution Transformers | | 3,205,486,688 KWH | |
| 7 | Level 6 - Sec. Distribution Lines | | 4,161,409,160 KWH | |
| 8 | Total Energy | | 7,366,895,848 KWH | |
| 9 | | | | |
| 10 | | | | |
| 11 | Secondary Conductor - 60 ' of 1/0 Conductor | | | |
| 12 | | | | |
| 13 | Resistance | 0.0127 ohms | | |
| 14 | | | | |
| 15 | Load /Residential Customer | 3.36 KW | (From Appendix K) | |
| 16 | | | | |
| 17 | Load /Commercial Customer | 13.02 KW | (From Appendix K) | |
| 18 | | | | |
| 19 | | | | |
| 20 | Losses for secondary run | 14.00 amps | 4.98 watts loss | |
| 21 | | | | |
| 22 | | | | |
| 23 | Number of Residential Customers Served at Secondary | | 234,628 Customers | |
| 24 | Assumes that 1 meter was served at transformer | | | |
| 25 | | | | |
| 26 | Total Secondary Loss | | 1,168 KW | |

Service Demand Loss

| | | | | | |
|----|------------------------|---------|----------------|-------|----------|
| 33 | Resistance Values | | | | |
| 34 | | | | | |
| 35 | | | | | |
| 36 | Residential Service | 0.02028 | ohms | | |
| 37 | 65' of #2 Triplex | | | | |
| 38 | | | | | |
| 39 | Commercial Service | 0.00636 | ohms | | |
| 40 | 30' of #1/0 Quad | | | | |
| 41 | | | | | |
| 42 | Residential | 331,812 | meters | 14.00 | amps/mtr |
| 43 | | | | | |
| 44 | Commercial | 49,195 | meters | 31.33 | amps/mtr |
| 45 | | | | | |
| 46 | | | | | |
| 47 | Residential Loss/Meter | 7.95 | watts | 2,637 | kw |
| 48 | | | | | |
| 49 | Commercial Loss/meter | 18.73 | watts | 922 | kw |
| 50 | | | | | |
| 51 | | | | | |
| 52 | | Total | Service Losses | 3,559 | kw |

Secondary and Service Energy Losses

| | | | | |
|----|--|--|-------------------|--|
| 57 | | | | |
| 58 | Total Sales | | 7,366,895,848 KWH | |
| 59 | | | | |
| 60 | Load Factor - Based on Total Secondary | | 0.4777 | |
| 61 | Demand and Energy Above | | | |
| 62 | Loss Factor | | 0.3031 | |
| 63 | | | | |
| 64 | Total Secondary and Service Demand Loss | | 4,726 KW | |
| 65 | | | | |
| 66 | Total Secondary and Service Energy Loss | | 12,583 MWH | |

Appendix M
Loss Summary

SOUTHWESTERN PUBLIC SERVICE COMPANY
SUMMARY OF LOSS EVALUATION

JAN - DEC 2016

| Line No. | System Component | Demand MW | Energy MWH | Adjusted Energy MWH | Demand Percent | Energy Percent | Factored KWH | Loss Level | Demand Total Loss KW | Energy Total Loss kWh |
|-------------------------|--------------------------------|--------------|---------------|---------------------------|-------------------|-------------------|---------------|---------------|----------------------------|-----------------------------|
| Percent of Total Losses | | | | | | | | | | |
| 1 | | | | | | | | 1 | 0.00 | 0 |
| 2 | | | | | | | | | | |
| 3 | | | | | | | | | | |
| 4 | | | | | | | | | | |
| 5 | | | | | | | | | | |
| 6 | | | | | | | | | | |
| 7 | | | | | | | | | | |
| 8 | | | | | | | | | | |
| 9 | | | | | | | | | | |
| 10 | | | | | | | | | | |
| 11 | | | | | | | | | | |
| 12 | | | | | | | | | | |
| 13 | Transmission Lines | | | | | | | | | |
| 14 | 345 kV | 8.26 | 81,914 | 80,473 | 1.88 | 4.20 | 80,472,979 | | | |
| 15 | 230 kV | 47.35 | 364,668 | 358,252 | 10.77 | 18.71 | 358,252,268 | 2 | 138.79 | 913,763,470 |
| 16 | 115 kV | 66.32 | 357,874 | 351,579 | 15.09 | 18.36 | 351,578,600 | | | |
| 17 | 69 kV | 19.19 | 61,909 | 60,820 | 4.37 | 3.18 | 60,820,099 | 3 | 25.61 | 103,252,764 |
| 18 | | | | | | | | | | |
| 19 | Corona and Insulator Loss | | | | | | | | | |
| 20 | 345 kV | 2.12 | 18,634 | 18,307 | 0.48 | 0.96 | 18,306,549 | 4 | 221.49 | 757,391,388 |
| 21 | 230 kV | 2.21 | 19,382 | 19,041 | 0.50 | 0.99 | 19,040,983 | | | |
| 22 | 115 kV | 1.27 | 11,116 | 10,921 | 0.29 | 0.57 | 10,920,881 | 5 | 48.85 | 127,775,281 |
| 23 | 69 kV | 0.30 | 2,678 | 2,631 | 0.07 | 0.14 | 2,630,895 | 6 | 4.73 | 12,361,948 |
| 24 | | | | | | | | | | |
| 25 | Autotransformers - Load | | | | | | | | | |
| 26 | 345/230 kV | 0.80 | 6,651 | 6,534 | 0.18 | 0.34 | 6,533,694 | | | |
| 27 | 230/115 kV | 7.40 | 43,241 | 42,480 | 1.68 | 2.22 | 42,480,219 | | | |
| 28 | 115/69 kV | 4.36 | 23,239 | 22,830 | 0.99 | 1.19 | 22,830,107 | | | |
| 29 | | | | | | | | | | |
| 30 | Autotransformers - No Load | | | | | | | | | |
| 31 | 345/230 kV | 0.52 | 4,741 | 4,658 | 0.12 | 0.24 | 4,657,903 | | | |
| 32 | 230/115 kV | 2.54 | 21,905 | 21,519 | 0.58 | 1.12 | 21,519,395 | | | |
| 33 | 115/69 kV | 1.76 | 17,276 | 16,972 | 0.40 | 0.89 | 16,971,664 | | | |
| 34 | | | | | | | | | | |
| 35 | Distribution Sub. Transformers | 16.52 | 95,330 | 93,653 | 3.76 | 4.89 | 93,653,226 | | | |
| 36 | | | | | | | | | | |
| 37 | Distribution | | | | | | | | | |
| 38 | Primary | 204.96 | 675,624 | 663,738 | 46.64 | 34.67 | 663,738,161 | | | |
| 39 | Line Transformers | 48.85 | 130,063 | 127,775 | 11.12 | 6.67 | 127,775,281 | | | |
| 40 | Secondary & Services | 4.73 | 12,583 | 12,362 | 1.08 | 0.65 | 12,361,948 | | | |
| 41 | | | | | | | | | | |
| 42 | Total Determined Losses | 439.46 | 1,948,829 | | | | | | | |
| 43 | Undeterminable Losses | | -34,284 | | | | | | | |
| 44 | Total Losses | | 1,914,545 | 1,914,545 | | | 1,914,544,850 | | | |
| 45 | | | | | | | | | | |
| 46 | | | | | | | | | | |
| 47 | | | | | | | | | | |
| 48 | | | | | | | | | | |
| 49 | | | | | | | | | | |
| 50 | | | | | | | | | | |
| 51 | | | | | | | | | | |
| | Check Total | | 1,948,829 | | | | | | | |

Appendix N
Powerflow Study Loss Results

Appendix N
Powerflow Study Loss Results

Appendix N
Powerflow Study Loss Results

Case Name: 2016MDWGFfinal-16S_7_6003_edited.sav

Case Title 1: "2016 MDWG FINAL WITH 2015 SERIES MMWG FINAL"

Case Title 2: "MDWG 2016S WITH MMWG 2016S"

Bus Range: 522800 - 528799

***** L O S S E S B Y E L E M E N T C L A S S *****

----- AUTOTRANSFORMER LOSSES (MW) -----

| | | | | | |
|----------------|----------------|----------------|---------------|---------------|-----------|
| [345/230 kV] | [345/115 kV] | [230/115 kV] | [230/69 kV] | [115/69 kV] | [TOTAL] |
| 0.80394 | 0.0 | 7.399254 | 0.0 | 4.360944 | 12.56414 |

----- TRANSMISSION LINE LOSSES (MW) -----

| | | | | |
|------------|------------|------------|-----------|-----------|
| [345 kV] | [230 kV] | [115 kV] | [69 kV] | [TOTAL] |
| 8.262287 | 47.34864 | 66.32214 | 19.1898 | 141.1229 |

----- CASE TOTALS -----

TOTAL AREA LOSSES: 153.687MW

| | |
|------------------------|----------------------------------|
| TOTAL 345kV LINES: 10 | TOTAL 345/230kV TRANSFORMERS: 7 |
| TOTAL 230kV LINES: 79 | TOTAL 345/115kV TRANSFORMERS: 0 |
| TOTAL 115kV LINES: 391 | TOTAL 230/115kV TRANSFORMERS: 53 |
| TOTAL 69kV LINES: 288 | TOTAL 230/69kV TRANSFORMERS: 0 |
| | TOTAL 115/69kV TRANSFORMERS: 86 |

Appendix N
Powerflow Study Loss Results

Case Name: 2016MDWGFfinal-16G_6_Jan-Feb_3379_edited_07172017.sav

Case Title 1: "2016 MDWG FINAL WITH 2015 SERIES MMWG FINAL"

Case Title 2: "MDWG 2016G WITH MMWG 2016L"

Bus Range: 522800 - 528799

***** L O S S E S B Y E L E M E N T C L A S S * * * * *

----- AUTOTRANSFORMER LOSSES (MW) -----

| | | | | | |
|----------------|----------------|----------------|---------------|---------------|-----------|
| [345/230 kV] | [345/115 kV] | [230/115 kV] | [230/69 kV] | [115/69 kV] | [TOTAL] |
| 0.673998 | 0.0 | 4.880167 | 0.0 | 2.564221 | 8.118386 |

----- TRANSMISSION LINE LOSSES (MW) -----

| | | | | |
|------------|------------|------------|-----------|-----------|
| [345 kV] | [230 kV] | [115 kV] | [69 kV] | [TOTAL] |
| 8.959543 | 27.26439 | 29.51939 | 6.117981 | 71.86131 |

----- CASE TOTALS -----

TOTAL AREA LOSSES: 79.97969MW

| | |
|------------------------|----------------------------------|
| TOTAL 345kV LINES: 10 | TOTAL 345/230kV TRANSFORMERS: 7 |
| TOTAL 230kV LINES: 79 | TOTAL 345/115kV TRANSFORMERS: 0 |
| TOTAL 115kV LINES: 387 | TOTAL 230/115kV TRANSFORMERS: 53 |
| TOTAL 69kV LINES: 289 | TOTAL 230/69kV TRANSFORMERS: 0 |
| | TOTAL 115/69kV TRANSFORMERS: 86 |

Appendix N
Powerflow Study Loss Results

Case Name: 2016MDWGFfinal-16G_6_Mar-May_3323_edited_07172017.sav

Case Title 1: "2016 MDWG FINAL WITH 2015 SERIES MMWG FINAL"

Case Title 2: "MDWG 2016G WITH MMWG 2016L"

Bus Range: 522800 - 528799

***** LOSSES BY ELEMENT CLASS *****

----- AUTOTRANSFORMER LOSSES (MW) -----

| [345/230 kV] | [345/115 kV] | [230/115 kV] | [230/69 kV] | [115/69 kV] | [TOTAL] |
|----------------|----------------|----------------|---------------|---------------|-----------|
| 0.764193 | 0.0 | 4.626019 | 0.0 | 2.540981 | 7.931192 |

----- TRANSMISSION LINE LOSSES (MW) -----

| [345 kV] | [230 kV] | [115 kV] | [69 kV] | [TOTAL] |
|------------|------------|------------|-----------|-----------|
| 9.852043 | 48.48065 | 41.44 | 6.09039 | 105.8631 |

----- CASE TOTALS -----

TOTAL AREA LOSSES: 113.7943MW

| | |
|------------------------|----------------------------------|
| TOTAL 345kV LINES: 10 | TOTAL 345/230kV TRANSFORMERS: 7 |
| TOTAL 230kV LINES: 79 | TOTAL 345/115kV TRANSFORMERS: 0 |
| TOTAL 115kV LINES: 387 | TOTAL 230/115kV TRANSFORMERS: 53 |
| TOTAL 69kV LINES: 289 | TOTAL 230/69kV TRANSFORMERS: 0 |
| | TOTAL 115/69kV TRANSFORMERS: 86 |

Appendix N
Powerflow Study Loss Results

Case Name: 2016MDWGFina1-16S_6_June-Aug_4432_edited.sav

Case Title 1: "2016 MDWG FINAL WITH 2015 SERIES MMWG FINAL"

Case Title 2: "MDWG 2016S WITH MMWG 2016S"

Bus Range: 522800 - 528799

* * * * * L O S S E S B Y E L E M E N T C L A S S * * * * *

----- AUTOTRANSFORMER LOSSES (MW) -----

| | | | | | |
|----------------|----------------|----------------|---------------|---------------|-----------|
| [345/230 kV] | [345/115 kV] | [230/115 kV] | [230/69 kV] | [115/69 kV] | [TOTAL] |
| 0.853081 | 0.0 | 5.503023 | 0.0 | 3.201583 | 9.557688 |

----- TRANSMISSION LINE LOSSES (MW) -----

| | | | | |
|------------|------------|------------|-----------|-----------|
| [345 kV] | [230 kV] | [115 kV] | [69 kV] | [TOTAL] |
| 7.400779 | 40.52235 | 43.1105 | 10.91577 | 101.9494 |

----- CASE TOTALS -----

TOTAL AREA LOSSES: 111.5071MW

| | |
|------------------------|----------------------------------|
| TOTAL 345kV LINES: 10 | TOTAL 345/230kV TRANSFORMERS: 7 |
| TOTAL 230kV LINES: 79 | TOTAL 345/115kV TRANSFORMERS: 0 |
| TOTAL 115kV LINES: 391 | TOTAL 230/115kV TRANSFORMERS: 53 |
| TOTAL 69kV LINES: 288 | TOTAL 230/69kV TRANSFORMERS: 0 |
| | TOTAL 115/69kV TRANSFORMERS: 86 |

Appendix N
Powerflow Study Loss Results

Case Name: 2016MDWGFfinal-16W_6_Sep-Dec_3386_edited.sav

Case Title 1: "2016 MDWG FINAL WITH 2015 SERIES MMWG FINAL"

Case Title 2: "MDWG 2016W WITH MMWG 2016W"

Bus Range: 522800 - 528799

***** L O S S E S B Y E L E M E N T C L A S S *****

----- AUTOTRANSFORMER LOSSES (MW) -----

| | | | | | |
|----------------|----------------|----------------|---------------|---------------|-----------|
| [345/230 kV] | [345/115 kV] | [230/115 kV] | [230/69 kV] | [115/69 kV] | [TOTAL] |
| 0.733934 | 0.0 | 4.827077 | 0.0 | 2.383778 | 7.944789 |

----- TRANSMISSION LINE LOSSES (MW) -----

| | | | | |
|------------|------------|------------|-----------|-----------|
| [345 kV] | [230 kV] | [115 kV] | [69 kV] | [TOTAL] |
| 10.88771 | 44.96074 | 44.78917 | 5.293581 | 105.9312 |

----- CASE TOTALS -----

TOTAL AREA LOSSES: 113.876MW

| | |
|------------------------|----------------------------------|
| TOTAL 345kV LINES: 10 | TOTAL 345/230kV TRANSFORMERS: 7 |
| TOTAL 230kV LINES: 79 | TOTAL 345/115kV TRANSFORMERS: 0 |
| TOTAL 115kV LINES: 397 | TOTAL 230/115kV TRANSFORMERS: 55 |
| TOTAL 69kV LINES: 287 | TOTAL 230/69kV TRANSFORMERS: 0 |
| | TOTAL 115/69kV TRANSFORMERS: 85 |

Appendix O
Energy Loss Factors

SOUTHWESTERN PUBLIC SERVICE COMPANY
ENERGY LOSS FACTOR CALCULATION
12 MONTHS ENDING DECEMBER 2016

| Loss Factor Calculation | | Total Generation Inputs = 31,758,276.076 kWh | | | | | | | | | | | |
|-------------------------|---|--|--|-----------------|--------------------------|-------------------|-------------------------|-----------------------------|--|--|--|--|----------------|
| | | Loss Factor to Gross up to Gen | Loss factor to gross up 1 level 1/(1-loss %) | % loss by level | KWH Flow into each level | KWH Loss by Level | KWH Sales by loss level | Loss Check Loss fac X sales | | | | | |
| 10 | | | | | | | | | | | | | |
| 11 | Sales at the Generator | 1.000000 | 1.000000 | 0.000000% | 31,758,276.076 | 0 | 8,295,082 | 8,295,082 | | | | | 8,295,082 |
| 12 | @ Generation | | | | | | | | | | | | |
| 13 | | | | | | | | | | | | | |
| 14 | Sales @ 115, 230 & 345 KV | 1.029633 | 1.029633 | 2.877997% | 31,749,980,994 | 913,763,470 | 13,821,244,766 | 14,230,809,712 | | | | | 14,230,809,712 |
| 15 | Level 2 | | | | | | | | | | | | |
| 16 | | | | | | | | | | | | | |
| 17 | Sales @ 69 KV | 1.035919 | 1.006105 | 0.606835% | 17,014,972,758 | 103,252,764 | 4,942,501,116 | 5,120,030,814 | | | | | 5,120,030,814 |
| 18 | Level 3 | | | | | | | | | | | | |
| 19 | | | | | | | | | | | | | |
| 20 | Sales @ Primary (33kv - 2.4kv) | 1.105898 | 1.067553 | 6.327826% | 11,969,218,878 | 757,391,388 | 3,704,794,414 | 4,097,124,733 | | | | | 4,097,124,733 |
| 21 | Level 4 | | | | | | | | | | | | |
| 22 | | | | | | | | | | | | | |
| 23 | Secondary Sales @ the Transf. | 1.125047 | 1.017315 | 1.702074% | 7,507,033,076 | 127,775,281 | 3,205,486,688 | 3,606,323,182 | | | | | 3,606,323,182 |
| 24 | Level 5 | | | | | | | | | | | | |
| 25 | | | | | | | | | | | | | |
| 26 | Sales served by secondary lines | 1.128389 | 1.002971 | 0.296182% | 4,173,771,108 | 12,361,948 | 4,161,409,160 | 4,695,688,321 | | | | | 4,695,688,321 |
| 27 | Level 6 | | | | | | | | | | | | |
| 28 | | | | | | | | | | | | | |
| 29 | Total | | 1.064152 | 6.028491% | 31,758,276.076 | 1,914,544,850 | 29,843,731,226 | 31,758,271,843 | | | | | 31,758,271,843 |
| 30 | | | | | | | | | | | | | |
| 31 | | | | | | | | | | | | | |
| 32 | | | | | | | | | | | | | |
| 33 | | | | | | | | | | | | | |
| 34 | Composite Factors 5 & 6 to Gen. | 1.126935 | 1.019023 | 1.866746% | 7,507,033,076 | 140,137,228 | 7,366,895,848 | | | | | | |
| 35 | | | | | | | | | | | | | |
| 36 | Loss factor calculation for gross up to a target level equals the product of loss factors for each level up through the target level. | | | | | | | | | | | | |
| 37 | | | | | | | | | | | | | |
| 38 | | | | | | | | | | | | | |
| 39 | | | | | | | | | | | | | |
| 40 | | | | | | | | | | | | | |
| 41 | | | | | | | | | | | | | |
| 42 | | | | | | | | | | | | | |
| 43 | | | | | | | | | | | | | |
| 44 | | | | | | | | | | | | | |
| 45 | | | | | | | | | | | | | |
| 46 | | | | | | | | | | | | | |
| 47 | | | | | | | | | | | | | |
| 48 | | | | | | | | | | | | | |
| 49 | | | | | | | | | | | | | |
| 50 | | | | | | | | | | | | | |
| 51 | | | | | | | | | | | | | |
| 52 | | | | | | | | | | | | | |
| 53 | | | | | | | | | | | | | |
| 54 | | | | | | | | | | | | | |
| 55 | | | | | | | | | | | | | |
| 56 | | | | | | | | | | | | | |
| 57 | | | | | | | | | | | | | |
| 58 | | | | | | | | | | | | | |
| 59 | | | | | | | | | | | | | |
| 60 | | | | | | | | | | | | | |
| 61 | | | | | | | | | | | | | |
| 62 | | | | | | | | | | | | | |
| 63 | | | | | | | | | | | | | |
| 64 | | | | | | | | | | | | | |
| 65 | | | | | | | | | | | | | |
| 66 | | | | | | | | | | | | | |
| 67 | | | | | | | | | | | | | |
| 68 | | | | | | | | | | | | | |
| 69 | | | | | | | | | | | | | |
| 70 | | | | | | | | | | | | | |
| 71 | | | | | | | | | | | | | |
| 72 | | | | | | | | | | | | | |
| 73 | | | | | | | | | | | | | |
| 74 | | | | | | | | | | | | | |
| 75 | | | | | | | | | | | | | |
| 76 | | | | | | | | | | | | | |
| 77 | | | | | | | | | | | | | |
| 78 | | | | | | | | | | | | | |
| 79 | | | | | | | | | | | | | |
| 80 | | | | | | | | | | | | | |
| 81 | | | | | | | | | | | | | |
| 82 | | | | | | | | | | | | | |
| 83 | | | | | | | | | | | | | |
| 84 | | | | | | | | | | | | | |
| 85 | | | | | | | | | | | | | |
| 86 | | | | | | | | | | | | | |
| 87 | | | | | | | | | | | | | |
| 88 | | | | | | | | | | | | | |
| 89 | | | | | | | | | | | | | |
| 90 | | | | | | | | | | | | | |
| 91 | | | | | | | | | | | | | |
| 92 | | | | | | | | | | | | | |
| 93 | | | | | | | | | | | | | |
| 94 | | | | | | | | | | | | | |
| 95 | | | | | | | | | | | | | |
| 96 | | | | | | | | | | | | | |
| 97 | | | | | | | | | | | | | |
| 98 | | | | | | | | | | | | | |
| 99 | | | | | | | | | | | | | |
| 100 | | | | | | | | | | | | | |
| 101 | | | | | | | | | | | | | |
| 102 | | | | | | | | | | | | | |
| 103 | | | | | | | | | | | | | |
| 104 | | | | | | | | | | | | | |
| 105 | | | | | | | | | | | | | |
| 106 | | | | | | | | | | | | | |
| 107 | | | | | | | | | | | | | |
| 108 | | | | | | | | | | | | | |
| 109 | | | | | | | | | | | | | |
| 110 | | | | | | | | | | | | | |
| 111 | | | | | | | | | | | | | |
| 112 | | | | | | | | | | | | | |
| 113 | | | | | | | | | | | | | |
| 114 | | | | | | | | | | | | | |
| 115 | | | | | | | | | | | | | |
| 116 | | | | | | | | | | | | | |
| 117 | | | | | | | | | | | | | |
| 118 | | | | | | | | | | | | | |
| 119 | | | | | | | | | | | | | |
| 120 | | | | | | | | | | | | | |
| 121 | | | | | | | | | | | | | |
| 122 | | | | | | | | | | | | | |
| 123 | | | | | | | | | | | | | |
| 124 | | | | | | | | | | | | | |
| 125 | | | | | | | | | | | | | |
| 126 | | | | | | | | | | | | | |
| 127 | | | | | | | | | | | | | |
| 128 | | | | | | | | | | | | | |
| 129 | | | | | | | | | | | | | |
| 130 | | | | | | | | | | | | | |
| 131 | | | | | | | | | | | | | |
| 132 | | | | | | | | | | | | | |
| 133 | | | | | | | | | | | | | |
| 134 | | | | | | | | | | | | | |
| 135 | | | | | | | | | | | | | |
| 136 | | | | | | | | | | | | | |
| 137 | | | | | | | | | | | | | |
| 138 | | | | | | | | | | | | | |
| 139 | | | | | | | | | | | | | |
| 140 | | | | | | | | | | | | | |
| 141 | | | | | | | | | | | | | |
| 142 | | | | | | | | | | | | | |
| 143 | | | | | | | | | | | | | |
| 144 | | | | | | | | | | | | | |
| 145 | | | | | | | | | | | | | |
| 146 | | | | | | | | | | | | | |
| 147 | | | | | | | | | | | | | |
| 148 | | | | | | | | | | | | | |
| 149 | | | | | | | | | | | | | |
| 150 | | | | | | | | | | | | | |
| 151 | | | | | | | | | | | | | |
| 152 | | | | | | | | | | | | | |
| 153 | | | | | | | | | | | | | |
| 154 | | | | | | | | | | | | | |
| 155 | | | | | | | | | | | | | |
| 156 | | | | | | | | | | | | | |
| 157 | | | | | | | | | | | | | |
| 158 | | | | | | | | | | | | | |
| 159 | | | | | | | | | | | | | |
| 160 | | | | | | | | | | | | | |
| 161 | | | | | | | | | | | | | |
| 162 | | | | | | | | | | | | | |
| 163 | | | | | | | | | | | | | |
| 164 | | | | | | | | | | | | | |
| 165 | | | | | | | | | | | | | |
| 166 | | | | | | | | | | | | | |
| 167 | | | | | | | | | | | | | |
| 168 | | | | | | | | | | | | | |
| 169 | | | | | | | | | | | | | |
| 170 | | | | | | | | | | | | | |
| 171 | | | | | | | | | | | | | |
| 172 | | | | | | | | | | | | | |
| 173 | | | | | | | | | | | | | |
| 174 | | | | | | | | | | | | | |
| 175 | | | | | | | | | | | | | |
| 176 | | | | | | | | | | | | | |
| 177 | | | | | | | | | | | | | |
| 178 | | | | | | | | | | | | | |
| 179 | | | | | | | | | | | | | |
| 180 | | | | | | | | | | | | | |
| 181 | | | | | | | | | | | | | |
| 182 | | | | | | | | | | | | | |
| 183 | | | | | | | | | | | | | |
| 184 | | | | | | | | | | | | | |
| 185 | | | | | | | | | | | | | |
| 186 | | | | | | | | | | | | | |
| 187 | | | | | | | | | | | | | |
| 188 | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |

Check using rounded factors
-4,233

Appendix P
Demand Loss Factors

| SOUTHWESTERN PUBLIC SERVICE COMPANY | | | | | | | | | | |
|---|---------------------------------|----------|----------|-----------|-------------|---------|---------|-----------|-----------|-----------|
| DEMAND LOSS FACTOR CALCULATION | | | | | | | | | | |
| 12 MONTHS ENDING DECEMBER 2016 | | | | | | | | | | |
| Total Generation Inputs = <div>6,003,000 Kw</div> <div>6,003,000 Kw</div> | | | | | | | | | | |
| System Peak Hr. | | | | | | | | | | |
| Loss factor to | | | | | | | | | | |
| gross up 1 level | | | | | | | | | | |
| 1/(1-loss %) | | | | | | | | | | |
| % loss by level | | | | | | | | | | |
| KW Flow into each level | | | | | | | | | | |
| KW Loss by Level | | | | | | | | | | |
| KW Demand by loss level | | | | | | | | | | |
| Loss Check Loss fac X sales | | | | | | | | | | |
| 1 | | | | | | | | | | |
| 2 | | | | | | | | | | |
| 3 | | | | | | | | | | |
| 4 | | | | | | | | | | |
| 5 | | | | | | | | | | |
| 6 | | | | | | | | | | |
| 7 | | | | | | | | | | |
| 8 | | | | | | | | | | |
| 9 | | | | | | | | | | |
| 10 | | | | | | | | | | |
| 11 | Sales at the Generator | 1.000000 | 1.000000 | 0.000000% | 6,003,000 | | 0 | | 0 | 0 |
| 12 | @ Generation | | | | | | | | | |
| 13 | | | | | | | | | | |
| 14 | Sales @ 115, 230 & 345 KV | 1.023667 | 1.023667 | 2.311973% | 6,003,000 | | 138,788 | | 2,244,415 | 2,297,533 |
| 15 | Level 2 | | | | | | | | | |
| 16 | | | | | | | | | | |
| 17 | Sales @ 69 KV | 1.030961 | 1.007126 | 0.707520% | 3,619,798 | | 25,611 | | 1,090,485 | 1,124,247 |
| 18 | Level 3 | | | | | | | | | |
| 19 | | | | | | | | | | |
| 20 | Sales @ Primary (33kv - 2.4kv) | 1.131015 | 1.097049 | 8.846390% | 2,503,702 | | 221,487 | | 436,754 | 493,975 |
| 21 | Level 4 | | | | | | | | | |
| 22 | | | | | | | | | | |
| 23 | Secondary Sales @ the Transf. | 1.161769 | 1.027192 | 2.647180% | 1,845,461 | | 48,853 | | 640,746 | 744,399 |
| 24 | Level 5 | | | | | | | | | |
| 25 | | | | | | | | | | |
| 26 | Sales served by secondary lines | 1.166539 | 1.004106 | 0.408905% | 1,155,862 | | 4,726 | | 1,114,734 | 1,300,380 |
| 27 | Level 6 | | | | | | | | | |
| 28 | | | | | | | | | | |
| 29 | Total | | 1.078990 | 7.320754% | 5,966,598 = | 439,465 | + | 5,527,133 | | 5,960,535 |
| 30 | | | | | | | | | | |
| 31 | Composite Factor Levels 5 and 6 | 1.164833 | 1.029901 | 2.903288% | 1,845,461 | | 53,579 | | 1,755,480 | |

App. Q - Factors

12 MONTHS ENDING DECEMBER 2016

| Line No. | | Rate Class Loss Factors by Loss Level | | |
|----------|------------------------------|---------------------------------------|---------------------|---------------------|
| | | Loss Level | Demand Loss factors | Energy Loss Factors |
| 1 | | | | |
| 2 | | | | |
| 3 | | | | |
| 4 | Residential Lighting | 6 | 1.164833 | 1.126935 |
| 5 | Residential Space Heating | 6 | 1.164833 | 1.126935 |
| 6 | Small General Service | 6 | 1.164833 | 1.126935 |
| 7 | General Service - Secondary | 5 | 1.164833 | 1.126935 |
| 8 | General Service - Primary | 4 | 1.131015 | 1.105898 |
| 9 | Large General Service | | | |
| 10 | Transmission Backbone | 2 | 1.023667 | 1.029633 |
| 11 | Sub-Transmission | 3 | 1.030961 | 1.035919 |
| 12 | Street Lighting | 6 | 1.164833 | 1.126935 |
| 13 | Area Lighting | 6 | 1.164833 | 1.126935 |
| 14 | Small Municipal and School | 6 | 1.164833 | 1.126935 |
| 15 | Large Municipal | 6 | 1.164833 | 1.126935 |
| 16 | Large Municipal - Primary | 4 | 1.131015 | 1.105898 |
| 17 | Large Schools | 5 | 1.164833 | 1.126935 |
| 18 | Interruptible Service -SAS 4 | 4 | 1.131015 | 1.105898 |
| 19 | Wholesale - Service -115 kV | 2 | 1.023667 | 1.029633 |
| 20 | Wholesale - Service -69 kV | 3 | 1.030961 | 1.035919 |

* For Levels 5 & 6, the Composite Factors used in billing applications are stated.