

# **Southwestern Public Service Company**

## **10 Year Transmission Plan**

**and**

## **20 Year Transmission Vision**

***December 23, 2009***

This report contains transmission planning data which is conceptual in nature and is subject to change. The transmission projects listed may change scope, in-service dates, or may not be constructed.

## **Executive Summary**

This report documents the Southwestern Public Service Company (SPS) transmission plans for a 10 year planning horizon and a scenario assessment for a 20 year planning horizon.

### **10 Year Plan Summary**

The development efforts for this plan are a combination of internal SPS transmission planning efforts and Southwest Power Pool (SPP) Transmission Expansion Plan (STEP) activities. STEP looks at a 10 year planning horizon and documents needed system improvements to meet NERC reliability standards TPL-001 and TPL-002. The 10 Year Plan is primarily a reliability-based plan to assure compliance with NERC planning standards and maintain load-serving capabilities.

Long-term firm transmission service that has been sold under the SPP OATT or the Xcel Energy Joint OATT has been included in the studies.

Speculative new generation projects are not included in this transmission plan. Only new generation, that have a signed interconnection agreement and have demonstrated a commitment to construct, are included.

### **20 Year Scenario Assessment**

The 20 Year Assessment is more conceptual in nature, not a rigid plan. The Assessment does not consider different wind penetration levels or different resource alternatives. It concentrates primarily on future transmission development to support development of renewable energy in the SPS footprint. The focus is to provide an overview of current discussions occurring in the region related to long term transmission development.

The difficulty with such long-term transmission assessments is defining the resource commitments that will occur. If that can be done with certainty, then that previously unknown factor has been quantified and multiple transmission plans can be created with considerable confidence.

Independent transmission projects are discussed in the report. No discussion has been provided of perceived transmission – market interactions.

## **Introduction**

This transmission plan is a summary of the transmission capital construction needs for the Southwestern Public Service (SPS) transmission system over a 10 year period starting with 2010 and going through 2019. It is based on the study work done by Southwest Power Pool (SPP) through their Transmission Expansion Planning (STEP) process, the SPS Transmission Reliability Assessment group, and the results of processing new load and delivery point interconnections, transmission service requests, and generation interconnection requests.

The certainty of needed projects decreases in the later years due to the uncertainty of new load projects, new generation requests, and new resource additions.

## **I. Methodology & Assumptions**

### **A. Scope & Purpose**

The purpose of this study is to document the transmission additions needed on the SPS transmission system 10 years into the future. The study is based on the most recent set of powerflow models and includes all firm loads, firm transactions, but no non-firm or economy energy transactions in the planning studies.

### **B. Transmission Grid Description**

SPS's service territory is primarily agricultural, containing large areas of oil and gas production. SPS serves electric consumers in most of the towns within the service territory. Many areas outside those towns are served by rural electric cooperatives.

Oil and natural gas production is a major industrial activity within SPS's service region. The agricultural areas are mostly irrigated by pumping water from natural underground sources. Crops include cotton, corn, grain sorghum, soybeans, and peanuts. There is also a large investment in cattle feeding, and more recently, dairy operations, in the service territory.

As of December 31, 2008 the breakdown of total SPS sales by revenue class is 11.6 percent residential, 47.0 percent commercial and industrial, 39.6 percent wholesale, and 1.8 percent for public authorities, street lighting, and area lighting.

SPS has an installed net generation capability of 4,290 megawatts (MW), with 49.4 percent of this capacity in coal-fired plants and 50.6 percent in plants utilizing other fuels (primarily natural gas). SPS purchases 221 MW of firm power and energy from Borger Energy Associates, L.L.P. (BEA-Blackhawk), a qualifying facility (QF), whose purchased power contract was certified in Case No. 2770. SPS also purchases firm power and energy from Exelon Generation L.L.C. (Exelon) (150 MW), Engineered Carbons QF (12 MW), Sid Richardson QF (9 MW), and Lubbock Power and Light (LP&L) (219 MW). SPS also purchases energy from approximately 636 MW of wind generation facilities connected to SPS's New Mexico and Texas system. In September 2008, SPS began purchasing power from the Lea Power Partners', LLC (LPP) Hobbs Generating Station, near Hobbs, New Mexico (526 MW).




Figure 1 – SPS Service Territory

Figure 1 is a map of SPS's service territory showing the locations of SPS's generating facilities and its major transmission lines. SPS's transmission system contains 345 kV, 230 kV, 115 kV, and 69 kV transmission lines. The interconnections from SPS to eastern utilities are primarily at 345 kV and 230 kV, but there are also some 115 kV interconnections. Retail and wholesale load is served at all voltages except 345 kV. Generation is located on the SPS system in five main complexes – the Nichols/Harrington Plants near Amarillo, Texas; the Cunningham/Maddox/Hobbs Generating Station complex, near Hobbs, New Mexico; the Jones Plant and LP&L generation facilities in Lubbock, Texas; the Tolk Plant/Plant X complex near Earth, Texas; and the Golden Spread Mustang Plant facility near Denver City, Texas. There are smaller plant locations such as Moore County Plant, near Dumas, Texas and Blackhawk Plant, near Borger, Texas.

SPS is interconnected with the Western Electricity Coordinating Council (WECC) and the SPP. SPS's location and tie lines are shown in the attached Figure 2. SPS's has three interconnections with utilities in the WECC. The first interconnection is the 200 MW HVDC tie with Public Service Company of New Mexico (PNM) and El Paso Electric Company (EPE) near Artesia, New Mexico (Eddy County HVDC Converter) and that converter is owned by EPE and PNM. operates Eddy County HVDC for EPE and PNM and the facility

is shown by Line H on Figure 2. The second interconnection with WECC is the 200 MW (nominal rating) Blackwater HVDC tie, which is owned and operated by PNM near Clovis, New Mexico. It is shown by Line E in Figure 2. The third interconnection with WECC is the Lamar HVDC (210 MW nominal rating) that is owned and operated by PSCo. The Lamar facility is shown by Line A in Figure 2 (Finney – Lamar HVDC).

Additionally, SPS has three primary interconnection facilities with the SPP, a 230 kV transmission line and two 345 kV transmission lines. The first interconnection is a 230 kV transmission line that interconnects SPS's Grapevine Interchange to Public Service Company of Oklahoma's (PSO) Elk City Interchange, (shown as Line D on Figure 2). The second interconnection with PSO is a 345 kV transmission line from SPS's TUCO Interchange to PSO's Oklaunion Interchange near Oklaunion, Texas (shown as Line I on Figure 2). The third interconnection is a 345 kV transmission line that interconnects Potter County Interchange near Amarillo, Texas, to the Finney Interchange to Holcomb Station near Garden City, Kansas. Sunflower Electric Power Corporation (Sunflower) owns Holcomb Station. This line was placed in service in September 2001 and is shown as Line B on Figure 2.

SPS's interconnection with West Texas Utilities (WTU), an American Electric Power operating company (shown as Line G on Figure 2). There is a 115 transmission kV line from the Nichols Station to WTU's 115 kV interchange at Shamrock, Texas. At this interchange, there is a voltage transformation from 115 kV to 69 kV and from 69 kV to 138 kV. This is necessary because SPS's system is designed for 115 kV, but WTU's system is designed for 138 kV, as is most of western and southern Oklahoma. Additionally, SPS has another 115 kV interconnect with WTU (shown as Line F on Figure 2). At Jericho, WTU has a 115/69 kV transformer and 69 kV transmission line to connect to their 69 kV transmission system in the Clarendon, Texas area.

SPS also has a 115 kV interconnection with Sunflower from SPS's Texas County Interchange near Guymon, Oklahoma, to Sunflower's Liberal Interchange at Liberal, Kansas. This interconnection has a phase shifter located at SPS's Texas County Interchange, which prevents loop flow problems in western Kansas (shown as Line C on Figure 2, below).




Figure 2 – SPS Transmission Interconnections

## **C. Planning Process**

### **1. FERC 890 – Subregional/Others**

The SPP Regional Transmission Organization (RTO) has functional control over the high voltage (60kV and above) transmission systems of SPS under Attachment AI of the SPP Open Access Transmission Tariff (OATT). As an RTO, SPP performs coordinated and transparent regional planning for all transmission facilities in the multistate SPP footprint through the annual SPP STEP process. Attachment O of the SPP OATT describes the STEP process. It is through this process that most transmission planning for the SPS system complies with FERC's Order No. 890 planning principles. SPP also functions as the Regional Entity (RE) for the SPP region and is responsible for reliability oversight (including transmission planning and reliability standards compliance) for the SPP region pursuant to a Delegation Agreement between SPP and the North American Electric Reliability Corporation (NERC). SPS is also a member of the SPP Reserve Sharing group.

In addition to the STEP regional planning process, SPS also conducts local planning to identify transmission improvements. These necessary improvements are to ensure the adequacy and reliability of the SPS system for the benefit of interconnected entities and transmission customers that utilize SPS system transmission facilities to receive transmission service. This local planning process is described in this Attachment R – SPS to the Joint OATT. Attachment R – SPS should be reviewed in coordination with Attachment O to the SPP OATT, since the SPS local planning process is coordinated with and supplements the SPP regional planning process.

The SPS transmission planning region is limited to the boundary of SPS's electrical system.

SPS's internal transmission planning process is responsive to direct transmission requests by wholesale NITS customers and native loads for new load interconnections.

SPS meets the nine principles in the following manner:

- Coordination – periodic meetings, study coordination, new project submission to SPP through their modeling efforts.
- Openness – works through SPP STEP process, but also coordinates directly when working on 115 and 69 kV systems, studies are posted on SPS OASIS, open coordination and planning meetings.
- Transparency – posted planning criteria (including study methodology), posted guidelines for interconnections.
- Information exchange – SPS uses NITS load forecasts from customer, if provided, for input to SPP modeling.
- Comparability – SPP currently does studies of long term firm transmission service requests under XE OATT using parallel method to SPS's Aggregate Transmission Service Study methodology. SPS clusters studies together for new

retail and wholesale load requests when it will be beneficial and more efficient. SPS typically considers impacts on neighboring systems. SPS is implementing a load and delivery point request queue to provide additional comparability.

- Dispute resolution – any issues for customers of SPP OATT are resolved under the procedures of that OATT and any issues for customers of the XE Joint OATT are resolved under the procedures of that OATT.
- Regional participation – SPS provides the modeling data for itself and its customers, if provided, to SPP for their modeling processes. SPS is active in SPP reviews, working groups, committees
- Economic planning studies – SPP has a regional economic planning process and SPS participates in that process. Any customer requesting economic studies may do so under SPP's processes.
- Cost allocation – SPP OATT addresses cost allocation (Attachment J) and SPS subscribes to this approach. SPS has its own policy for cost allocation related to new load interconnections.

SPS is located in Subregion 1 of the SPP. Subregion 1 includes SPS, Sunflower Electric Power Corp., and MidWest Electric. SPP holds one annual sub-regional meeting to review transmission projects in the sub-regions and get input for the STEP from those sub-region members.

## **2. SPP Transmission Expansion Plan**

The SPP STEP is a reliability centered region wide transmission planning process that covers a 10 year planning horizon. SPP specifically creates the powerflow models from the data submitted by its members and customers. SPP then considers all sold firm transmission service and then models the region for the next 10 years. Powerflow contingency studies are done and some stability studies to evaluate the regions performance over the planning horizon. Should improvements be necessary, the SPP will provide Notices To Construct (NTC) for facilities to meet the planning criteria.

SPS submits most, if not all, of its future transmission projects through this process for validation by SPP.

The results of the SPP STEP plan are incorporated in to the SPS Transmission Plan along with any new load serving projects developed by SPS.

The study scope of the SPP STEP is included in Appendix A.

## **3. SPP Balanced Portfolio**

The Balanced Portfolio projects were developed by SPP to provide a group of economic upgrades that would benefit the entire SPP region and allocating the costs for those projects over that full region. Savings are realized when transmission upgrades reduce congestion on the SPP transmission system and produce lower production cost for operation of member systems.



Projects were analyzed by SPP and many were proposed to increase flowgate ratings, increase import or export capability, reduce congestion, or provide a benefit which leads to greater economy of operation.

Through this effort, SPP is expecting lower overall fuel and customer costs by the implementation of this group of projects. The value of the entire portfolio is \$692 million and was approved by the SPP Board of Directors in April 2009. Notifications To Construct were issued in June 2009.

SPS received a Notification To Construct for the Tuco-Woodward 345 kV transmission line. This project will be jointly constructed with Oklahoma Gas and Electric (OGE). SPS will construct and own the transmission line from Tuco to the TX/OK state line and OGE will construct and own the transmission line from Woodward to the OK/TX state line. Expected in-service date of this project is spring 2014.

The results of the most recent planning exercise are shown below in Figure 3.




Figure 3 – SPP Balanced Portfolio Projects

SPS has not committed to construct any sections of the current proposed 765 kV plan. These studies are being refined to better reflect more current levels of wind generation

export from the SPS area to eastern markets, commitments by other transmission owners for specific segments of the plan, and better knowledge of adjacent regions transmission planning activities.

## **D. Drivers Impacting Transmission Planning**

### **1. Regulatory / Environmental Considerations**

SPS is regulated by the FERC for wholesale customers and by two state regulatory agencies: the Public Utility Commission of Texas (PUCT) and the New Mexico Public Regulation Commission (NMPRC). These bodies are responsible for approving SPS's rate requests and also approving SPS's permits for new transmission line construction and siting of those new transmission lines. Siting approval is done at a state level in both Texas and New Mexico. In Oklahoma, SPS has no retail loads. Oklahoma has their transmission and siting approval only at county levels and no processes at the state levels.

SPS service territory is mostly privately owned land in Texas, and considerable public land in New Mexico. Much of New Mexico land is owned by the State of New Mexico therefore permitting activities frequently require the approvals of the federal Bureau of Land Management, federal Bureau of Reclamation, and the State of New Mexico. Both states have permit issuing processes for cultural and historic resources in addition to requirements for mitigation of archeological sites that are found along rights of way.

### **2. SPP Generator Interconnection Queue**

SPP performs generation interconnection studies for SPS and other members of the SPP region, under the requirements of the SPP OATT. Currently, the queue consists of:

- ~ 9,900 MW wind energy
- ~ 3,900 MW fossil fuel based energy
- ~ 70 MW solar energy

Interconnection requests are significantly backlogged at SPP and are taking approximately a year or more to go through the study process. SPP has instituted a new generator interconnection process in 2009, which clusters the requests into group studies to reduce the backlog and provide more timely response.

One major issue from these requests is that most generation developers are not requesting firm transmission service. Some of these are being constructed and will impact the operation of the SPS transmission system on a non-firm basis. Once these are connected to the SPS transmission system, SPS Transmission Operations must frequently review outputs from these types of generators to see if their output must be curtailed to prevent operating security issues on the transmission system.

### **3. Transmission Service Studies**

The SPP Aggregate Transmission Service study is a process where customers that want transmission service can request a study three times per year. All requests are made through an open season process combined into one study effort, with system upgrade costs being determined in the study.

SPS also conducts long-term network transmission service studies for requests within its system boundary if the request is under the XE OATT. The customers that are affected by this are SPS retail and GSEC, who is taking grandfathered service under the XE OATT. After January 1, 2010 SPS retail customers will be taking transmission service under the SPP OATT.

#### **4. Wholesale / Retail Load Interconnections**

New load interconnections are studied by SPS. If the customer is a transmission service customer of SPP, the request is still studied by SPS. SPP is developing a process which will formalize this arrangement. The requests for new load service are not submitted through the SPP Aggregate Transmission Service Study process.

In 2009, SPS has seen a marked decrease in requests for new wholesale and retail service points. This has been brought on by the economic downturn. However, some of those requests that were made, and then deferred, are now being re-activated, albeit at a very slow rate. As before, the primary interest is oil and gas production and agriculture related development.

#### **5. Texas / New Mexico State Renewable Mandates**

New Mexico has implemented the Renewable Energy Act, NMSA 1978 Section 62-16-1, et seq. (NMREA) to bring significant economic development and environmental benefits to New Mexico. SPS will require approximately 435,000 MWH (10% of New Mexico retail sales) of annual renewable energy or renewable energy certificates (RECs) beginning in 2011 in order to comply with the regulation. The above requirement increases to 15% of NM retail sales beginning Jan 2015 and beginning January 2020 to 20% of NM retail sales. Certain technologies have been earmarked with the following minimums:

Wind	>= 20%
Solar	>= 20%
Other	>= 10% (biomass/geothermal)
Distributed Generation	>= 1.5% (increasing to 3% in 2015)
Remainder	>= 48.5%

The remaining category can be filled with any of the above four identified energy technologies. SPS is developing plans to meet this requirement.

Texas has implemented a statewide renewable mandate and portfolio standard (RPS). The 2005 Texas Legislature increased the state's total renewable-energy mandate to 5,880 MW by 2015 and a target of 10,000 MW in 2025. Each

provider is required to obtain new renewable energy capacity based on their market share of energy sales times the renewable capacity goal.

The RPS mandated that electricity providers (competitive retailers, municipal electric utilities, and electric cooperatives) collectively generate 2,000 MW of additional renewable energy by 2009. The Texas RPS has been so successful that its 10-year goal was met in just over six years. SPS has met its requirements under this mandate.

## **6. Stakeholder Groups and Their Concerns**

### **a. Cooperatives**

The cooperatives served by SPS include Golden Spread Electric Cooperative (GSEC), and their 11 member cooperatives. There are also the New Mexico cooperatives – Lea County Electric Cooperative, Central Valley Electric Cooperative, Farmers Electric, and Roosevelt County Electric Cooperative. Their concerns are primarily resource adequacy, transmission import limitations, and SPP RTO and NERC Compliance processes. GSEC is approximately a 1200 MW load, and the New Mexico cooperatives are approximately 400 MW load.

### **b. Municipalities**

SPS serves the West Texas Municipal Power Authority (WTMPA) as a full requirements customer. This is an association of City of Lubbock, Floydada, Brownfield, and Tulia. Their approximate load is 350 MW. Their issues are long-term resource adequacy, transmission import capacity, and SPP RTO and NERC Compliance processes.

### **c. Neighboring Utilities**

Cap Rock Electric is a southern utility that is served through two points of interconnections. Their load was transferred from ERCOT in the mid-90s to SPS and the SPP and their 138 kV transmission system overlays the ERCOT. Their load is approximately 125 MW and their issues are long-term resource adequacy, transmission import capacity, the need for remedies to the north-south transmission constraint issues, and rapid load growth within their footprint.

### **d. Independent Power Producers**

There are a number of independent power producers in the SPS area. They are:

- Blackhawk – Borger Energy Associates, L.L.P
- Hobbs Plant – Lea Power Partners, L.L.P.
- Sid Richardson
- Engineered Carbons
- Mustang Plant- Yoakum County Electric Cooperative

- John Deere Wind – numerous facilities
- San Juan Mesa (Padoma) – Mission Wind
- Caprock Wind – Babcock and Brown
- Wildorado – Cielo Wind Power
- White Deer – Shell Wind
- Majestic - NextEra Energy Resources, LLC.
- Noble - Noble Great Plains Windpark, LLC.
- Sunray – Valero
- Mesalands Community College – Tucumcari
- Aeolus – Vestas Wind Systems
- Llano Estacado – Shell Wind Energy
- High Plains Wind Power – John Deere Renewables

The issues each producer faces are different since the fossil fuel units and San Juan, Wildorado, Caprock Wind, and White Deer are designated network resources with firm transmission service. John Deere Wind, Aeolus, High Plains Wind Power and Sunray are Qualifying Facilities are receiving non-firm transmission service. SPS also purchases the output of the Qualifying Facilities.

The developers that are considering marketing their power into the SPP EIS market are very concerned about the transmission deliverability for their plants. SPS is also concerned about how many developers want to build plants to provide energy to this market as long as any transmission upgrades to provide firm service are absent.

e. Industrial Customers

The industrial customers are varied and diverse. SPS has key account representatives that work with these retail customers. For example, SPS has the following major industrial customers:

Apache Corporation	Intrepid
Covenant Health System	Mosaic
Enterprise Products Operating L.P.	Bell Helicopter-Textron
White Energy - Hereford	Pioneer Natural Resources
White Energy - Plainview	Cannon AFB
X-Fab Texas Inc.	Leprino Foods
XTO Energy	National Enrichment Facility
Chevron	Navajo Refining Company
ConocoPhillips	Asarco
Hess	Baptist St Anthony's Hospital
Oxy Permian	BWXT-Pantex
Valero Energy	Panda Energy - Hereford
Cargill Meat Solutions	Sid Richardson
Degussa	Swift and Company - Cactus TX
Northwest Texas Hospital	Tyson
CRMWA (Canadian River Municipal Water Authority)	Owens Corning

These customers are concerned about transmission system development being made, but only the necessary development to provide the required service. They have not been supportive of speculative transmission facilities for future uses that are poorly defined today.

## 7. Load Forecast

The historic actual and current forecast for the SPS BA, or control area, are is plotted below.




Figure 4 – SPS BA Coincident Peak Loads

The current forecast is shown below.




Figure 5 – SPS BA Forecast

## **8. Existing and New Generation Assumptions**

- a. Wind generation levels – assumed to be low (10%) in summer peak transmission planning model. The data used to represent the seasonal dispatch levels was taken from wind data obtained from the Alternative Energy Institute at West Texas A&M in Canyon, Texas. The dispatch levels for the non-summer peak models include the April Light (50%), Spring Peak (45%), Fall Peak (29%) and Winter Peak (30%). These values are based on average hourly values as a percent of the wind farm nameplate.
- b. New Generation Locations – no new generation locations are modeled in the SPP STEP study unless they have met several criteria such as: a signed interconnection agreement, a power purchase agreement, environmental permits granted, and major equipment on order. For the purpose of making the models through the SPP Model Development Working Group process, fictitious generation is shown at Tolk and Jones plant as needed to balance future load and generation requirements. This fictitious generation is removed in the SPP study processes.
- c. New Generation Capacity – no new SPS generation capacity is coming on the system after the Lea Power Partners Hobbs Plant. SPS has issued a Request for Proposal for 600 MW of dispatchable fossil based generation, but no entity has been selected as a winner in that process. SPS has also issued an RFP for up to 300 MW of additional wind generation, but no winners have been selected through that process either.

## **9. Planning Criteria**

SPS subscribes to the Southwest Power Pool ("SPP") Reliability Criteria, which incorporates compliance with the appropriate North American Electric Reliability Corporation ("NERC") Planning Standards, which are enforced by the Regional Entity ("RE") function of SPP.

SPS's own specific criteria are applied in the development of the power flow data and conducting the studies. These should be considered in coordination with Attachment R-SPS to the Xcel Energy Operating Companies Joint OATT. Brief descriptions of those criteria follow.

### Voltage Criteria

SPS allows a range of 0.95 per unit (p.u.) to 1.05 p.u. for the system voltage at a specific bus, for system intact conditions. SPS does not limit the maximum allowable voltage change during a contingency (voltage deviation criteria). The maximum allowable voltage change is dependent on the makeup of the customer load in the area of the contingency and the starting point for the voltage before the contingency. The +/-



0.05 p.u. base case voltage range is applied to all voltages, including sub-transmission networks.

During contingency studies SPS allows a range of 0.90 per unit (p.u.) to 1.05 per unit (p.u.) for the system voltage for most buses. The contingency range is dependent on the type of load at the bus under examination, the transmission equipment rating, and any regulating equipment which can be used to regulate the voltage delivered to the customer. Voltage deviations up to 1.10 per unit voltage may be permitted depending on the specific equipment ratings.

When evaluating available transfer capability, the TUCO 230 kV bus voltage is monitored and not allowed to go below 0.92 p.u. to minimize the risk of voltage collapse and system separation from the SPP. This requirement will be removed if the TUCO Static Var Controller is in service.

#### Transmission Element Rating Criteria

SPS has rated its transmission elements in accordance with the Xcel Energy Transmission Facility Rating Methodology, Version 4.0; July 8, 2009. The document requires the use of the most limiting element for each transmission branch and considers all elements of the transmission branch. Normal and emergency ratings are developed for both summer and winter periods and used in the powerflow models.

#### Transformer Tap Ratios

Transformers with both fixed high side taps and low side tap changers are modeled to reflect the setting of the high side taps. The actual load tap changer adjustment range of the specific transformer is provided in the power flow data.

#### North-South Flow Criteria

SPS has three 230 kV north-south transmission lines and two 115 kV north-south transmission lines. The 230 kV lines are the Amarillo South Interchange-Swisher County Interchange line, the Bushland Interchange-Deaf Smith Interchange-Plant X line, and the Potter County Interchange-Plant X line. The 115 kV lines are the Randall County Interchange-Palo Duro-Happy Interchange line and Osage Switching Station-Canyon-Hereford Interchange line. The stability limit is 800 MW flow south on these lines for an outage of a Tolk unit.

#### Interconnected Reliability Criteria

These criteria provide a framework for analyzing SPS's system in transfer analysis with other companies to which SPS is connected.

SPS's AC or synchronous interconnections have historically been built for system reliability. However, due to increases in load, these interconnections are presently required to meet demand during peak loading conditions. Additionally, these interconnections provide for emergency power if one of SPS's generators is suddenly

taken off line. The largest SPS generators are the Tolk Plant units, both of which are rated 540 MW net. The existing synchronous interconnections are designed to allow the SPS system to sustain the loss of a Tolk unit without separating from the SPP.

The evaluation of power flows in or out of SPS's system should be based on SPS's reliability criteria to maintain synchronous connection with the SPP at all times. It is SPS's interconnected reliability criteria that any proposed transmission service will not reduce the ability of SPS to remain connected with the SPP in all contingencies under study. Thus, if any import of power is scheduled into the SPS system, this scheduled import cannot be so large that the loss of this import forces SPS to separate from the SPP. Similarly, the evaluation of an export of power from the SPS system should meet the same criteria. With the export or import of power occurring, there should not be cascading loss of interconnections with the SPP due to the single outage of a transmission or generation element.

### General Assessment Practices

On an annual basis, SPS prepares power flow model data based on the previous year's annual peak and the current load forecast. Historical actual load point data is used in preparing the new power flow base cases.

SPS performs single contingency outage studies on the summer peak models by examining the loss of each transmission element. The transmission elements are defined to be all transmission lines between 345 kV and 115 kV and transformers with high side connections to these transmission voltage levels. Each single contingency outage case is reviewed to determine if system improvement is required to provide reliable service during this contingency. Single contingency studies may be performed on the winter peak and average load models, to determine the sensitivity of the network to outages with seasonal generation patterns. Studies on the 69 kV sub-transmission network are targeted every two years. SPS's 69 kV network is extensive and is for a large part operated radial. Studies on selected portions of the 69 kV network may be done on a much more frequent basis, depending on load growth in a specific area.

If a network addition is proposed in a specific region of the transmission system, single contingency studies will be made of that area with the proposed addition to determine its ability to provide service. The studies will be made in the model year that the transmission addition is proposed to go into service and also for the model year that is the farthest into the future. For example, if a new 230/115 kV interchange is to go into service in 2009, the addition of this interchange would be studied in 2009 power flow models, and would also be studied in the future models to determine the long-term performance of this network addition.

For SPS' study purposes, power flow simulations are done with area interchange control enabled with tie-lines and load, transformers with load tap changers regulating, and generator voltage regulation enabled. All SPS generators are assumed to be capable of regulating voltage between their minimum and maximum reactive power limits. Small non-utility generators, and wind farms do not provide significant voltage regulation. The

HVDC interconnections are block loaded in power flow simulations. Studies can be done with a full Newton solution or a decoupled Newton solution.

Where new generation is needed but not yet known as to its exact location, fictitious generators will be placed on the system as needed to maintain a balance between load and generation. These are normally placed at the Tolk Plant bus first, and if needed the Jones Plant bus. These are internal busses in the powerflow model.

#### Interconnected Reliability Assessment Practices

It is important that any proposed transfer of power or construction of facilities not degrade SPS's interconnected reliability. SPS does perform contingency studies on the loss of a Tolk unit, the largest generating unit in the control area, with all HVDC tie-lines in service as a baseline case. As stated above SPS conforms to the NERC Planning Standards and produces annual studies in response to specific standards requirements. The standards, which can affect transmission are significant and are not listed in this report.

### **10. Transmission Congestion**

SPS has several flowgates which have caused concern in past years. The primary flowgates are the North-South flowgate and the import flowgate, SPPSPSTIES.

The North-South flowgate limits due to a stability limitation based on loss of south generation. With additional non-firm wind based resources north of the flowgate, it hits its limit much more frequently than in past years.

The other key flowgate is the import flowgate. It is based on the sum of all of SPS AC ties to the SPP. This flowgate, while not a significant limit for operation today, does potentially limit future transactions. However, if future firm transactions are requested, SPP will study the needed service and determine what upgrades are needed to increase the import capability. A map of those constraints is shown in Figure 6.




Figure 6 – Transmission Congestion Map

## 11. Economic Planning

SPS reviews studies by others and is actively involved in various regional economic planning efforts such as:

- Department of Energy (DOE) national transmission congestion studies
- SPP Transmission Expansion Planning (STEP) process
- Eastern Interconnection Planning Collaborative (EIPC)
- Joint Coordinated System Planning (JCSP)

The economic planning process involves various resource scenario evaluations, economic impact of market congestion on transmission elements, and energy and demand loss evaluation on transmission elements.

The benefits are frequently not large enough to justify stand alone transmission investment. Economic benefits, coupled with other benefits (reliability, local or regional policy, etc.), are factored into the transmission alternative evaluation.

## **II. System Plans**

A. SPS Planning Zones has eight planning zones that it uses in its planning and these are based on operating historical data being available to analyze performance in these regions.

They are:

- Zone 1: Western Kansas, Oklahoma Panhandle, & Texas North Areas:  
Includes Garden City, Guymon, Dumas, Dalhart, Spearman, Borger, Pampa, and Wheeler.
- Zone 2: Amarillo Area: Adrian, Vega, Channing, Amarillo, Groom and McLean.
- Zone 3: Clovis, Hereford, Canyon Area: Includes Portales, Clovis, Muleshoe, Friona, Hereford, and Canyon.
- Zone 4: Central Plains and Lubbock Area: Includes Tulia, Plainview, Littlefield, Levelland, Brownfield, Post, Lubbock, and Floydada.
- Zone 5: Yoakum and Gaines Area: Includes Denver City, Seminole, and Seagraves.
- Zone 6: Pecos Valley Area: Includes Roswell, Artesia, and Carlsbad.
- Zone 7: Southeastern New Mexico Area: Includes Hobbs, Eunice, and Jal.
- Zone 8: Caprock Area: Includes Midland and Big Spring.

A map of the zones is shown below.




Figure 7 – SPS Planning Zone Map

## **B. Zone Descriptions**

### **Zone 1 Description:** Western Kansas, Oklahoma Panhandle, & Texas North Area

The Zone 1 region is one of the larger territorial regions in the Southwestern Public Service (SPS) system. It encompasses the transmission system from the northern end at Garden City, Kansas to the southeastern end near Shamrock, Texas. The eastern border for this region is on the Texas-Oklahoma state line and extends as far west as Lamar, Colorado but the service area typically extends westward to the New Mexico state line.


The summer peaking loads for this region consist mostly of industrial and agricultural with lesser levels of commercial and residential. The 2009 summer peak load is forecasted to be approximately 850 MW. SPS provides service to four cooperatives in this region, one in Oklahoma and three in Texas.

Most of the transmission lines in this region are operated at 115 and 69 kV, but there are also some 230 and 345 kV lines. There are two 345 kV tie lines and one major internal 345 kV line between Finney and Potter. There is a 230 kV tie line and two additional 115 kV tie lines in this region. One of the 115 kV tie lines is through a 115 kV 150 MVA phase shifting transformer. Most of the 230 and 115 lines are operated looped and the 69 kV lines are normally operated in a radial fashion to minimize outage risk. Switching can normally be performed on the 69 kV system to restore service from a different source.

The maximum generation in this region is approximately 580 MW with 210 MW being from wind generation, and the remaining from gas generators and cogen facilities. Much more wind generation is earmarked for this region.

#### **Challenges:**

- Huge amounts of additional wind generation is expected to be added to this region and will require significant transmission expansion.
- The 115 kV loop from Moore County to Dalhart and Dallam will continue to be an issue until the Dallam to Sherman 115 kV line is complete.
- Load growth in the north Texas and Oklahoma panhandles is going to require significant transmission expansion, which has been addressed with the Texas North Improvements.
- Currently, the capacity of the Kingsmill 115/69 kV transformer is of concern under certain peak load conditions.
- By 2014 the capacity of new Howard 115/69 kV Interchange will be exceeded due to load growth.
- By 2019 the capacity of the Bowers 115/69 kV Interchange will be exceeded due to load growth.





**Zone 2 Description:** Amarillo Area: Adrian, Vega, Channing, Amarillo, Groom and McLean.

The Amarillo Metro area covers the entire city of Amarillo as well as areas to the north up to Channing, White Deer to the East, and Adrian to the west. The load for this area is a mix of residential, industrial, agricultural, oilfield and commercial loads.

The transmission lines in the Amarillo Area are operated at 345, 230, 115, and 69 kV levels. The 345 kV transmission line out of Potter Co. is connected to the north (WECC) with nominal capacity of 210 MW. The 230 and 115 kV transmission lines out of Nichols Substation are connected to the East (SPP) via Grapevine and Kirby substations respectively.

In the Amarillo Metro area, SPS owns two generating stations at Nichols and Harrington plant with a generating net capacity of approximately 1,500 MW. There are also two independent power wind farm-generating facilities at Bushland and White Deer with a combined nominal capacity of 168 MW.

Challenges:

- Currently the 115 kV line from Osage to Canyon East, the 115 kV line from East Plant to Manhattan, the 230 kV line from Nichols to Amarillo South, the 69 kV line from Northwest Interchange to North Amarillo switching station, the 69 kV underground cable from Georgia to Lawrence Park, and the 230/115 kV transformer at Randall County Interchange lack the capacity for continued reliable service.
- By 2011 the capacity issues on the 115 kV transmission system extends to the transmission line from East Plant to Pierce Street, the line from Manhattan to Osage, and the line from Osage to Georgia. Also by 2011 the capacity of the East Plant 230/115 kV transformer will have been depleted for further reliable service.
- By 2014 the capacity issues on the 115 kV transmission persists and include the line from East Plant to Whitaker, the line from Osage to Pierce Street, and the line from Nichols to Cherry Street. Also by 2014 the 69 kV overloads include the transmission lines from Northwest Interchange to East Plant.
- If there are no system improvements to alter the growing transmission problems in the Amarillo area, by 2019 most of the transmission elements in the area will lack capacity for reliable transmission service including the 115/69 kV transformers at Georgia and Northwest Interchanges, and the 230 kV line from Harrington to East Plant.



### **Zone 3 Description:** Clovis, Hereford, and Canyon Area

The Clovis, Hereford, and Canyon area covers the cities of Portales, Clovis, Tucumcari, Muleshoe, Friona, Hereford, and Canyon. The load for this area is a mix of residential, agricultural, industrial, and commercial loads.

The transmission lines in this area are operated at 230, 115, and 69 kV levels. SPS provides power to two electric cooperatives in the Hereford and Clovis area.

There are two independent power wind farm-generating facilities at Caprock in Tucumcari and San Juan in Elida both in New Mexico. They have a combined nominal capacity of 200 MW. In the last six months, wind farm generation interconnection request studied totaled approximately 880 MW.

#### **Challenges:**

- Currently the 115 kV line from Randall County Interchange to Palo Duro Substation, the 115 kV line from Osage Substation to Canyon East Substation, both 115/69 kV transformers at Bailey County Interchange, and one of the Deaf Smith 230/115 kV transformers lack the capacity for continued reliable service.
- By 2011, the 230/115 kV transformers at Roosevelt County and Oasis Interchanges will no longer have the capacity to cover the loss of the other, the second 230/115 kV transformer at Deaf Smith Interchange will no longer have the capacity to cover the loss of the other, and the 115 kV line from Canyon East to Canyon West will overload.
- By 2014, both 230 kV lines from Tolk to Roosevelt County Interchange, the 230 kV line from Oasis to Roosevelt County, the 115 kV line from Roosevelt County Interchange to Curry County Interchange, the 115 kV line south of Hereford Interchange, and the 115/69 kV transformers at Portales Interchange will no longer have the capacities for reliable service.
- If there are no improvement projects to address the above problems, by 2019 the 115 kV line from Curry County to Hereford Interchange, and both of the Curry County 115/69 kV transformers will no longer have the capacity for reliable service.



#### **Zone 4 Description: Central Plains and Lubbock Area**

The Central Plains zone is a region in the West Texas Plains from Muleshoe to Brownfield and from Crosbyton to the Texas-New Mexico border. This area has approximately 1,630 MW of summer peaking load that is made up from a mix of residential, industrial, agricultural, and commercial loads. The load growth in this area is due to the increased farm irrigation, irrigation conversions from gas to electric, and the expanding industrial base for the production of ethanol.

SPS provides power to six electrical cooperatives, all members of Golden Spread Electric Cooperative, that lie within the Central Plains area. SPS also serves Lubbock Power & Light (LP&L) at transmission level voltages, and is in direct competition with the municipal electric utility at the distribution level.

The transmission lines in the Central Plains area are operated at 230, 115, and 69 kV. Most of the 230 and 115 kV lines are operated looped or networked. The 69 kV lines are operated as radial feeders, with normally open line-switches to restore service to loads affected by an outage.

Within the Central Plains zone there is approximately 2,550 MW of Southwestern Public Service (SPS) generation within the Central Plains area from the facilities at Tolk, Plant-X, and Jones plants. Within the city of Lubbock, Texas on LP&L's system there is approximately 256 MW of generation. Figure 11 on the following page illustrates the area covered by Zone 4.

#### **Challenges:**

- Currently both of the 115/69 kV transformers at Crosby County Interchange, both of the 115/69 kV transformers at Lynn County Interchange, both of the 115/69 kV transformers at TUCO Interchange, and one of the 115/69 kV transformers at Kress Interchange lack capacity for reliable service. Additionally, the 69 kV voltage in the Plainview area are inadequate for service under summer peak load conditions and will violate NERC Category A voltage requirements.
- By 2014 the 230 kV line from Jones Plant to Grassland Interchange, the 115 kV line from Lubbock South Interchange to SP-Woodrow Interchange, the 115 kV line from TUCO Interchange to Stanton Substation, the 230/115 kV transformer at Swisher County Interchange, the 115/69 kV transformer at Happy County Interchange, and the 345/230 kV transformer at TUCO Interchange will lack the capacity for reliable service.
- By 2019, if there are no system improvements, the 115 kV lines from Plant-X to Bailey County Interchange, from Grassland Interchange to Lynn County Interchange, from Hale County Interchange to TUCO Interchange, from Hale County Interchange to Lamton Interchange, from Kress Interchange to Swisher County Interchange, and from Lynn County Interchange to SP-Woodrow Interchange will overload. Also overloading by 2019 are the 230 kV line from Lubbock South to Jones Plant, the 230/115 kV transformers at Carlisle, Grassland, and TUCO interchanges. Other overloads observed by 2019 include the 69 kV lines from Kress Interchange to Kress Rural Substation to LH-Plainview, and from Lamton Interchange to LC-Olton Substation to LC-Hart Substation.

- [illegible]

30

## **Zone 5 Description: Yoakum and Gaines Area**

The Yoakum and Gaines zone is a region in the West Texas Plains covering the Yoakum and Gaines Counties along the Texas-New Mexico border. This area has approximately 430 MW of summer peaking load that is made up from a mix of residential, industrial, agricultural, and commercial loads. The majority of the load growth in this area is due to the expanding oil and gas production. With increased oil prices, this area will experience large blocks of load additions. An example of what load additions are expected in this zone is where a single customer states (not a request) that their operations will be expanding to include 130 to 150 MW of new load that has not been studied before. This area also experiences a very high load factor with very little year-round change.

SPS also provides power to two electrical cooperatives that lie within the Yoakum and Gaines area. One of these cooperatives is a member of Golden Spread Electric Cooperatives, Inc. The other cooperative is a total requirements wholesale customer.

The transmission lines in the Yoakum and Gaines area are operated at 230, 115, and 69 kV. Most of the 230 and 115 kV lines are operated looped or networked. The 69 kV lines are operated as radial feeders, with normally open line-switches to restore service to loads affected by an outage.

Within the Yoakum and Gaines zone there is approximately 760 MW of generation capacity from the facilities at Mustang Station. SPS does not own this generation and this generation may not be dispatchable in the off peak seasons. Figure 12 on the following page illustrates the area covered by Zone 5.

### **Challenges:**

- Currently both of the 115/69 kV transformers at Gaines County Interchange lack capacity for reliable service. The approved Legacy Interchange project will relieve this capacity concern.
- Additionally the 115 kV transmission line from Denver City Interchange through Lea County Electric Cooperative's system terminating at Lea County Interchange is inadequate to carry the connected load from end to end. A yet un-contracted new interconnection with Lea County Electric Cooperative would mitigate this condition.
- By 2019 the capacity of the new 115 kV line from Gaines County Interchange to Legacy Interchange will need to be increased to meet the anticipated loading.




Figure 12 – Planning Zone 5 Map



## **Zone 6 Description: Pecos Valley**

The Pecos Valley zone is a region in the eastern New Mexico from Roswell to White City that includes Chaves and Eddy Counties. This area has approximately 466 MW of summer peaking load that is made up from a mix of residential, industrial, agricultural, and commercial loads. The load growth in this area is due to the increased farm irrigation, irrigation conversions from gas to electric, and the expanding industrial base for the production of ethanol.

SPS provides power to the cities of Roswell, Artesia, and Carlsbad and several other rural communities. SPS also serves an area electrical cooperative that has a total requirements contract with SPS.

The transmission lines in the Pecos Valley area are operated at 230, 115, and 69 kV. Most of the 230 and 115 kV lines are operated looped or networked. The 69 kV lines are operated as radial feeders, with normally open line-switches to restore service to loads affected by an outage.

Within the Pecos Valley zone there is only 18 MW of generation at the Carlsbad Plant with all other resources outside the zone. The Eddy County HVDC interconnect with EPE is at Eddy County Interchange. Figure 13 on the following page illustrates the area covered by Zone 6.

### **Challenges:**

- Currently the 115/69 kV transformers at Roswell, Carlsbad, Artesia, and Chaves County Interchanges lack the capacity for reliable service. The approved Ocotillo conversion project will relieve the capacity issues at Carlsbad Interchange, the Eagle Creek Interchange Project will mitigate the capacity concerns in the Artesia area, and the load conversions in the Roswell area to 115 kV will relieve this capacity concerns at Roswell and Chaves County Interchanges.
- By 2014 the capacity of the 115 kV line from Roswell Interchange to Brasher Substation Tap, and the capacity of the 230/115 kV transformer at Chaves County Interchange will need to be increased to meet the anticipated loading.
- Then by 2019, if there are no system improvements, the 115 kV lines from Chaves County Interchange to Samson Substation, from Chaves County Interchange to Urton Substation, the 69 kV line from Chaves County Interchange to Price Substation, and the 230/115 kV transformers at Eddy County and Seven Rivers Interchanges from will overload.




Figure 13 – Planning Zone 6 Map

## **Zone 7 Description: Hobbs/Jal Area**

The Hobbs/Jal zone is a region in southeastern New Mexico covering Lea County along the Texas-New Mexico border. This area has approximately 344 MW of summer peaking load that is made up from a mix of residential, industrial, agricultural, and commercial loads. The majority of the load growth in this area is due to the expanding oil and gas production, and with the high oil prices, this area will experience large blocks of load additions.

SPS serves the communities of Hobbs, Jal, Eunice and several other rural communities. The transmission lines in the Hobbs/Jal area are operated at 230 and 115 kV. Most of the 230 and 115 kV lines are operated looped or networked.

Within the Hobbs/Jal zone there is approximately 1200 MW of generation capacity from the facilities at Cunningham, Maddox, and Hobbs Stations. SPS owns and operates the generation at Cunningham and Maddox, while SPS purchases the generation at the Hobbs Plant through long-term agreements. Figure 14 on the following page illustrates the area covered by Zone 7.

### **Challenges:**

- By 2014 the capacity of the 115 kV lines from Maddox Station to Sanger Switching Station will need to be increased to meet the anticipated loading.
- By 2019 the capacity concerns on the 115 kV transmission lines from Maddox Station to Monument Substation and from Sanger Switching Station to Oxy Permian Substation.



## **Zone 8 Description: Caprock Area**

The Caprock zone is the southern most region of the SPS service territory, covering an area between Midland, Texas to Big Springs, Texas and as far south as Reagan County, Texas. Caprock Electric Cooperative is a total-requirements customer of SPS. They serve approximately 112 MW of transmission and distribution loads in the Caprock zone. SPS serves the Caprock zone through two 230 kV transmission lines originating south of Lubbock, Texas, and at the new generating facilities near Hobbs, New Mexico. Currently there is no significant generation within the Caprock zone.

The load in this area is summer peaking with a mix of residential, industrial, agricultural, and commercial loads. The majority of the load growth in this area will be to support the growth of the oil and gas industry.

### **Challenges:**


- Currently the 230 kV tie-lines from Hobbs Station to Midland Interchange and from Grassland Interchange to Borden Interchange do not have the capacity to carry the Caprock Electric Cooperative (CREC) load from end to end. The CREC system is operated at 138 kV, and is largely uncompensated for the loss of either 230 kV tie-line from SPS. Current load projections for CREC exceed the 150 MW contingency transformer limit; therefore, system improvements on the SPS to CREC ties are needed as-soon-as-feasible.




## C. Projects by Zone

Drawings are provided for most of the existing and new projects. SPP STEP drawings are used where applicable. SPP STEP Drawings show a desired in-service date based on the studies performed. Realistic dates are being determined based on completion of project scopes. In Status column of table, Current means project is under construction – Proposed means a new project.

**Figure 17 - Zone 1 – Current and Proposed Projects**



**Figure 18 - Zone 1 – Current and Proposed Projects (Cont.)**



#	Project	Est. ISD	Status	Drivers
1	Wheeler Interchange – Howard Substation 230/115 kV Project	6/2010	Current	Reliability
2	2 <sup>nd</sup> 115/69 kV transformer at Kingsmill Interchange	12/2011	Proposed	Reliability
3	2 <sup>nd</sup> 115/69 kV transformer at Howard Interchange	6/2013	Proposed	Reliability
4	2 <sup>nd</sup> 115/69 kV transformer at Bowers Interchange	6/2018	Proposed	Reliability



Figure 19 - Zone 2 – Current and Proposed Projects





Figure 20 - Zone 3 – Current and Proposed Projects



**Figure 21 - Zone 4 – Current and Proposed Projects**





Figure 22 - Zone 4 – Current and Proposed Projects (Cont.)




#	Project	Est. ISD	Status	Drivers
1	Hale Co. 115/69 kV auto upgrades	1/2010	Current	Reliability
2	Plainview City 115/69 kV Int.	6/2014	Proposed	Reliability
3	Kress – Plainview City 115 kV line	6/2014	Proposed	Reliability
4	Kress Rural conversion to 115 kV	6/2014	Proposed	Reliability
5	Plainview North conversion to 115 kV	6/2014	Proposed	Reliability


<span style="color: green;">—</span>	345 kV
<span style="color: orange;">—</span>	230 kV
<span style="color: blue;">—</span>	115 kV

Note: Project scope and timing subject to change

Figure 23 - Zone 4 – Current and Proposed Projects (Cont.)




**Figure 24 - Zone 5 – Current and Proposed Projects**




#	Project	Est. ISD	Status	Drivers
1	Legacy 115/69 kV Int.	6/2011	Current	Reliability
2	Seminole - Hobbs 230 kV line.	6/2015	Current	Reliability
3	2 <sup>nd</sup> 230/138 kV transformer at Borden Interchange	9/2012	Proposed	Reliability



Figure 25 - Zone 6 – Current and Proposed Projects




#	Project	Est. ISD	Status	Drivers
1	Eagle Creek 115/69 kV Int.	4/2011	Current	Legal
2	Ocotillo Substation conversion to 115 kV	6/2011	Current	Reliability
3	Roswell 69 kV Conversion Project.	6/2012	Current	Reliability
4	Roswell Int. – Brasher-Tap 115 kV re-conductor.	5/2012	Proposed	Reliability
5	Chaves Co. 230/115 kV auto upgrade.	6/2014	Proposed	Reliability
6	Chaves Co. – Urton Sub 115 kV re-conductor.	6/2017	Proposed	Reliability
7	Chaves Co. – Samson Sub 115 kV re-conductor.	6/2017	Proposed	Reliability
8	2 <sup>nd</sup> 230/115 kV auto at Eddy Co. Int.	6/2018	Proposed	Reliability
9	Artesia – CV-Artesia Sub 69 kV re-conductor.	6/2019	Proposed	Reliability




Note: Project scope and timing subject to change

Figure 26 - Zone 7 – Current and Proposed Projects




#	Project	Est. ISD	Status	Drivers
1	Maddox Station – Sanger Switch 115 kV re-conductor	6/2011	Proposed	Reliability
2	Maddox Station – Monument Sub 115 kV re-conductor	6/2011	Proposed	Reliability
3	Hobbs Plant 345/230 kV auto.	4/2012	Proposed	Reliability
4	Convert Hobbs Plant to Midland Int. to 345 kV	4/2012	Proposed	Reliability
5	Midland Int. 345/138 kV auto	4/2012	Proposed	Reliability



Note: Project scope and timing subject to change



Figure 27 - Tie Lines - Current and Proposed Projects



Note: Project scope and timing subject to change

Zone 2 Project – Potter-Mid-Point 345 kV line

Zone 4 Project – Tuco-Mid-Point 345 kV line

#### **D. Project Tracking Information**

SPS provides to SPP project tracking information, such as in-service dates, updates cost estimates, key equipment delivery information on quarterly basis for the STEP projects. This information can be obtained by going to this link and downloading the records for SPS.

Link: <http://www.spp.org/section.asp?pageID=114>

### **III. Summary of the Initial 10-Year Plan**

#### **A. Summary of Proposed Additions from 2009 – 2019**

The transmission additions discussed in this report for the upcoming 10 year horizon are primarily for load serving purposes. They consist of numerous transformer upgrades, 230 and 115 kV transmission line construction, and installation of some transmission capacitor banks for improved voltage response in contingencies.

The sheer magnitude of the upgrades is due to heavy import into the SPS area and an increased load forecast for the SPS area through all years of the studies. SPS is currently seeking new generation additions through various RFP processes. Once the winners to the generation RFPs are known, it is that some of the recommended STEP upgrades will not need to be done. SPS will work with SPP to refine the list of upgrades as additional information becomes known.

The 2009 STEP process identified some locations where conversion of 69 kV substation transformers to 115 kV operation will need to be done to remove loading issues on SPS's 69 kV transmission system. The exact choice of which substation to convert to a higher voltage may change, but the trend for more 69 to 115 kV conversions will continue into the future.

#### **B. Transmission Interface Expansion**

SPS is aware of the interface issues which it faces. SPS is on the far western edge of the eastern electrical grid with AC interconnections available only to the north and east. Many SPP members have the potential for AC interconnection in all directions around their load service regions. As part of this report and the 2009 SPP STEP, no detailed study of the transmission interface capability (transfer capability) has been done. The study processes that are used in the SPP STEP assure that the proposed projects will be sufficient to import the required flows from resources external to SPS. Should a detailed transfer analysis study be done in the future, the additions of the Tuco-Woodward 345 kV line plus the STEP-required Potter-Stateline-Anadarko 345 kV line are expected to raise the SPS import and export capability substantially.

#### **C. Challenges and Issues**

SPS faces many upcoming challenges. They can be listed below.

- a. Load growth – With the uncertain economic climate affecting energy production and agricultural development in the region, SPS's customers may be postponing development projects until their market is more stable.

- b. SPP – New internal transmission planning process with a longer time frame planning view (20 year planning horizon) containing enhanced economic analysis along with a reliability analysis – Integrated Transmission Planning
- c. Transmission and substation construction level – availability of internal and external engineering and construction resources to support the transmission projects in this plan
- d. Material deliveries – Industry pressure due to increased transmission development nationwide and higher focus on renewable energy. Challenge to make deliveries on needed dates.
- d. NERC/FERC Compliance requirements – Additional compliance study requirements which may require additional transmission additions under short time frames in response to new standards.

## **Section IV. 20 Year Scenario Assessment**

This section of the report examines potential 20-year scenarios for the SPS control area. They are not intended to represent detailed study work, but more conceptual plans that have a reasonable basis in developments being done currently in the SPS area.

These scenarios do not consider varied load levels or varied wind energy development, but rather consider scenarios for transmission development. SPS' 2009 peak loads were robust considering the state of the energy economy in Texas. Requests for new wind energy connections have continued to come to SPP, albeit at a slower rate. Both facts are indicative of the future strength of the various sectors of the economies that make up the demands on the SPS transmission system.

The scenarios for consideration are for future transmission development. Significant wind energy development seems possible given the quantity of wind energy interconnection requests in the SPS footprint.

There are four transmission development scenarios:

- Scenario I – SPS Quanta EHV Study
- Scenario II – High Plains Express Initiative
- Scenario III – Tres Amigas Grid Connection Proposal
- Scenario IV – Multiple Grid Overlays

### **Scenario I – SPS Quanta EHV Study**

In 2009, SPS requested Quanta Technologies to perform studies looking at the development of EHV transmission to serve large wind energy development in the SPS area. The study was based on adding 16,000 MW of wind energy inside the SPS footprint, exporting nearly 10,000 MW to the SPP, and approximately 3,000 MW to the WECC. The remaining 3,000 MW was consumed by SPS in an effort to maximize their consumption of renewable energy.

Location of the wind resources was based on the then current SPP Generation Interconnection queue. Resources were located county by county in an effort to improve resolution as compared to previous studies. Quanta evaluated five alternatives, each with varying amounts of 345 kV and 765 KV transmission added to the cases.

The recommended solution in the study was known as Alternative 2 shown in Figure 28. This plan had a 765 kV loop going deeply into southeastern New Mexico. Considerable 345 kV infrastructure was also required to fully support the 765 kV transmission system. The estimated costs of this proposed system is \$ 4.2 billion, with \$1.9 billion in 765 kV transmission costs and \$2.3 billion in 345 kV infrastructure costs.

SPS has no current plans to pursue construction of Alternative 2, but does see the Quanta study as an important 'strawman' study in the long term analysis of transmission required to move large amounts of wind energy to market.




Figure 28 – SPS – Quanta EHV Study – Alternate 2

## Scenario II – High Plains Express Initiative

The High Plains Express Initiative (HPX) is a proposed transmission development that will connect the eastern slopes of Colorado and New Mexico with the Southern Arizona areas. The purpose is to move renewable energy (wind and solar) to major load centers in or near southern California. Eleven parties are participating in the studies, including Public Service Company of Colorado, an Xcel Energy operating company. The studies are in the second phase of the feasibility studies.

The proposal consists of two 1,280 miles 500 kV AC transmission lines that are routed through Wyoming, Colorado, New Mexico, and Arizona. The proposed transmission lines will connect various regional wind, solar, and fossil fuel based projects. A diagram of the project is shown in Figure 29, below. Connections to the eastern grid are possible based on position of proposed lines to eastern grid facilities.




Figure 29 – High Plains Express Initiative

### Scenario III – Tres Amigas Multi-Grid Interconnection

The proposed Tres Amigas project is a proposed HVDC facility that would link all three grids at a common point. The ultimate capacity is 5,000 MW transfer into each grid. The location of the project is just north of Clovis, New Mexico. This location was chosen to be close to the rich wind energy developments of eastern New Mexico and the Texas Panhandle. It is also close to the CREZ 345 kV transmission lines which are being built into the SPS area to harvest wind energy for ERCOT.

A diagram of the proposed Tres Amigas facility is shown in Figure 30. Many transmission lines will need to be built into this facility and they will likely be a mixture of 345 kV and 765 kV. SPS expects significant future studies will be performed on this proposed project.




Figure 30 – Tres Amigas Project



## Scenario IV – Multiple Grid Overlays

Multiple grid overlays are collections of proposed projects which may start in one interconnection area of the grid, but spans other regions. It is important to understand potential cumulative impacts from these plans on SPS customers even though they may not directly serve SPS customers. Through these efforts, SPS can strive to minimize impacts.

A good example of this is shown in Figure 31 below.




Figure 31 – Multiple Grid Overlays

The green lines in the WECC area are the High Plains Express Projects. The red lines in the SPS and Texas area are the Competitive Renewable Energy Zone (CREZ) transmission projects. The purple lines comprise the SPP EHV plan. Lastly, the blue lines represent a plan developed through the Joint Coordinated System Plan (JCSP) for high voltage direct current transmission lines to carry renewable energy to eastern load centers.

Another example of grid overlays is shown in Figure 32. This diagram shows the SPS Quanta EHV study Alternative 2 recommendation along with the Texas CREZ

transmission lines. The SPS region is the focal point where lines from all grids can meet.




Figure 32 – SPS EHV Alternative 2 and Texas CREZ Transmission Lines

SPS is in a strategic position for transmission development for renewable energy. Any proposed transmission concepts must be evaluated to develop reliable transmission plans. Considerable study work is needed and will be done as these conceptual plans are refined into a practical framework for transmitting renewable energy.

Public policy is just as important as the planning studies for these conceptual projects, and must be clarified to provide a framework to resolution of the plans. The clear and concise policy statements will provide guidance to the system planners who can then go about the business of refining the concepts into detailed plans to meet the required public policy.

## **Appendices**

### **Appendix A - SPP STEP Study Scope**

#### **List of Maps (Diagrams)**

Figure 1 – SPS Service Territory  
Figure 2 – SPS Transmission Interconnections  
Figure 3 – SPP Balanced Portfolio Projects  
Figure 4 – SPS BA Coincident Peak Loads  
Figure 5 – SPS BA Forecast  
Figure 6 – Transmission Congestion Map  
Figure 7 – SPS Planning Zone Map  
Figure 8 – Planning Zone 1 Map  
Figure 9 – Planning Zone 2 Map  
Figure 10 – Planning Zone 3 Map  
Figure 11 – Planning Zone 4 Map  
Figure 12 – Planning Zone 5 Map  
Figure 13 – Planning Zone 6 Map  
Figure 14 – Planning Zone 7 Map  
Figure 15 – Planning Zone 8 Map  
Figure 16 – Zone 1 and 2 Projects  
Figure 17 – Zone 1 – Current and Proposed Projects  
Figure 18 – Zone 1 – Current and Proposed Projects (Cont.)  
Figure 19 – Zone 2 – Current and Proposed Projects  
Figure 20 – Zone 3 – Current and Proposed Projects  
Figure 21 – Zone 4 – Current and Proposed Projects  
Figure 22 – Zone 4 – Current and Proposed Projects (Cont.)  
Figure 23 – Zone 4 – Current and Proposed Projects (Cont.)  
Figure 24 – Zone 5 – Current and Proposed Projects  
Figure 25 – Zone 6 – Current and Proposed Projects  
Figure 26 – Zone 7 – Current and Proposed Projects  
Figure 27 – Tie Lines - Current and Proposed Projects  
Figure 28 – SPS – Quanta EHV Study – Alternate 2  
Figure 29 – High Plains Express Initiative  
Figure 30 – Tres Amigas Project  
Figure 31 – Multiple Grid Overlays  
Figure 32 – SPS EHV Alternative 2 and Texas CREZ Transmission Lines

### **Transmission Expansion Plan Scope For 2009 10 year Reliability Assessment Study TWG Approved November 2008 Updated May 2009**

#### **Introduction**

The main objective of the reliability review SPP Transmission Expansion Plan (STEP) is to create an effective long-range plan for the SPP footprint which identifies problems for normal conditions (no contingency) and (N-1) scenarios using NERC Reliability Standards, SPP Criteria, and local planning criteria and coordinating appropriate mitigation plans to meet the reliability needs of the SPP region. This analysis is not for NERC compliance reporting (NERC compliance will be facilitated through a different SPP process), but rather to meet SPP OATT, Attachment 'O' requirements to plan a reliable transmission system for the long term transmission service needs of the SPP system. In addition, projects which may produce an economic benefit to the stakeholders in the SPP footprint are evaluated. This process consists of the following steps:

1. Identification of the reliability based problems (SPP and local criteria)
2. Comprehensive assessment of known mitigation plans

Development of additional mitigation plans to meet the needs of the region and maintain SPP and Local reliability/planning standards

The process is open and transparent allowing for stakeholder input. All study results from the planning process will be coordinated with other entities/regions responsible for transmission needs assessment/planning.

#### **Expansion Plan Objectives**

##### **Reliability Planning**

- SPP shall plan the SPP Transmission System to meet:
  - SPP Criteria
  - SPP RTO approved Local Planning Criteria as requested by Transmission Owners (TO)
- Address additional needs of the region
- Assess mitigation plans proposed by TO (operating guides and/or new facilities)
- SPP shall track authorized and planned system upgrades to ensure reliability projects are built in time to meet the needs of the system. This will be accomplished through the SPP Project Tracking quarterly reporting process.
- SPP shall coordinate regional transmission plans with neighboring entities, regions and RTO's.

### Assumptions for Reliability Assessment

#### Load Flow Models

- SPP shall use the 2010 Summer Peak, 2010/11 Winter Peak for timing projects, and the 2011 Summer Peak, 2011/12 Winter Peak, Summer Peak, 2014 Summer Peak, 2014/15 Winter Peak and 2019 Summer Peak cases with updates from nearby regions and entities will be used in the contingency analysis. The STEP load flow cases will be built using 2009 series MDWG Models On Demand (MOD) process. The 2008 spring MDWG case will be used for the basic starting topology and MOD process will be used to determine load and which MOD project to include in the STEP model. The load and capacity forecast for the flow cases have included the impact on load of the existing and planned demand response resources. Due to the recent economic downturn a new load forecast will be incorporated into the load flow models in June 2009.
  - Treatment of Transmission Owner-Initiated Projects
    - SPP shall include Transmission Owner-Initiated Projects as determined by the Transmission Owner. MOD Type – Reliability, MOD Status STEP (w/NTC) or Planned
  - Treatment of previous SPP Transmission Expansion Plan Projects
    - All projects that have either an LOA/NTC shall be included in the model except for those that have been requested to be removed and have been through stakeholder review. MOD Type- Reliability, MOD Status TEP (w/NTC) or TO Planned
    - Due to the economic downturn requiring new load forecast and a short lead time to complete the STEP, stakeholders can request projects with NTCs to be re-evaluated if the request is received by June 1, 2009.
    - Balanced Portfolio projects with NTCs will be included in the June models. Projects with NTCs that have been identified as impacted by the Balanced Portfolio will be re-evaluated.
  - Treatment of SPP Aggregate Study (Attachment Z) Projects
    - All projects that have either an LOA/NTC shall be included in the model except for those that have been requested to be removed and have been through stakeholder review. MOD Type TSR, MOD Status w/NTC (Approved)
  - Treatment transmission interconnection facilities of new generation. Include the interconnection facilities with executed agreements not on suspension. MOD Type LGIP, MOD status W/GIP.
  - Include all MOD projects that have been energized. MOD Type Network, MOD type Energized.
  - Include all MOD project that change network topology status. Constructed facilities that are out-of-service or normally open. MOD Type Outage, MOD Status Outage
  - Include all MOD projects that update network data. MOD Type, MOD Status Update.
  - Scenario cases

## Appendix A– SPP STEP

- SPP will develop six scenario cases for each season for the steady state evolution
  - The “Zero case” has the same dispatch as the MDWG cases with the exception that generation that does not have a signed interconnection agreement and generation that does not have transmission service is also removed. The exception to this is in later years when generation load and interchange does not match the shortfall is made up of units that are in-service.
  - The “West to East” scenario 1 case is the same as the zero scenario case with the dispatch changed to capture transmission service that has been sold that impact West to East flowgates with ERCOTN HVDC Tie South to North, ERCOTE HVDC Tie East to West, SPS exporting, and SPS exporting from the Lamar HVDC Tie.
  - The “East to West” scenario 2 case is the same as the zero scenario case with the dispatch changed to capture transmission service that has been sold that impact East to West flowgates with ERCOTN HVDC tie North to South, ERCOTE HVDC tie East to West, SPS importing, and SPS importing from the Lamar HVDC Tie.
  - The “South to North” (Scenario 3) scenario case is the same as the zero scenario case with the dispatch changed to capture transmission service that has been sold that impact South to North flowgates with ERCOTN HVDC tie South to North, ERCOTE HVDC tie East to West, SPS exporting, and SPS exporting to the Lamar HVDC Tie.
  - The “North to South” (Scenario 4) scenario case is the same as the zero scenario case with the dispatch changed to capture transmission service that has been sold that impact North to South flowgates with ERCOTN HVDC tie North to South, ERCOTE HVDC tie East to West, SPS importing, and SPS importing from the Lamar HVDC tie.
  - The “All transactions” scenario 5 case is the same as the zero scenario case with the dispatch changed to include all transmission service sold with ERCOTN North to South, ERCOTE East to West, SPS importing and SPS exporting to the Lamar HVDC tie

### Methodology for Reliability Assessment

#### Steady State Analysis

- Monitoring of Facilities

- SPP staff shall monitor all facilities in the SPP footprint 69 kV and above.
  - With the exception of Entergy (EES) and Associated Electric (AECl), SPP staff shall monitor all facilities in first tier control areas 230 kV and above. Within EES and AECl, facilities shall be monitored at 100 kV and above.
- Normal conditions and Contingency analysis shall be performed on 2011 Summer Peak, 2011/12 Winter Peak, 2014 summer, 2014/15 Winter Peak and 2019 Summer Peak cases (including all transaction cases).
  - Normal conditions
  - All N-1 single-element contingencies 69 kV and above in SPP will be evaluated. These contingencies do not include manual transfer of load or manual switching.
  - All N-1 single-element contingencies 100 kV and above in EES, AECl, and all other first-tier companies will be evaluated.
  - SPP will verify that all normal conditions and N-1 violations identified have corrective plans

### Use of Transmission Operating Directives (TOD)

- The Steady State analysis will identify all violations without the use of TODs.
- TODs may be used as alternatives to planned projects. Load flow analysis will be performed to determine the effectiveness of the TOD in alleviating the violation(s).
- SPP staff will determine all reinforcements that are needed to eliminate TODs used in alleviating violation(s). A list of reinforcements that are not required due to TODs will be included in the report.

### **Demand Response**

To address demand response the STEP will incorporate lessons learned in the EIS market which need to be addressed in long range expansion planning, as well as identify potential applications of demand response as a resource option, along with a list of issues which must be addressed before any approvals can be made regarding their implementation.